

American National Standard
National Standard of Canada

**ASSE 1016-2017/ASME A112.1016-2017/
CSA B125.16-17 (R2021)**



Performance Requirements for
**Automatic Compensating Valves for
Individual Showers and Tub/Shower
Combinations**

ANSI Approved: October 2021
ICS Codes: 23 060 99, 91 140 70



ASMENORMDOC.COM : Click to view the full PDF of ASSE 1016 ASME A112.1016 CSA B125.16 2017

Legal Notice for Harmonized Standard Jointly Developed by ASME, ASSE, and CSA

Intellectual property rights and ownership

As between The American Society of Mechanical Engineers ("ASME"), ASSE International Chapter of IAPMO, LLC. ("ASSE"), and Canadian Standards Association ("CSA") (collectively "ASME, ASSE, and CSA") and the users of this document (whether it be in printed or electronic form), ASME, ASSE, and CSA are the joint owners of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. The unauthorized use, modification, copying, or disclosure of this document may violate laws that protect the intellectual property of ASME, ASSE, and CSA and may give rise to a right in ASME, ASSE, and CSA to seek legal redress for such use, modification, copying, or disclosure. ASME, ASSE, and CSA reserve all intellectual property rights in this document.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document's fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party's intellectual property rights. ASME, ASSE, and CSA do not warrant the accuracy, completeness, or currency of any of the information published in this document. ASME, ASSE, and CSA make no representations or warranties regarding this document's compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL ASME, ASSE, and CSA, THEIR RESPECTIVE VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF ASME OR CSA HAVE BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, ASME, ASSE, and CSA are not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and ASME, ASSE, and CSA accept no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

ASME, ASSE, and CSA have no power, nor do they undertake, to enforce compliance with the contents of the standards or other documents they jointly publish.

Authorized use of this document

This document is being provided by ASME, ASSE, and CSA for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by ASME, ASSE, and CSA to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way or remove this Legal Notice from the attached standard;
- sell this document without authorization from ASME, ASSE, and CSA; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



ASMENORMDOC.COM : Click to view the full PDF of ASSE 1016 ASME A112.1016 CSA B125.16 2017

Standards Update Service

***ASSE 1016-2017/
ASME A112.1016-2017/
CSA B125.16-17
February 2017***

Title: *Performance requirements for automatic compensating valves for individual showers and tub/shower combinations*

To register for e-mail notification about any updates to this publication

- go to shop.csa.ca
- click on **CSA Update Service**

The **List ID** that you will need to register for updates to this publication is **2424630**.

If you require assistance, please e-mail techsupport@csagroup.org or call 416-747-2233.

Visit CSA Group's policy on privacy at www.csagroup.org/legal to find out how we protect your personal information.

ASMENORMDOC.COM : Click to view the full PDF of ASSE 1016 ASME A112.1016 CSA B125.16 2017

ASSE 1016-2017/ASME A112.1016-2017/CSA B125.16-17
***Performance requirements for automatic
compensating valves for individual showers and
tub/shower combinations***



**CSA
Group**

®A trademark of the Canadian Standards Association and CSA America Inc., operating as "CSA Group"

Published in February 2017 by ASSE International
18927 Hickory Creek Drive, Suite 220, Mokena, Illinois 60447
(708) 995-3019

Visit us online at **www.asse-plumbing.org**
Visit our webstore at **www.assewebstore.com**

Commitment for Amendments

This Standard is issued jointly by The American Society of Mechanical Engineers (ASME), the ASSE International Chapter of IAPMO, LLC. (ASSE), and CSA Group. Amendments to this Standard will be made only after processing according to the Standards development procedures of ASME, ASSE, and CSA Group.

The American Society of Mechanical Engineers
(ASME) Two Park Avenue
New York, NY 10016-5990
USA
www.asme.org

ISBN 978-0-7918-7012-9
© 2017

The 2017 edition of this Standard is being issued with an automatic addenda subscription service. The use of addenda allows revisions made in response to public review comments or committee actions to be published as necessary.

Published in January 2017 by
CSA Group
A not-for-profit private sector organization
178 Rexdale Boulevard
Toronto, Ontario, Canada
M9W 1R3
1-800-463-6727 or 416-747-4044
Visit the CSA Group Online Store at
shop.csa.ca

ISBN 978-1-4883-0440-8
© CSA Group — 2017

All rights reserved. No part of this publication may be reproduced in any form whatsoever without the prior permission of the publisher.

ASSE International
18927 Hickory Creek Dr., Suite 220
Mokena, IL 60448
Tel: (708) 995-3019
Fax: (708) 479-6139
E-mail: general.info@asse-plumbing.org
www.asse-plumbing.org

© ASSE International — 2017

Contents

ASME A112 Standards Committee on Plumbing Materials and Equipment 3

ASSE Product Standards Committee 6

CSA Technical Committee on Plumbing Fittings 8

ASME/ASSE/CSA Harmonization Task Group on Plumbing Fittings 13

Preface 15

Section I 18

1 Scope 18

Section II 19

2 Reference publications and definitions 19

2.1 Reference publications 19

2.2 Definitions 19

Section III 20

3 Design and general requirements 20

3.1 Types of devices 20

3.2 Accessible designs 20

3.3 Minimum rated flow 20

3.4 Pressure 20

3.5 Temperature 20

3.6 Servicing 21

Section IV 21

4 Performance requirements and test methods 21

4.1 General 21

4.2 Conditioning 21

4.2.1 Preconditioning 21

4.2.2 High-temperature conditioning 21

4.3 Working pressure test 22

4.3.1 Purpose 22

4.3.2 Procedure with the valves closed 22

4.3.3 Procedure with the outlet(s) blocked 22

4.3.4 Test temperatures and pressures 22

4.3.5 Performance requirements 23

4.4 Maximum operating torque or force adjustment test 23

4.4.1 Purpose 23

4.4.2 Procedure 23

4.4.3 Performance requirements 23

4.5	Life cycle tests	23
4.5.1	Purpose	23
4.5.2	Procedure — Operating controls	23
4.5.3	Procedure — Internal elements	24
4.5.4	Working pressure	25
4.5.5	Maximum torque or operating force	25
4.5.6	Failure criteria	25
4.6	Pressure and temperature variation test	25
4.6.1	Purpose	25
4.6.2	Data gathering, all types of devices (see Figure 1)	25
4.6.3	Procedure — All types of devices (see Figure 1)	26
4.6.4	Procedure — Type P devices	26
4.6.5	Procedure — Type T devices	26
4.6.6	Procedure — Type T/P devices	27
4.6.7	Performance requirements — Type P devices	27
4.6.8	Performance requirements — Type T devices	27
4.6.9	Performance requirements — Type T/P devices	27
4.7	Water supply failure test — All types	27
4.7.1	Purpose	27
4.7.2	Procedure	27
4.7.3	Performance requirements	28
4.8	Mechanical temperature limit stop test	28
4.8.1	Purpose	28
4.8.2	Procedure	28
4.8.3	Performance requirements	28
4.9	Outlet temperature and flow capacity test	29
4.9.1	Purpose	29
4.9.2	Procedure for all devices (see Figure 1)	29
4.9.3	Performance requirements	29
4.10	Hydrostatic pressure test	30
4.10.1	Purpose	30
4.10.2	Procedure	30
4.10.3	Performance requirements	30

Section V 30

5	Markings, packaging, and installation instructions and included literature	30
5.1	Markings	30
5.1.1	General	30
5.1.2	Visibility of markings	30
5.1.3	Temperature control setting identification	30
5.2	Installation and maintenance instructions	30
5.2.1	Instructions	30
5.2.2	Temperature limit setting	31
5.3	Packaging	31

Annex A (informative) — Verifying the time constant of the temperature-measuring equipment	32
Annex B (informative) — Temperature variation for thermostatic-compensating valves	34

ASME A112 Standards Committee on Plumbing Materials and Equipment

W.M. Smith	American Society of Plumbing Engineers, Montgomery, Alabama, USA	<i>Chair</i>
R.K. Adler	City of San Jose, San Jose, California, USA	
J.A. Ballanco	JB Engineering & Code Consulting, PC, Munster, Indiana, USA	
J.E. Bertrand	Moen Incorporated, North Olmsted, Ohio, USA	
A. Bonlender	Bradley Corporation, Menomonee Falls, Wisconsin, USA	
R. Burnham	Zurn Industries LLC, Erie, Pennsylvania, USA	
M. Campos	ICC Evaluation Service, LLC, Brea, California, USA	
S.L. Cavanaugh	Cavanaugh Consulting, Santa Fe, New Mexico, USA	<i>Contributing Member</i>
W.E. Chapin	Professional Code Consulting, LLC, Cullman, Alabama, USA	
P.V. DeMarco	IAPMO, Dayton, New Jersey, USA	
N.E. Dickey	CSA Group, Cleveland, Ohio, USA	
F. DiFolco	CSA Group, Toronto, Ontario, Canada	<i>Alternate</i>
G.S. Duren	Code Compliance, Inc., S Pasadena, Florida, USA	

R. Emmerson	Consultant, Mundelein, Illinois, USA	
R.L. George	Plumb-Tech Design and Consulting Services L.L.C, Newport, Michigan, USA	
D. Glieberman	Sloan, Huntington Beach, California, USA	<i>Alternate</i>
C.N. Gross	IAPMO, Ontario, California, USA	<i>Alternate</i>
G.W. Harrison	Wayne Harrison Consulting, Edmond, Oklahoma, USA	
L. Himmelblau	Chicago Faucet, Des Plaines, Illinois, USA	
C.L. Jahrling	ASSE International, Chicago, Illinois, USA	<i>Contributing Member</i>
J.M. Koeller	Koeller and Co., Yorba Linda, California, USA	
N.M. Kummerlen	Consultant, Lorain, Ohio, USA	<i>Contributing Member</i>
C.J. Lagan	American Standard, Piscataway, New Jersey, USA	
J.W. Lauer	Sloan Valve Company, Huntington Beach, California, USA	
W.H. LeVan	Cast Iron Soil Pipe Institute, Panama City Beach, Florida, USA	
D. Liang	CSA Group, GuangZhou, China	<i>Alternate</i>
M. Malatesta	American Standard, Piscataway, New Jersey, USA	<i>Alternate</i>
D. Marbry	Fluidmaster, Inc., San Juan Capistrano, California, USA	

R. Mata	CSA Group, Cleveland, Ohio, USA	
L.A. Mercer	IAPMO, Valley City, Ohio, USA	<i>Alternate</i>
D. Orton	NSF International, Ann Arbor, Michigan, USA	
S. Rawalpindiwala	Kohler Co., Kohler, Wisconsin, USA	<i>Alternate</i>
S.A. Remedios	Remedios Consulting LLC, London, Ontario, Canada	
M. Sigler	Plumbing Manufacturers International, Rolling Meadows, Illinois, USA	
G. L. Simmons	Charlotte Pipe & Foundry, Charlotte, North Carolina, USA	
D. Viola	IAPMO, Mokena, Illinois, USA	
D.G. Waggoner	Charlotte Pipe & Foundry, Charlotte, North Carolina, USA	<i>Alternate</i>
J.C. Watson	Elkay Manufacturing, Oak Brook, Illinois, USA	
M. Weiss	Plumbing and Drainage Institute, Polson, Montana, USA	
W.C. Whitehead	Whitehead Consulting Services, Peabody, Massachusetts, USA	
A.L. Guzman	American Society of Mechanical Engineers, New York, New York, USA	<i>Staff Secretary</i>

ASSE Product Standards Committee

E. Lyczko	Cleveland Clinic (Ret.), Cleveland, Ohio, USA	<i>Chair</i>
W. Briggs	MGJ Associates, New York, New York, USA	
T. Burger	NSF International, Ann Arbor, Michigan, USA	
W.E. Chapin	Professional Code Consulting, LLC, Cullman, Alabama, USA	
M. Fish	Zurn Industries, LLC, Cary, North Carolina, USA	
R. George, CPD	Plumb-Tech Design & Consulting Services, LLC, Monroe, Michigan, USA	
D. Gleiberman	Sloan, Huntington Beach, California, USA	
J.F. Higdon	Apollo Valves/Conbraco Industries, Matthews, North Carolina, USA	
G. Howard	Plumbers Local Union 130, LaGrange, Illinois, USA	
C. Lott	Precision Plumbing Products, Portland, Oregon, USA	
P. Marzec	New York Chapter — ASSE International, Pearl River, New York, USA	
T.C. Pitcherello	Pennsylvania Chapter — ASSE International, Trenton, New Jersey, USA	
D. Rademacher	Plumbing Code & Design Consulting, Butte, Montana, USA	
S. Rawalpindiwala	Kohler Co., Kohler, Wisconsin, USA	

W.M. Smith American Society of Plumbing Engineers,
Montgomery, Alabama, USA

T-L. Su Stevens Institute of Technology — Center for
Environmental Systems,
Hoboken, New Jersey, USA

C. Jahrling ASSE International,
Mokena, Illinois, USA

Staff Engineer

ASMENORMDOC.COM : Click to view the full PDF of ASSE 1016 ASME A112.1016 CSA B125.16 2017

CSA Technical Committee on Plumbing Fittings

K. Ernst	Oakville Stamping & Bending Limited, Oakville, Ontario <i>Category: Producer Interest</i>	<i>Chair</i>
M. Antonacci	Woodbridge, Ontario	<i>Associate</i>
W.T. Ball	WCM Industries Inc., Colorado Springs, Colorado, USA	<i>Associate</i>
J.E. Bertrand	Moen Incorporated, North Olmsted, Ohio, USA <i>Category: Producer Interest</i>	
A. Bonlender	Bradley Corporation, Menomonee Falls, Wisconsin, USA	<i>Associate</i>
S. Breda	Omni Brass Inc., Vaughan, Ontario <i>Category: User Interest</i>	
T. Burke	Victoria + Albert Baths Ltd., Telford, United Kingdom	<i>Associate</i>
R. Burnham	Zurn Industries LLC, Erie, Pennsylvania, USA	<i>Associate</i>
M. Campos	International Code Council, Brea, California, USA	<i>Associate</i>
W.E. Chapin	Professional Code Consulting, LLC, Cullman, Alabama, USA	<i>Associate</i>
Y. Duchesne	Régie du bâtiment du Québec, Québec, Québec <i>Category: Regulatory Authority</i>	
C. Erickson	Underwriters Laboratories Inc., Northbrook, Illinois, USA	<i>Associate</i>

W. Falcomer	The Corporation of the City of Ottawa, Ottawa, Ontario <i>Category: Regulatory Authority</i>	
F. Fernández	Toto U.S.A. Inc., Ontario, California, USA	<i>Associate</i>
M.E. Fish	Zurn Industries, LLC, Washington, District of Columbia, USA	<i>Associate</i>
D. Gleiberman	Sloan, Los Angeles, California, USA	<i>Associate</i>
R. Green	Brass-Craft Manufacturing Co., Novi, Michigan, USA	<i>Associate</i>
M. Guard	International Code Council (ICC), Washington, District of Columbia, USA	<i>Associate</i>
R. Guinn	Oro-Medonte, Ontario <i>Category: User Interest</i>	
L. Himmelblau	Chicago Faucets Geberit Manufacturing Division, Des Plaines, Illinois, USA <i>Category: Producer Interest</i>	
E. Ho	IAPMO Research & Testing Inc., Markham, Ontario	<i>Associate</i>
E. Hood	H. H. Angus & Associates Ltd., Toronto, Ontario <i>Category: User Interest</i>	
K.S. Hui	Ontario Ministry of Municipal Affairs and Housing, Toronto, Ontario <i>Category: Regulatory Authority</i>	
C. Jahrling	ASSE International, Mokena, Illinois, USA	<i>Associate</i>
A. Knapp	A. Knapp & Associates, Toronto, Ontario <i>Category: General Interest</i>	

J. Knapton	Southern Alberta Institute of Technology, Calgary, Alberta <i>Category: General Interest</i>	
J.M. Koeller	Koeller and Company, Yorba Linda, California, USA <i>Category: General Interest</i>	
F. Lemieux	Health Canada, Ottawa, Ontario <i>Category: Regulatory Authority</i>	
D. Liang	CSA Group, Guangzhou, China	<i>Associate</i>
R. Liao	Xiamen Lota International Co. Ltd., Xiamen, China	<i>Associate</i>
J. MacDonald	BLANCO Canada Inc., Brampton, Ontario	<i>Associate</i>
M. Malatesta	American Standard Brands, d/b/a AS America, Inc., Piscataway, New Jersey, USA	<i>Associate</i>
D. Marbry	Fluidmaster Inc., San Juan Capistrano, California, USA	<i>Associate</i>
C. McLeod	Kohler Co. Plumbing Division, Kohler, Wisconsin, USA	<i>Associate</i>
D. McNamara	Franke Kindred Canada Limited, Midland, Ontario <i>Category: Producer Interest</i>	
M. Mohammed	Reliance Worldwide Corp. (Canada) Inc., Vaughan, Ontario	<i>Associate</i>
A.I. Murra	Abraham Murra Consulting, Oakville, Ontario	<i>Associate</i>
S.R. O'Neill	Mohawk College of Applied Arts and Technology, Stoney Creek, Ontario	<i>Associate</i>
D. Orton	NSF International, Ann Arbor, Michigan, USA	<i>Associate</i>

P. Paré	Masco Canada Limited, St. Thomas, Ontario <i>Category: Producer Interest</i>	
R. Pickering	Eastern Research Group, Inc. (ERG), Morrisville, North Carolina, USA	<i>Associate</i>
S.M. Rawalpindiwala	Kohler Co. Plumbing Division, Kohler, Wisconsin, USA <i>Category: Producer Interest</i>	
S.A. Remedios	Remedios Consulting LLC, London, Ontario <i>Category: User Interest</i>	
P. Saeed	Powers, A Division of Watts Water Technologies, Inc., Mt. Prospect, Illinois, USA <i>Category: Producer Interest</i>	
R. Sharma	U.S. Environmental Protection Agency, Washington, District of Columbia, USA	<i>Associate</i>
M. Sigler	Plumbing Manufacturers Int'l, Orlando, Florida, USA	<i>Associate</i>
W. Smith	American Society of Plumbing Engineers (ASPE), Montgomery, Alabama, USA <i>Category: General Interest</i>	
S. Sparling	Giffin Koerth Forensic Engineering, Toronto, Ontario <i>Category: General Interest</i>	
J. St-Denis	Intertek Testing Services NA Ltd. Services d'essais Intertek AN Ltee., Lachine, Québec	<i>Associate</i>
S. Tanner	U.S. Environmental Protection Agency, Washington, District of Columbia, USA <i>Category: General Interest</i>	
P. Tardif	National Research Council Canada, Canadian Codes Centre, Ottawa, Ontario	<i>Associate</i>

C.W. Trendelman	Bargersville, Indiana, USA	<i>Associate</i>
C. Tripodi	Moen Incorporated, Oakville, Ontario	<i>Associate</i>
D. Tyner	Delta Faucet Company, Indianapolis, Indiana, USA	<i>Associate</i>
J.C. Watson	Elkay, Oak Brook, Illinois, USA	<i>Associate</i>
S.P. Williams	Sioux Chief Manufacturing Company Inc., Caledonia, Ontario	<i>Associate</i>
C. Wright	Ontario Pipe Trades, Dundalk, Ontario <i>Category: User Interest</i>	
L. Pilla	CSA Group, Toronto, Ontario	<i>Project Manager</i>

ASME/ASSE/CSA Harmonization Task Group on Plumbing Fittings

R. George, CPD	Plumb-Tech Design & Consulting Services, LLC, Monroe, Michigan, USA	<i>Co-Chair</i>
F. Lemieux	Health Canada, Ottawa, Ontario, Canada	<i>Co-Chair</i>
M. Malatesta	American Standard, Piscataway, New Jersey, USA	<i>Co-Chair</i>
J.E. Bertrand	Moen Inc., North Olmsted, Ohio, USA	
M. Campos	ICC Evaluation Service, LLC, Whittier, California, USA	
W.E. Chapin	Professional Code Consulting, LLC, Cullman, Alabama, USA	
R. Cota	Leonard Valve, Cranston, New Jersey, USA	
N. Dickey	CSA Group, Cleveland, Ohio, USA	
J.F. Higdon	Apollo Valves/Conbraco Industries, Matthews, North Carolina, USA	
L. Himmelblau	Chicago Faucet Company, Des Plaines, Illinois, USA	
C. Jahrling	ASSE International, Mokena, Illinois, USA	
N.M. Kummerlen	Lorain, Ohio, USA	
E. Lyczko	Cleveland Clinic (Ret.), Cleveland, Ohio, USA	

D. Orton	NSF International, Ann Arbor, Michigan, USA	
S. Rawalpindiwala	Kohler Co., Kohler, Wisconsin, USA	
S.A. Remedios	Remedios Consulting, LLC, London, Ontario, Canada	
P. Saeed	Powers (a division of Watts Water Technologies, Inc.), Mt. Prospect, Illinois, USA	
W.M. Smith	American Society of Plumbing Engineers, Montgomery, Alabama, USA	
L. Pilla	CSA Group, Toronto, Ontario, Canada	<i>Project Manager</i>

Preface

This is the second edition of ASSE 1016/ASME A112.1016/CSA B125.16, *Performance requirements for automatic compensating valves for individual showers and tub/shower combinations*. It supersedes the previous edition published in 2011.

This Standard is considered suitable for use with conformity assessment within the stated scope of the Standard.

This Standard was prepared by the ASSE/ASME/CSA Harmonization Task Group on Plumbing Fittings, under the jurisdiction of the ASME A112 Main Committee, the ASSE Product Standards Committee, and the CSA Technical Committee on Plumbing Fittings. The CSA Technical Committee operates under the jurisdiction of the CSA Strategic Steering Committee on Construction and Civil Infrastructure.

This Standard will be submitted for formal approval by the ASME Standards Committee on Plumbing Materials and Equipment, the ASSE Product Standards Committee and the CSA Technical Committee. This Standard was approved as an American National Standard by the American National Standards Institute on January 6, 2017.

Notes:

- 1) *This standard was developed under procedures accredited as meeting the criteria for American National Standards and it is an American National Standard. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed Standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.*
- 2) *ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.*
- 3) *ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.*
- 4) *Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this standard.*
- 5) *ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.*
- 6) *ASME issues written replies to inquiries concerning interpretation of technical aspects of this Standard. All inquiries regarding this Standard, including requests for interpretations, should be addressed to:*

*Secretary, A112 Standards Committee
The American Society of Mechanical Engineers
Three Park Avenue
New York, NY 10016-5990*

Note: *A request for interpretation should be clear and unambiguous. The request should*

- *cite the applicable edition of the Standard for which the interpretation is being requested.*
- *phrase the question as a request for an interpretation of a specific requirement suitable for general understanding and use, not as a request for an approval of a proprietary design or situation. The inquirer may also include any plans or drawings, which are necessary to explain the question; however, they should not contain proprietary names or information.*

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME Committee.

Interpretations are published on the ASME Web site under the Committee Pages at <http://cstools.asme.org/> as they are issued.

Notes:

- 1) Use of the singular does not exclude the plural (and vice versa) when the sense allows.
- 2) Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.
- 3) This publication was developed by consensus, which is defined by CSA Policy governing standardization — Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity”. It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this publication.
- 4) To submit a request for interpretation of CSA Standards, please send the following information to inquiries@csa.ca and include “Request for interpretation” in the subject line:
 - a) define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;
 - b) provide an explanation of circumstances surrounding the actual field condition; and
 - c) where possible, phrase the request in such a way that a specific “yes” or “no” answer will address the issue.
 - d) Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are published in CSA’s periodical Info Update, which is available on the CSA website at <http://standardsactivities.csa.ca>.
- 5) CSA Standards are subject to periodic review, and suggestions for their improvement will be referred to the appropriate committee. To submit a proposal for change to CSA Standards, please send the following information to inquiries@csa.ca and include “Proposal for change” in the subject line:
 - a) Standard designation (number);
 - b) relevant clause, table, and/or figure number;
 - c) wording of the proposed change; and
 - d) rationale for the change.
- 6) Attention is drawn to the possibility that some of the elements of this Standard may be the subject of patent rights. CSA is not to be held responsible for identifying any or all such patent rights. Users of this Standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

ASSE Foreword

This Foreword is not part of the Standard; however, it is offered to provide background information.

Several suggestions received from persons having had a disturbing experience with shower valves which were potentially hazardous allowing sudden surges of high temperature water to flow from the shower head prompted the initiation of the ASSE 1016 standard in 1973. Documents and field experiences relating to the behavioural characteristics of different classes of devices were studied and evaluated, and from this, the standard text was developed. Since that time, extensive research has been conducted toward the development of this standard in its current form.

This harmonized Standard was developed in response to an industry request for a harmonized set of requirements between ASSE 1016-2005 and Clause 5.10 of ASME A112.18.1-2005/CSA B125.1-05. In recognition of energy and water efficiency requirements, which have further reduced the maximum flow rate requirements in certain areas, testing requirements to address the performance of shower valves rated for shower heads and body sprays rated at less than 9.5 L/min (2.5 GPM) flow rates were needed to be addressed.

In 2005 the CSA/ASME Joint Harmonization Task Group formed a task force FT-05-24 to accomplish this end. The TF was joined by members of ASSE and their historical 1016 Working Group. The first meeting was held on August 30, 2007.

The shower control valves covered by this Standard are only those which will, in cases of changes to the incoming water supply pressure or temperature, reduce the risk of scalding and thermal shock by protecting the bather from exposure to such changes in water temperature that produce these effects.

These devices generally have one cold water inlet connection, one hot water inlet connection, and a mixed water outlet connection(s).

This Standard provides engineers, designers, manufacturers, health authorities, inspection agencies and others with a set of minimum performance requirements for such individual automatic compensating valves.

Recognition is made of the time volunteered by members of the Joint Harmonization Task Group and Task Force, the ASME members, ASSE members and CSA members and of the support of the manufacturers who also participated in the meetings for this standard.

The Standard does not imply ASME, ASSE, or CSA's endorsement of a product which conforms with these requirements.

This Standard is considered suitable for use with conformity assessment within its stated scope.

It is recommended that these devices be installed consistent with local codes.

ASSE 1016-2017/ ASME A112.1016-2017/ CSA B125.16-17 **Performance requirements for automatic compensating valves for individual showers and tub/shower combinations**

Section I

1 Scope

1.1

This Standard applies to automatic compensating valves intended to be installed at the point of use, where the user has access to flow or final temperature controls, and where no further mixing occurs downstream of the device.

Note: In this Standard, automatic compensating valves are also referred to as devices.

1.2

This Standard covers automatic compensating valves intended to control the water temperature to wall or ceiling mounted

- a) hand-held showers;
- b) shower heads;
- c) body sprays either in individual shower or tub/shower combination fittings; and
- d) tub spouts when part of tub/shower combination fittings.

1.3

In this Standard, “shall” is used to express a requirement, i.e., a provision that the user is obliged to satisfy in order to comply with the standard; “should” is used to express a recommendation or that which is advised but not required; and “may” is used to express an option or that which is permissible within the limits of the Standard.

Notes accompanying clauses do not include requirements or alternative requirements; the purpose of a note accompanying a clause is to separate from the text explanatory or informative material.

Notes to tables and figures are considered part of the table or figure and may be written as requirements.

Annexes are designated normative (mandatory) or informative (non-mandatory) to define their application.

1.4

SI units are the units of record in Canada. In this Standard the inch/pound units are shown in parentheses.

The values stated in each measurement system are equivalent in application; however, each system is to be used independently. Combining values from the two measurement systems can result in non-conformance with this Standard.

All references to gallons are to U.S. gallons.

Section II

2 Reference publications and definitions

2.1 Reference publications

This Standard refers to the following publications, and where such reference is made, it shall be to the edition listed below, including all amendments published thereto.

ASME (The American Society of Mechanical Engineers)/CSA Group

ASME A112.18.1-2012/CSA B125.1-12

Plumbing supply fittings

ASSE International

Plumbing Dictionary Sixth Edition — 2007

2.2 Definitions

In addition to the definitions in ASME A112.18.1/CSA B125.1 and in the ASSE *Plumbing Dictionary*, the following definitions shall apply in this Standard:

Automatic compensating valve — a water-mixing valve that is supplied with hot and cold water and that provides a means of automatically maintaining the water temperature selected for an outlet.

Note: *Automatic compensating valves are used to reduce the risk of scalding and thermal shock.*

Combination pressure-balancing and thermostatic compensating valve (Type T/P) — a compensating valve that senses inlet supply hot and cold water pressures before mixing, senses the water temperature at the outlet, and compensates for pressure and thermal variations to maintain the water temperature at the outlet.

Pressure-balancing compensating valve (Type P) — a compensating valve that senses inlet supply hot and cold water pressures and compensates for variations in the inlet supply pressures to maintain the water temperature at the outlet.

Thermostatic compensating valve (Type T) — a compensating valve that senses the water temperature at the outlet and compensates for thermal variations to maintain the water temperature at the outlet.

Initial outlet set temperature — the average of the values of the mixed temperature measured at the outlet for the 10 s immediately preceding the temperature change measured at the outlet resulting from a pressure or temperature change.

Point-of-use — the final outlet of the water supply system just prior to discharge to atmosphere.

Temperature limit setting — an adjustable means to limit the maximum setting of the device towards the hot position limiting the maximum discharge temperature.

Thermal shock — a rapid change in the outlet water temperature that is felt by the user and is sufficient to produce a potentially hazardous reaction.

User — an individual who can adjust the outlet water temperature at the point of use while he or she is in contact with the outlet water.

Section III

3 Design and general requirements

3.1 Types of devices

3.1.1

The types of devices covered by this Standard and the type-specific requirements that they shall meet are

- a) Type P, Clause 4.6.7;
- b) Type T, Clause 4.6.8; and
- c) Type T/P, Clause 4.6.9.

3.1.2

Devices covered by this Standard shall comply with all the applicable requirements of this Standard and also comply with the applicable requirements of ASME A112.18.1/CSA B125.1.

3.2 Accessible designs

Devices intended for use in accessible designs shall comply with the requirements in Clause 4.6 of ASME A112.18.1/CSA B125.1.

3.3 Minimum rated flow

Devices shall comply with the requirements in this Standard when tested at the manufacturer's minimum rated flow of 9.5 L/min (2.5 gpm), whichever is lower.

3.4 Pressure

Devices shall be designed for a rated pressure between 140 and 860 kPa (20 and 125 psi).

3.5 Temperature

3.5.1

Devices shall be designed to be the final temperature control.

3.5.2

Devices shall be adjustable from the cold position up to at least 38 °C (100 °F) with hot water inlet temperatures ranging from 49 to 82 °C (120 to 180 °F) and cold water inlet temperatures ranging from 4 to 27 °C (40 to 80 °F).

3.5.3

Devices shall

- a) be equipped with an adjustable means to limit the setting towards the hot position;
- b) be capable of limiting the maximum outlet temperature to 49 °C (120 °F) or the manufacturer's stated maximum outlet temperature, whichever is less; and
- c) maintain an outlet temperature within ± 2.0 °C (± 3.6 °F) from the set temperature in accordance with Clause 4.6.

3.6 Servicing

The internal parts of concealed devices shall be accessible from the finished wall line for inspection, repairs, or replacement.

Section IV

4 Performance requirements and test methods

4.1 General

Tests shall be conducted on the same specimen, in the order listed in this Standard.

4.2 Conditioning

4.2.1 Preconditioning

Before testing, specimens shall be conditioned at ambient laboratory conditions for not less than 12 h.

4.2.2 High-temperature conditioning

4.2.2.1 Purpose

The purpose of the high-temperature conditioning is to determine if the device can withstand the maximum temperatures specified in Clause 3.5.


4.2.2.2 Procedure

Specimens shall be conditioned as follows:

- a) Set up the specimen in accordance with Figure 1, with shut off valves V1 and V2 and valve V3 in the full open position.
- b) Establish and maintain an equal flowing pressure of 310 ± 14 kPa (45 ± 2 psi) on both the hot and cold water supplies.
- c) Set the hot water temperature to $82 \pm 0, -6$ °C ($180 \pm 0, -10$ °F).
- d) Set the cold water temperature to 10 ± 3 °C (50 ± 5 °F).
- e) Adjust the outlet temperature to the maximum allowable outlet temperature, not exceeding 49 °C (120 °F).

- f) Adjust valve V3 to reduce the flow rate to 9.5 ± 1.0 L/min (2.5 ± 0.3 gpm) or the manufacturer's minimum rated flow $\pm 10\%$.
- g) Allow the water to flow through the specimen for 5 min.

Figure 1
Set-up for high-temperature conditioning, pressure
and temperature variation, and water supply pressure loss tests
(See Clauses 4.2.2.2, 4.4.2.2, 4.6.2, 4.6.3, 4.7.2.1, 4.8.2, and 4.9.2.)



4.3 Working pressure test

4.3.1 Purpose

The purpose of this test is to determine if the device can withstand pressures between 140 and 860 kPa (20 and 125 psi).

4.3.2 Procedure with the valves closed

The device shall be tested in accordance with Clause 4.3.4 with the device's valve in the closed position. The specimen shall be subjected to the pressures specified in Clause 4.3.1, for 5 min each.

4.3.3 Procedure with the outlet(s) blocked

The device shall be tested in accordance with Clause 4 with the device's valve in the fully open position. The outlet(s) shall then be blocked and the specimen shall be subjected to the pressures specified in Clause 4.3.1, for 5 min each.

4.3.4 Test temperatures and pressures

4.3.4.1

The test shall be conducted in an ambient environment of 20 ± 5 °C (68 ± 9 °F). The device shall be brought to equilibrium test temperatures by running water through it.

4.3.4.2

Test temperatures and pressures shall be as follows:

- a) 140 ± 14 kPa and 10 ± 6 °C (20 ± 2 psi and 50 ± 10 °F);
- b) 860 ± 14 kPa and 10 ± 6 °C (125 ± 2 psi and 50 ± 10 °F);
- c) 140 ± 14 kPa and 66 ± 6 °C (20 ± 2 psi and 150 ± 10 °F); and
- d) 860 ± 14 kPa and 66 ± 6 °C (125 ± 2 psi and 150 ± 10 °F).

4.3.5 Performance requirements

Leakage or other failures of the seals shall result in the rejection of the device.

4.4 Maximum operating torque or force adjustment test

4.4.1 Purpose

The purpose of this test is to determine the maximum torque or force required to adjust the device.

4.4.2 Procedure

4.4.2.1

The tests specified in Clause 5.5 of ASME A112.18.1/CSA B125.1 shall be conducted.

4.4.2.2

After the tests specified in Clause 4.4.2.1, the following tests shall be conducted:

- a) Set up the specimen as specified in Items a) to f) of Clause 4.6.3. See Figure 1.
- b) Move the adjusting mechanism of the specimen (e.g., handle(s) or lever(s)) through its full operating range. The force shall be applied at the extreme end of the adjusting mechanism.
- c) Record the maximum operating torque or force.

4.4.3 Performance requirements

A maximum operating torque or force to adjust the device exceeding the requirements specified in ASME A112.18.1/CSA B125.1 shall result in the rejection of the device.

4.5 Life cycle tests

4.5.1 Purpose

The purpose of these tests is to determine if there is any deterioration in the performance of the device upon completion of the following cycles of operation:

- a) The operating control test shall simulate the intended operating motion of the device.
- b) The internal elements test shall simulate inlet pressure and temperature changes.


4.5.2 Procedure — Operating controls

The life cycle test for operating controls shall be conducted as follows:

- a) Set up and test the specimen in accordance with the set-up and conditions specified in Figure 2 with valves V1 and V3 and the device's valve fully open. This test shall simulate the intended operating motion of the device without impacting the end stops, except as agreed to by the manufacturer.
- b) Prior to starting the test, the following conditions shall be established and maintained for 1 min:
 - i) 345 ± 35 kPa (50 ± 5 psi) flowing pressure as measured at the inlets;

- ii) $40 \pm 3 \text{ }^{\circ}\text{C}$ ($105 \pm 5 \text{ }^{\circ}\text{F}$) measured at the outlet;
 - iii) A minimum flow of 4.5 L/min (1.2 gpm) by adjusting valve V5; and
 - iv) the device's maximum outlet temperature adjusted to $49 +0, -6 \text{ }^{\circ}\text{C}$ ($120 +0, -10 \text{ }^{\circ}\text{F}$) using the device's temperature limit stop adjustment.
- c) The temperature and volume control mechanism(s) shall be tested for 20,000 cycles of the control dial, handle, or knob, cycled at a constant rate between 5 and 20 cycles per minute, as specified in Items i) to iv). The packing nut may be tightened once during the life cycle test to stop leakage. The testing shall be conducted as follows:
- i) Single-handle mixing valves of the cycling type: the control shall be operated from full-off to the full-on cold, position through full-on mixed to the full-on hot position, through full-on mixed to the full-on cold position, and back to the off position, to complete one cycle.
 - ii) Single-control mixing valves with combined volume and temperature control: the control shall be adjusted to operate the volume control from off to the full-on $40 \pm 3 \text{ }^{\circ}\text{C}$ ($105 \pm 5 \text{ }^{\circ}\text{F}$) position, to the full-on cold position, to the full-on hot limit stop position, to the $40 \pm 3 \text{ }^{\circ}\text{C}$ ($105 \pm 5 \text{ }^{\circ}\text{F}$) position, to the off position, to complete one cycle.
 - iii) Devices with a separate volume control: the volume control shall be turned full-on, the temperature control dial shall be turned through its full operating range and back, the volume control shall be turned off to complete one cycle.
 - iv) Single-handle mixing valves that only have temperature control: the testing laboratory shall provide a shut-off valve, and the device shall be tested in accordance with Clause 4.5.2 c) iii).

Figure 2
Set-up for life cycle test for automatic compensating valves
(See Clauses 4.5.2 and 4.5.3.)



4.5.3 Procedure — Internal elements

The life cycle test for internal elements shall be conducted as follows:

- a) Set up and test the specimen in accordance with the set-up and conditions specified in Figure 2 with valves V1, V3, and the device's valve fully open.
- b) Before starting the test, establish and maintain for 1 min the following conditions:
 - i) $345 \pm 35 \text{ kPa}$ ($50 \pm 5 \text{ psi}$) flowing pressure as measured at the inlets;
 - ii) $40 \pm 3 \text{ }^{\circ}\text{C}$ ($105 \pm 5 \text{ }^{\circ}\text{F}$) measured at the outlet; and
 - iii) A minimum flow of 4.5 L/min (1.2 gpm) by adjusting valve V5.
- c) Change the conditions to those described in Step 1 of Table 1 and maintain for 4 s, then change the conditions to Step 2 in Table 1 and maintain for 4 s. Return to the beginning conditions in Step 1 to complete one cycle.

- d) Test the internal elements for 80,000 cycles in accordance with Table 1.

Table 1
Life cycle test for the control mechanism
(See Clause 4.5.3.)

	Valve 1	Valve 2	Valve 3	Valve 4	Duration
Step 1	Open	Closed	Closed	Open	4 s
Step 2	Closed	Open	Open	Closed	4 s

4.5.4 Working pressure

The device shall be retested in accordance with Clause 4.3.

4.5.5 Maximum torque or operating force

The device shall be retested in accordance with Clause 4.4.

4.5.6 Failure criteria

During the test, leakage or the need to tighten the packing nut more than once shall result in a rejection of the device.

During the test specified in Clause 4.5.4, any leakage shall result in the rejection of the device.

During the test specified in Clause 4.5.5, an operating torque or force that exceeds 120% of the requirements of Clause 4.4 shall result in the rejection of the device. Accessible designs shall not exceed the requirements specified in Clause 4.4.

4.6 Pressure and temperature variation test

4.6.1 Purpose

The purpose of this test is to determine if the outlet water temperature at the point-of-use is maintained within a set temperature range.

4.6.2 Data gathering, all types of devices (see Figure 1)

Data shall be gathered as follows:

- The temperature-recording device shall be started 10 s before the step changes.
- Temperature measurements shall be taken at temperature sensors T1, T2, and T3 with measuring equipment capable of detecting a 63.2% step change within 0.3 s with a frequency rate of 20 Hz (one value every 0.05 s) for 25 ± 5 s unless otherwise specified in this Standard. See Annex A.
- The outlet temperature measurements at sensor T3 shall be averaged every 0.25 s.
- Temperature sensors T1, T2, and T3 shall be located as follows:
 - temperature sensors T1, T2, and T3, within the flow stream in Type K or Type L copper water tube;
 - temperature sensors T1 and T2, within 914 mm (36 in) of the device; and
 - temperature sensor T3, within 914 ± 13 mm (36 ± 0.5 in) from the outlet of the device. The outlet tube shall be the same size as the outlet connection size of the device.

Notes:

- For verifying the time constant of the temperature-measuring equipment, see Annex A.
- Data can be gathered in formats similar to those depicted in Figures B.1 to B.5.

4.6.3 Procedure — All types of devices (see Figure 1)

Controllers with pressure feedback loops shall not be active during the tests, but may be used to set the test parameters.

Note: *Controllers with pressure feedback loops interact with the specimen and result in inaccurate test results.*

The pressure and temperature variation test shall be conducted as follows:

- Set up the specimen as shown in Figure 1, with valves V1, V2, and V3 and the device's valve in the fully open position.
- Adjust and maintain the hot and cold water flowing pressures directly upstream of the inlet connections to a flowing pressure of 310 ± 14 kPa (45 ± 2 psi), as measured by gauges G1 and G2.
- Adjust the temperatures at temperature sensors T1 and T2 so that there is a temperature differential of 44 to 56 °C (80 to 100 °F) between the hot water temperature [minimum of 60 °C (140 °F)] and the cold water temperature [maximum of 21 °C (70 °F)]. After the hot water and cold water inlet temperatures are established, maintain the inlet temperatures at ± 1 °C (± 2 °F).
- Adjust the device so that the outlet temperature at temperature sensor T3 (point of use outlet) is 40.5 ± 0.5 °C (105.0 ± 1.0 °F).
- Adjust valve V3 so that the device delivers 9.5 ± 1.0 L/min (2.5 ± 0.3 gpm) and maintain the conditions established in Items b) to d) or, if the manufacturer's minimum rated flow is less than 9.5 ± 1.0 L/min (2.5 ± 0.3 gpm), adjust valve V3 to the manufacturer's minimum rated flow +1.0, -0.0 L/min (+0.3, -0.0 gpm) and maintain the conditions established in Items b) to d).
Note: *Adjustments in Items b) to e) are an iterative process.*
- Flow water through the device for 1 min.
- Record the initial outlet set temperature.

4.6.4 Procedure — Type P devices

The pressure changes specified in this Section shall be accomplished in less than 1 s. In addition to the procedures specified in Clauses 4.6.2 and 4.6.3, the following test procedure shall be conducted:

- Decrease the hot water flowing pressure by 50% to 155 ± 14 kPa (22.5 ± 2 psi). Observe and record the temperature changes at the outlet temperature sensor T3 for 25 ± 5 s.
- Restore the conditions as described in Clause 4.6.3. Increase the hot water flowing pressure by 50% to 465 ± 14 kPa (67.5 ± 2 psi). Observe and record the temperature changes at the outlet temperature sensor T3 for 25 ± 5 s.
- Restore the conditions as described in Clause 4.6.3. Decrease the cold water flowing pressure by 50% to 155 ± 14 kPa (22.5 ± 2 psi). Observe and record the temperature changes at the outlet temperature sensor T3 for 25 ± 5 s.
- Restore the conditions as described in Clause 4.6.3. Increase the cold water flowing pressure by 50% to 465 ± 14 kPa (67.5 ± 2 psi). Observe and record the temperature changes at the outlet temperature sensor T3 for 25 ± 5 s.

4.6.5 Procedure — Type T devices

The pressure changes specified in this Section shall be accomplished in less than 1 s. In addition to the procedures specified in Clauses 4.6.2 and 4.6.3, the following test procedure shall be conducted:

- Decrease the hot water flowing pressure by 20% to 248 ± 14 kPa (36 ± 2 psi). Observe and record temperature changes at the outlet temperature sensor T3 for 25 ± 5 s.
- Restore conditions as described in Items a) to g) of Clause 4.6.3. Increase the hot water flowing pressure by 20% to 372 ± 14 kPa (54 ± 2 psi). Observe and record the temperature changes at the outlet temperature sensor T3 for 25 ± 5 s.

- c) Restore conditions as described in Items a) to g) of Clause 4.6.3. Decrease the cold water flowing pressure by 20% to 248 ± 14 kPa (36 ± 2 psi). Observe and record the temperature changes at the outlet temperature sensor T3 for 25 ± 5 s.
- d) Restore conditions as described in Items a) to g) of Clause 4.6.3. Increase the cold water flowing pressure by 20% to 372 ± 14 kPa (54 ± 2 psi). Observe and record the temperature changes at the outlet temperature sensor T3 for 25 ± 5 s.
- e) Restore conditions as described in Items a) to g) of Clause 4.6.3. Increase the hot water supply temperature by 14 ± 0.5 °C (25 ± 1 °F) at a rate of 3 ± 0.5 °C (5 ± 1 °F) per minute. Observe and record the temperature changes at the outlet temperature sensor T3 for 25 ± 5 s.

4.6.6 Procedure — Type T/P devices

Type T/P devices shall be tested in accordance with Clauses 4.6.4 and 4.6.5.

4.6.7 Performance requirements — Type P devices

When tested in accordance with Clause 4.6.4, an outlet temperature variation exceeding ± 2.0 °C (± 3.6 °F) from the initial outlet set temperature at the outlet temperature sensor T3 shall result in a rejection of the device.

4.6.8 Performance requirements — Type T devices

When tested in accordance with Clause 4.6.5, the temperature change from the initial outlet set temperature shall not

- a) within the initial 5 s following a temperature change at sensor T3,
 - i) exceed $+3.0$ °C ($+5.4$ °F) for more than 1.5 s (see Figures B.1 and B.3); and
 - ii) exceed -5.0 °C (-9.0 °F) for more than 1 s (see Figures B.2 and B.3); and
- b) after the initial 5 s following a temperature change at sensor T3, exceed ± 2.0 °C (± 3.6 °F) (see Figure B.3).

4.6.9 Performance requirements — Type T/P devices

When tested in accordance with Clause 4.6.6, an outlet temperature variation exceeding ± 2.0 °C (± 3.6 °F) from the initial outlet set temperature at the outlet temperature sensor T3 shall result in a rejection of the device.

4.7 Water supply failure test — All types

4.7.1 Purpose

The purpose of the water supply failure test is to determine if the device automatically reduces the discharge flow to reduce the risk of scalding and thermal shock of the user when the water supply is suddenly interrupted.

4.7.2 Procedure

4.7.2.1

The specimen shall be set up as shown in Figure 1 and in accordance with the conditions specified in Items a) to f) of Clause 4.6.3.

4.7.2.2

After the device flows for 1 min at the parameters specified in Clause 4.7.2.1, the following tests shall be conducted:

- Close the cold water supply valve within 1 s (cold water supply failure test). Continuously record the outlet temperature at sensor T3 and flow rate for 5 s after the cold water supply valve has been fully closed.
- Re-establish the initial test parameters specified in Clause 4.7.2.1.
- Repeat the test by closing the hot water supply valve within 1 s (hot water supply failure test). Continuously record the outlet temperature at sensor T3 and flow rate for 5 s after the hot water supply valve has been fully closed.

4.7.3 Performance requirements

When tested in accordance with Clause 4.7.2, failure of the device to reduce the flow to 1.9 L/min (0.5 gpm) or 30% of the manufacturer's minimum rated flow, whichever is less, within 5 s, shall result in a rejection of the device.

During the procedure specified in Clause 4.7.2.2 a) (i.e., the cold water supply failure test), failure of the device to reduce the flow to 1.9 L/min (0.5 gpm) or 30% of the manufacturer's minimum rated flow, whichever is less, prior to the water temperature at sensor T3 exceeding 49 °C (120 °F) shall result in a rejection of the device.

4.8 Mechanical temperature limit stop test

4.8.1 Purpose

The purpose of the mechanical temperature limit stop test is to ensure that the temperature control that stops against a limit stop can maintain its set position.

4.8.2 Procedure

The mechanical temperature limit stop test shall be conducted as follows:

- Set up the specimen in accordance with Figure 1.
- Pressurize the hot and cold water inlets to 310 ± 14 kPa (45 ± 2 psi).
- Flow water through the device at a rate of 9.5 ± 1.0 L/min (2.5 ± 0.3 gpm) or the manufacturer's minimum rated flow $\pm 10\%$, whichever is less.
- Set the cold inlet temperature at 10 ± 3 °C (50 ± 5 °F).
- Set the hot inlet temperature at 82 ± 0 , -6 °C (180 ± 0 , -10 °F).
- Set the limit stop to an outlet temperature of 46 ± 0 , -3 °C (115 ± 0 , -5 °F), or the manufacturer's specified maximum temperature, whichever is less.
- Set the device at the full hot position, flow for 1 min, and measure and record the outlet temperature at sensor T3.
- Apply a torque of $5.1 \text{ N}\cdot\text{m}$ ($45.0 \text{ lbf}\cdot\text{in}$) to the temperature control (handle or valve stem) for 20 ± 5 s.
- While applying the torque specified in Item h) and for 1 min after, measure and record the outlet temperature at sensor T3.

4.8.3 Performance requirements

When tested in accordance with Clause 4.8.2, the device shall be rejected if

- the outlet temperature measured in Clause 4.8.2 i) exceeds the outlet temperature recorded in Clause 4.8.2 g) by 2.0 °C (3.6 °F); or

- b) there are any observable fractures in the limit stop.

4.9 Outlet temperature and flow capacity test

4.9.1 Purpose

The purpose of the outlet temperature and flow capacity test is to determine compliance with the design requirements of Clauses 3.3 and 3.5.

4.9.2 Procedure for all devices (see Figure 1)

The outlet temperature and flow capacity test shall be conducted as follows:

- a) Set up the specimen as shown in Figure 1, with valves V1, V2, and V3 in the fully open position.
- b) Set the hot and cold water flowing pressures directly upstream of the inlet connections to 310 ± 14 kPa (45 ± 2 psi), as measured by gauges G1 and G2.
- c) After the hot water and cold water inlet temperatures are established in Item e) i) to iv) of this Clause, maintain these inlet temperatures within ± 1.0 °C (± 2.0 °F) without exceeding the limits specified in Item e) i) to iv) of this Clause.
- d) Adjust valve V3 so that the device delivers 9.5 ± 1.0 L/min (2.5 ± 0.3 gpm) and maintain the conditions established in Items b) to d) of this Clause, or if the manufacturer's minimum rated flow is less than 9.5 ± 1.0 L/min (2.5 ± 0.3 gpm), adjust valve V3 to the manufacturer's minimum rated flow $+1.0$, -0.0 L/min ($+0.3$, -0.0 gpm) and maintain the conditions established in Items b) to d) of this Clause.

Note: Adjustments in Items b) to d) are an iterative process.

- e) The temperature limit stop and the valve V3 may be readjusted to conduct the following tests:
 - i) Set the cold inlet temperature to 10 ± 3 °C (50 ± 5 °F) and the hot inlet temperature to $49 +0$, -3 °C ($120 +0$, -5 °F). Set the device to the full cold position and then adjust the device to an outlet temperature of $38 +3$, -0 °C ($100 +5$, -0 °F). Flow for 1 min and record the outlet temperature and flow.
 - ii) Set the cold inlet temperature to 10 ± 3 °C (50 ± 5 °F) and the hot inlet temperature to $82 +0$, -6 °C ($180 +0$, -10 °F). Set the device to the full cold position and then adjust the device to an outlet temperature of $38 +3$, -0 °C ($100 +5$, -0 °F). Flow for 1 min and record the outlet temperature and flow. Set the temperature limit stop to a maximum outlet temperature of 49 °C (120 °F). Set the device at the full hot position, flow for 1 min, and record the outlet temperature.
 - iii) Set the cold inlet temperature to $27 +0$, -6 °C ($80 +0$, -10 °F) and the hot inlet temperature to $82 +0$, -6 °C ($180 +0$, -10 °F). Set the device to the full cold position and then adjust the device to an outlet temperature of $38 +3$, -0 °C ($100 +5$, -0 °F). Flow for 1 min and record the outlet temperature and flow. Set the temperature limit stop to a maximum outlet temperature of 49 °C (120 °F). Set the device at the full hot position, flow for 1 min, and record the outlet temperature.
 - iv) Set the cold inlet temperature to $27 +0$, -6 °C ($80 +0$, -10 °F) and the hot inlet temperature to $49 +0$, -3 °C ($120 +0$, -5 °F). Maintain a minimum outlet temperature of $38 +3$, -0 °C ($100 +5$, -0 °F). Flow for 1 min and record the outlet temperature and flow.

4.9.3 Performance requirements

When tested in accordance with Clause 4.9.2, the device shall be rejected if it

- a) fails to flow a minimum of 8.5 L/min (2.3 gpm) or the manufacturer's minimum rated flow;
- b) cannot be adjusted to a minimum of 38 °C (100 °F) outlet water temperature; or
- c) cannot limit the outlet temperature to a maximum of 49 °C (120 °F).

4.10 Hydrostatic pressure test

4.10.1 Purpose

The purpose of this test is to determine if any leakage occurs at a hydrostatic pressure of 3,450 kPa (500 psi).

4.10.2 Procedure

With the outlet(s) blocked and seating member(s) fully open, the device's body shall be pressurized to $3,450 \pm 35$ kPa (500 ± 5 psi) for 1 min with water at ambient temperature.

4.10.3 Performance requirements

When tested in accordance with Clause 4.10.2, any leakage shall result in a rejection of the device.

Section V

5 Markings, packaging, and installation instructions and included literature

5.1 Markings

5.1.1 General

Devices covered by and complying with this Standard shall be marked with

- the name of the manufacturer, trademark, or other mark known to identify the manufacturer or, in the case of private labelling, the name, trademark, or other mark of the customer for whom the device was manufactured;
- the model; and
- the type of the device (e.g., Type P, Type T, or Type T/P).

5.1.2 Visibility of markings

Markings shall be clear, permanent, and visible after installation (e.g., during field servicing).

5.1.3 Temperature control setting identification

Devices shall have identifiable control settings

- in which the settings are indicated by words (e.g., "cold", "warm", or "hot"), numbers, or graphically (e.g., colour coding); and
- that indicate the direction or means of adjustment to change the temperature.

5.2 Installation and maintenance instructions

5.2.1 Instructions

Manufacturer's instructions for installation, adjustment, and maintenance of the device shall be packaged with each device.

If the device is not equipped with an integral shut-off, the instructions shall provide a warning to install check valves on the inlets.