

INTERNATIONAL STANDARD



GROUP SAFETY PUBLICATION

Safety requirements for electrical equipment for measurement, control, and laboratory use –

Part 2-012: Particular requirements for climatic and environmental testing and other temperature conditioning equipment

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IECNORM.COM : Click to view the full text of IEC 60399-012:2019 RLV



IEC 61010-2-012

Edition 2.0 2019-04
REDLINE VERSION

INTERNATIONAL STANDARD



GROUP SAFETY PUBLICATION

**Safety requirements for electrical equipment for measurement, control, and laboratory use –
Part 2-012: Particular requirements for climatic and environmental testing and other temperature conditioning equipment**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 19.080

ISBN 978-2-8322-6838-4

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	4
INTRODUCTION	7
1 Scope and object	10
2 Normative references	11
3 Terms and definitions	12
4 Tests	17
5 Marking and documentation	24
6 Protection against electric shock	33
7 Protection against mechanical HAZARDS	35
8 Resistance to mechanical stresses	37
9 Protection against the spread of fire	37
10 Equipment temperature limits and resistance to heat	39
11 Protection against HAZARDS from fluids and solid foreign objects	43
12 Protection against radiation, including laser sources, and against sonic and ultrasonic pressure	58
13 Protection against liberated gases and substances, explosion and implosion	60
14 Components and subassemblies	62
15 Protection by interlocks	63
16 HAZARDS resulting from application	65
17 RISK assessment	66
Annexes	67
Annex K (normative) Insulation requirements not covered by 6.7	68
Annex L (informative) Index of defined terms	69
Annex AA (informative) Useful symbols	71
Annex BB (informative) Protection for of people who are inside WALK-IN EQUIPMENT	74
Annex CC (informative) Safety requirements for components and piping	76
Annex DD (informative) Equipment containing FLAMMABLE REFRIGERANTS – Information and marking requirements	81
Annex EE (normative) Non-sparking "n" electrical device	84
Bibliography	85
Figure 101 – Schema of a REFRIGERATING SYSTEM incorporating a CONDENSER	8
Figure 102 – Flow chart illustrating the selection process	9
Figure 103 – Details of scratching TOOL tip	53
Table 1 – Symbols	24
Table 101 – Time-temperature conditions	30
Table 102 – Maximum temperatures for MOTOR-COMPRESSORS	40
Table 103 – Minimum temperature for the determination of SATURATED-VAPOUR PRESSURE of the REFRIGERANT	48
Table 104 – REFRIGERANT flammability parameters	56
~~Table 105 – Lamp or lamp systems considered photobiologically safe~~	~~.....~~

~~Table 106 – Lamp or lamp systems considered photobiologically safe under certain conditions~~

Table AA.1 – Useful symbols	71
Table CC.1 – Parameters of pressure vessels according to EN 14276-1	76
Table CC.2 – Parameters of piping according to EN 14276-2	78
Table CC.3 – Components and piping requirements.....	79
Table CC.4 – Minimum wall thickness for copper and steel tubing	80

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV

INTERNATIONAL ELECTROTECHNICAL COMMISSION

SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL, AND LABORATORY USE –

Part 2-012: Particular requirements for climatic and environmental testing and other temperature conditioning equipment

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

International Standard IEC 61010-2-012 has been prepared by IEC technical committee 66: Safety of measuring, control and laboratory equipment.

It has the status of a group safety publication in accordance with IEC Guide 104.

This second edition cancels and replaces the first edition published in 2016. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) alignment with changes introduced by Amendment 1 of IEC 61010-1:2010;
- b) changes related to the use of small capitals for defined terms only;
- c) clarifications for cooling tests in 4.4.2.10;
- d) requirements for overtemperature protection in 10.101, including deletion of the second part of the sentence in item b), and the deletion of item c);
- e) changes pertaining to the accurate employment of terms "temperature", "operating temperature", "working temperature", "application temperature", "room temperature" and "ambient temperature" in 3.5.104, 3.5.105, 4.3.1, 4.3.2, 5.4.2, 8.2.1, 8.2.2, 11.7.2.101.2, 11.7.2.101.3, 13.2.102, 14.102, 15.101, 15.102, 15.103, introduction and many other locations. For the purpose of clarification, the definition of 3.5.114, CONTROLLED TEMPERATURE, is added.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
66/687/FDIS	66/688/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61010 series, published under the general title, *Safety requirements for electrical equipment for measurement, control, and laboratory use*, can be found on the IEC website.

IEC 61010-2-012 is to be used in conjunction with the latest edition of IEC 61010-1. It was established on the basis of the third edition (2010) and its Amendment 1 (2016), hereinafter referred to as Part 1.

This Part 2-012 supplements or modifies the corresponding clauses in IEC 61010-1 so as to convert that publication into the IEC standard: *Particular requirements for climatic and environmental testing and other temperature conditioning equipment*.

Where a particular subclause of Part 1 is not mentioned in this Part 2-012, that subclause applies as far as is reasonable. Where this Part 2-012 states "addition", "modification", "replacement", or "deletion", the relevant requirement, test specification, or note in Part 1 should be adapted accordingly.

In this standard:

- 1) the following print types are used:
 - requirements and definitions: in roman type;
 - NOTES: in smaller roman type;

- *conformity and tests: in italic type;*
- terms used throughout this standard which have been defined in Clause 3: SMALL ROMAN CAPITALS.

2) subclauses, figures, tables and notes which are additional to those in Part 1 are numbered starting from 101. Additional annexes are lettered starting from AA.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this standard using a colour printer.

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV

INTRODUCTION

This Part 2-012, ~~in conjunction~~ along with Part 2-010 and Part 2-011, ~~taken together~~, address the specific HAZARDS associated with the heating and cooling of materials by equipment and are ~~segregated~~ organized as follows:

IEC 61010-2-010	Specifically addresses the HAZARDS associated with equipment incorporating heating systems.
IEC 61010-2-011	Specifically addresses the HAZARDS associated with equipment incorporating REFRIGERATING SYSTEMS.
IEC 61010-2-012	Specifically addresses the HAZARDS associated with equipment incorporating both heating and REFRIGERATING SYSTEMS that interact with each other such that the combined heating and ~~cooling~~ REFRIGERATING SYSTEM yield additional or more severe HAZARDS for the two systems than if treated separately. It also addresses the HAZARDS associated with the treatment of materials by other factors like irradiation, excessive humidity, CO ₂ and MECHANICAL MOVEMENT, etc.

Guidance for the application of the appropriate Part 2 standard(s)

When the equipment includes only a material heating system, and no REFRIGERATING SYSTEM or other environmental factors apply, then Part 2-010 applies without needing Part 2-011 or Part 2-012. Similarly, when the equipment includes only a REFRIGERATING SYSTEM, and no material heating system or other environmental factors apply, then Part 2-011 applies without needing Part 2-010 or Part 2-012. However, when the equipment incorporates both a material heating system, and a REFRIGERATING SYSTEM or the materials being treated in the intended application introduce significant heat into the REFRIGERATING SYSTEM, a determination should be made ~~as to~~ whether the interaction between the two systems will generate additional or more severe HAZARDS than if the systems were evaluated separately (~~application~~ CONTROLLED TEMPERATURE, see flow chart for selection process). If the interaction of the heating and cooling functions yields no additional or more severe HAZARDS, then both Part 2-010 and Part 2-011 apply for their respective functions. Conversely, if additional or more severe HAZARDS result from the combining of the heating and cooling functions, or if the equipment incorporates additional material treatment factors, then Part 2-012 applies, but not Part 2-010 or Part 2-011.

What HAZARDS are applicable for a REFRIGERATING SYSTEM?

The typical HAZARDS for a REFRIGERATING SYSTEM (see Figure 101) consisting of a MOTOR-COMPRESSOR, a CONDENSER, an expansion device and an EVAPORATOR include but are not limited to:

- The maximum temperature of LOW-PRESSURE SIDE (return temperature) to the MOTOR-COMPRESSOR. A MOTOR-COMPRESSOR incorporates a REFRIGERANT cooled motor and it should be established that the maximum temperatures of the LOW-PRESSURE SIDE under least favourable condition do not exceed the insulation RATINGS within the motor.
- The maximum pressure of LOW-PRESSURE SIDE at the inlet to the MOTOR-COMPRESSOR. The housing of the MOTOR-COMPRESSOR is exposed to this pressure and so the design RATING of the MOTOR-COMPRESSOR housing should accommodate the worst-case pressures whilst providing the correct safety margin for a pressure vessel.
- The maximum temperature of HIGH-PRESSURE SIDE to the CONDENSER. The temperatures of the HIGH-PRESSURE SIDE under most unfavourable conditions may present a temperature HAZARD if the OPERATOR is exposed to them or if the electrical insulation is degraded.
- The maximum pressure of HIGH-PRESSURE SIDE at the outlet to the MOTOR-COMPRESSOR. The REFRIGERANT components downstream of the MOTOR-COMPRESSOR up to the expansion device are exposed to this pressure and so the design RATING of these components should accommodate the worst-case pressures whilst providing the appropriate safety margin for a pressure vessel.

- The maximum ~~application~~ CONTROLLED TEMPERATURES, namely, the SOAKED TEMPERATURE CONDITIONS, from which the heat is being extracted, may impact the maximum temperature of LOW-PRESSURE SIDE to the MOTOR-COMPRESSOR as well as present a temperature HAZARD if the OPERATOR is exposed to them or if the electrical insulation is degraded. Whether this ~~application~~ CONTROLLED TEMPERATURE is derived from an integral heating function of the device or from the heat dissipated from the material being cooled, the impact under worst case conditions should be evaluated.
- The current draw of the equipment should be established when including the worst-case running conditions of the REFRIGERATING SYSTEM including any defrost cycles that may apply.

The worst-case conditions should be determined for the equipment and will include both the least favourable NORMAL USE conditions as well as the most unfavourable testing results under SINGLE FAULT CONDITIONS.





Figure 101 – Schema of a REFRIGERATING SYSTEM incorporating a CONDENSER

The selection process is illustrated in the following flow chart (see Figure 102).



IEC

Figure 102 – Flow chart illustrating the selection process

SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL AND LABORATORY USE –

Part 2-012: Particular requirements for climatic and environmental testing and other temperature conditioning equipment

1 Scope and object

This clause of Part 1 is applicable except as follows:

1.1.1 Equipment included in scope

Replacement:

Replace the ~~first~~ ~~second~~ paragraph by the following:

~~This group safety publication is primarily intended to be used as a product safety standard for the products mentioned in the scope, but shall also be used by technical committees in the preparation of their publications for products similar to those mentioned in the scope of this standard, in accordance with the principles laid down in IEC Guide 104 and ISO/IEC Guide 51.~~

This part of IEC 61010 specifies safety requirements for electrical equipment and its accessories within the categories a) through c), wherever it is intended to be used, whenever that equipment incorporates one or more of the following characteristics:

- A REFRIGERATING SYSTEM that is acted on or impacted by an integral heating function such that the combined heating and ~~cooling~~ REFRIGERATING SYSTEM generates additional and/or more severe HAZARDS than those for the two systems if treated separately.
- The materials being treated in the intended application introduce significant heat into the REFRIGERATING SYSTEM, so that the ~~cooling~~ REFRIGERATING SYSTEM in the application yields additional and/or more severe HAZARDS than those for the ~~cooling~~ REFRIGERATING SYSTEM if operated at the maximum RATED ambient temperature alone.
- An irradiation function for the materials being treated presenting additional HAZARDS.
- A function to expose the materials being treated to excessive humidity, carbon dioxide, salt mist, or other substances which ~~may~~ can result in additional HAZARDS.
- A function of MECHANICAL MOVEMENT presenting additional HAZARDS.
- Provision for an OPERATOR to walk in to the operating area to load or unload the materials being treated.

Addition:

Add the following text after the last paragraph:

NOTE 101 Examples of such equipment include environmental testing and plant growth TEST CHAMBERS, refrigerating CIRCULATORS which incorporate heating, and recirculating coolers for extracting heat.

~~If~~ It is possible that all or part of the equipment falls within the scope of one or more other Part 2 standards of IEC 61010 as well as within the scope of this standard, ~~it should also meet~~. In that case, the requirements of those other Part 2 standards also apply. This document is intended for application when one or more of the additional HAZARDS described in the above dashed listed items are introduced. However, when the equipment incorporates only a REFRIGERATING SYSTEM or only a heating function or a combination of the two without introducing the additional HAZARDS described in the above list, then ~~the application of~~

IEC 61010-2-011 or IEC 61010-2-010 or both, as ~~applicable, shall be considered~~ appropriate, apply instead of this Part 2-012.

See further information in the flow chart (Figure 102) for selection process and guidance in the Introduction.

NOTE 102 Subclause 3.1.107 and Annex BB provide the definition and requirements for the protection of people who are inside WALK-IN EQUIPMENT.

1.1.2 Equipment excluded from scope

Addition:

Add the following items after item j):

- aa) equipment for the heating, cooling, and ventilation of laboratories;
- bb) sterilizing equipment.

1.2 Object

1.2.1 Aspects included in scope

Addition:

Add ~~two new items to the list~~ the following items after item g):

- aa) biohazards (see 13.101);
- bb) hazardous chemical substances (see 13.102).

2 Normative references

This clause of Part 1 is applicable, except as follows:

Addition:

IEC 60079-15:2010, *Explosive atmospheres – Part 15: Equipment protection by type of protection "n"*

IEC 60079-20-1, *Explosive atmospheres – Part 20-1: Material characteristics for gas and vapour classification – Test methods and data*

~~IEC 60335-2-24:2010, Household and similar electrical appliances – Safety – Part 2-24: Particular requirements for refrigerating appliances, ice-cream appliances and ice makers
IEC 60335-2-24:2010/AMD1:2012~~

IEC 60335-2-34:2012, *Household and similar electrical appliances – Safety – Part 2-34: Particular requirements for motor-compressors*

IEC 60335-2-34:2012/AMD1:2015

IEC 60335-2-34:2012/AMD2:2016

IEC 60950-1:2005, *Information technology equipment – Safety – Part 1: General requirements*

~~IEC 62471, Photobiological safety of lamps and lamp systems~~

~~IEC TR 62471-2, Photobiological safety of lamps and lamp systems – Part 2: Guidance on manufacturing requirements relating to non-laser optical radiation safety~~

ISO 7010:2011, *Graphical symbols – Safety colours and safety signs – Registered safety signs* (available at <https://www.iso.org/obp>)

3 Terms and definitions

This clause of Part 1 is applicable except as follows:

3.1 Equipment and states of equipment

Addition:

Add the following new terms and definitions:

3.1.101

BATH

complete device intended for application of CONTROLLED TEMPERATURES to SPECIMENS by immersion in a temperature-controlled liquid HEAT TRANSFER MEDIUM

3.1.102

CIRCULATOR

equipment intended for application of CONTROLLED TEMPERATURES to an APPLICATION SYSTEM by external circulating of a temperature-controlled liquid HEAT TRANSFER MEDIUM

3.1.103

TEST CHAMBER

ENCLOSURE or space in some part of which specified conditions can be achieved, in particular, temperature, humidity, irradiation, low air pressure, mould growth and salt spray

3.1.104

COMBINED TEST CHAMBER

special TEST CHAMBER combined with the function of MECHANICAL MOVEMENT, for example, for vibration, shock, impact, and similar dynamic tests

3.1.105

INCUBATOR

special TEST CHAMBER, primarily for incubation of microorganisms and tissue culture

3.1.106

SHAKER

equipment to disperse or dissolve one substance in another by MECHANICAL MOVEMENT without the use of blades or stirrers that might destroy the structure of the substance, in particular, shaking BATH and shaking INCUBATOR

3.1.107

WALK-IN EQUIPMENT

TEST CHAMBER or INCUBATOR, the door of which allows the OPERATOR to enter and remain inside the equipment even with the door closed

3.1.108

DRYING-OUT

period to wait or procedure to be carried out before operation to return the equipment to NORMAL CONDITION if it has been transported or stored in humid conditions, or moved from a cold environment to a much warmer one where condensation could occur, and could cause the equipment to then fail to meet all the safety requirements of this document

3.1.109

STANDSTILL

period to wait or procedure to be carried out before operation to return the equipment to NORMAL CONDITION if it has been transported, moved, shaken, tilted or inverted and which could cause the equipment to then fail to meet all the safety requirements of this document

3.2 Parts and accessories

Addition:

Add the following new terms and definitions:

3.2.101

RESISTANCE-HEATING DEVICE

part of resistance-heating equipment, comprising one or more heating resistors, typically composed of metallic conductors or an electrically conductive compound suitably insulated and protected

[SOURCE: IEC 60050-426:2008, 426-08-08, modified – "resistance-heating unit" has been replaced with "resistance-heating equipment".]

3.2.102

REFRIGERATING SYSTEM

combination of interconnected REFRIGERANT-containing parts constituting one closed REFRIGERANT circuit in which the REFRIGERANT is circulated for the purpose of extracting and rejecting heat

[SOURCE: ~~ISO 5149:1993, 1.3.47~~ ISO 5149-1:2014, 3.1.9, modified – the term "(heat pump)" has been deleted from the term and the words "(i.e. cooling and heating)" have been deleted from the definition and the note.]

3.2.103

CASCADE SYSTEM

REFRIGERATING SYSTEM consisting of two or more independent refrigeration circuits where the CONDENSER of one system rejects heat directly to the EVAPORATOR of another

[SOURCE: EN 378-1:2008, 3.1.12, modified – "REFRIGERATING SYSTEM consisting of" has been included.]

3.2.104

MOTOR-COMPRESSOR

refrigerating subassembly consisting of the mechanical mechanism of the compressor and the motor, both of which are enclosed in the same sealed housing, with no external shaft seals, and with the motor operating in a REFRIGERANT atmosphere with or without oil

Note 1 to entry: The housing may be permanently sealed, such as by welding or brazing (hermetic MOTOR-COMPRESSOR), or may be sealed by gasketed joints (semi-hermetic MOTOR-COMPRESSOR). A TERMINAL box, a TERMINAL boxcover, and other electrical components or an electronic control system may be included.

[SOURCE: IEC 60335-2-34:2012/~~AMD1:2015~~, 3.101, modified – "appliance" has been replaced by "refrigerating subassembly".]

3.2.105

CONDENSER

heat exchanger in which vaporized REFRIGERANT is liquified by removal of heat

[SOURCE: ~~ISO 5149:1993, 1.3.11~~ ISO 5149-1:2014, 3.4.4, modified – "refrigerant vapour" has been replaced by "vaporized REFRIGERANT".]

3.2.106

CONDENSING UNIT

specific refrigerating subassembly combination for a given REFRIGERANT, consisting of one or more MOTOR-COMPRESSORS, CONDENSERS, liquid receivers (when required) and the regularly furnished accessories

[SOURCE: ~~ISO 5149:1993, 1.3.12, modified – “machine” has been replaced by “subassembly”~~]

3.2.107

EVAPORATOR

heat exchanger in which liquid REFRIGERANT is vaporized by absorption of heat

[SOURCE: IEC 60335-2-40:2009 2018, 3.110, modified – “refrigerant liquid” has been replaced by “liquid refrigerant”.]

3.2.108

HIGH-PRESSURE SIDE

part of a REFRIGERATING SYSTEM operating approximately at the CONDENSER pressure

[SOURCE: ~~ISO 5149:1993, 1.3.24~~ ISO 5149-1:2014, 3.1.7]

3.2.109

LOW-PRESSURE SIDE

part of a REFRIGERATING SYSTEM operating approximately at the EVAPORATOR pressure

[SOURCE: ~~ISO 5149:1993, 1.3.30~~ ISO 5149-1:2014, 3.1.8]

3.2.110

CIRCULATING PUMP

pressure and/or suction pump transporting the liquid HEAT TRANSFER MEDIUM in a BATH or CIRCULATOR

3.2.111

CIRCULATING FAN

propeller fan or centrifugal impeller designed to circulate the air in a TEST CHAMBER or an INCUBATOR with or without any air duct

3.2.112

HUMIDIFIER

electric device that generates a water mist or steam and releases it into a room, greenhouse or other ENCLOSURE

3.2.113

BATH TANK

open or enclosed vessel containing the HEAT TRANSFER MEDIUM, in a BATH or CIRCULATOR

3.2.114

LIQUID CONNECTION

pipe fitting through which liquid is expelled from or discharged into a vessel or a heat exchanger

3.2.115

VENTILATOR

device for replacing air inside a TEST CHAMBER or an INCUBATOR ~~by~~ with outside air

3.2.116

TEMPERATURE-LIMITING DEVICE

temperature-actuated device that is designed to prevent unsafe temperatures

[SOURCE: EN 378-1:2008, 3.6.5]

3.2.117

LIQUID LEVEL CUT OUT

liquid level-actuated device designed to prevent unsafe liquid levels

[SOURCE: EN 378-1:2008, 3.6.12]

3.2.118

PRESSURE-LIMITING DEVICE

pressure-actuated device (for example, a high-pressure switch) which is designed to stop the operation of the pressure-imposing element and may also operate an alarm

3.2.119

PRESSURE-RELIEF DEVICE

valve or disc designed to relieve excessive pressure automatically

[SOURCE: ~~ISO 5149:1993, 1.3.40~~ ISO 5149-1:2014, 3.6.7, modified – "pressure relief valve or bursting disc device" has been replaced with "valve or disc" in the definition.]

3.2.120

FLAMMABLE LIQUID

liquid capable of producing a flammable gas or vapour which, when mixed with air in certain proportions, will form an EXPLOSIVE GAS ATMOSPHERE under any foreseeable operating conditions

3.2.121

HEAT TRANSFER MEDIUM

medium used to transfer heat to the material being processed

3.2.122

REFRIGERANT

fluid used for heat transfer in a REFRIGERATING SYSTEM, which absorbs heat at a low temperature and a low pressure of the fluid and rejects heat at a higher temperature and a higher pressure of the fluid, usually involving changes of state of the fluid

[SOURCE: ~~ISO 5149:1993, 1.3.45~~ ISO 817:2014, 3.1.35, modified – the term "phase" has been replaced with "state" in the definition.]

3.2.123

FLAMMABLE REFRIGERANT

REFRIGERANT with a flammability classification of ~~group 2 or 3~~ A2L, A2 or A3 in accordance with ~~ISO 5149~~ ISO 817

[SOURCE: IEC 60335-2-24:2010 and IEC 60335-2-24:2010/~~AMD1:2012~~AMD2:2017, 3.109]

3.2.124

SPECIMEN

any material, substance, or product designated to be processed, for example, in a BATH, TEST CHAMBER or an INCUBATOR

3.2.125

APPLICATION SYSTEM

system or device intended to work with a CIRCULATOR to carry out a functional purpose

3.5 Safety terms

Addition:

Add the following new terms and definitions:

3.5.101

SATURATED-VAPOUR PRESSURE

<of REFRIGERANT> vapour pressure at which the liquid and vapour can exist in equilibrium at a given temperature

3.5.102

MAXIMUM ALLOWABLE PRESSURE

PS

maximum pressure for which the equipment is designed, as specified by the manufacturer

Note 1 to entry: This note applies to the French language only.

[SOURCE: EN 378-1:2008, 3.3.2]

3.5.103

RATED PRESSURE

MAXIMUM ALLOWABLE PRESSURE for pressure components of equipment with regard to their ability to withstand pressures as specified by the manufacturer

3.5.104

ACTIVE COOLING CONTROL RANGE

ACC RANGE

~~working~~ CONTROLLED TEMPERATURE range that is achieved by an active REFRIGERATING SYSTEM

Note 1 to entry: This note applies to the French language only.

3.5.105

FLASH POINT

lowest liquid temperature at which, under certain standardized conditions, a liquid gives off vapours in quantity such as to be capable of forming an ignitable vapour/air mixture

Note 1 to entry: At the FLASH POINT, the vapour may cease to burn when the ignition source is removed.

[SOURCE: IEC 60050-426:2008, 426-02-14]

3.5.106

FIRE POINT

lowest temperature at which a substance ignites and continues to burn for at least 5 s after a small flame has been applied to its surface under standardized conditions

3.5.107

AUTO IGNITION TEMPERATURE

lowest temperature at which a substance will spontaneously ignite in a normal atmosphere without an external ignition source, such as a flame or spark

Note 1 to entry: Once ignited, the substance will continue to burn until it is either completely consumed or the temperature of the remainder of the substance is reduced to or below its FIRE POINT.

3.5.108

LOWER EXPLOSIVE LIMIT

LEL

concentration of flammable gas or vapour in air, below which an EXPLOSIVE GAS ATMOSPHERE will not be formed

Note 1 to entry: This note applies to the French language only.

[SOURCE: IEC 60050-426:2008, 426-02-09]

3.5.109

EXPLOSIVE GAS ATMOSPHERE

mixture with air, under atmospheric conditions, of flammable substances in the form of gas or vapour which, after ignition, permits self sustaining flame propagation

[SOURCE: IEC 60050-426:2008, 426-01-07]

3.5.110

SOAKED TEMPERATURE CONDITION

temperature conditions when the ambient temperature of the equipment under test (EUT) equals to $\pm 2,0$ °C of maximum ambient of 1.4.1 for NORMAL USE, storage or transport, and the ~~operating~~ CONTROLLED TEMPERATURE of the EUT equals to $\pm 2,0$ °C of the maximum ACC RANGE with the MOTOR-COMPRESSOR running or, the maximum RATED ~~operating~~ CONTROLLED TEMPERATURE with the MOTOR-COMPRESSOR off

Note 1 to entry: This note applies to the French language only.

3.5.111

MECHANICAL MOVEMENT

~~general description for the~~ motion of materials being processed, for example in a SHAKER or COMBINED TEST CHAMBER

3.5.112

MOVEMENT FREQUENCY

number of complete cycles of MECHANICAL MOVEMENT

3.5.113

MOVEMENT AMPLITUDE

maximum radius, distance, or angle of the MECHANICAL MOVEMENT

3.5.114

CONTROLLED TEMPERATURE

temperature where the EVAPORATOR is located and to which the LOW-PRESSURE SIDE of the equipment is exposed, as a result of heat transfer either by active heating or from the APPLICATION SYSTEM or SPECIMEN

Note 1 to entry: For a heat pump system, where a four-way valve is used to shift between heat and cool, the function of CONDENSER and EVAPORATOR is exchanged.

4 Tests

This clause of Part 1 is applicable except as follows:

4.3 Reference test conditions

4.3.1 Environmental conditions

Addition:

Add the following text after item d):

Since the ~~operating~~ temperatures, pressures and current draw for a REFRIGERATING SYSTEM are significantly impacted by ambient temperatures in a non-linear way, linear extrapolation of test data is not possible. Therefore, tests to establish the temperatures, pressures, and current draw for a REFRIGERATING SYSTEM shall be conducted under the following environmental conditions:

- ~~aa~~1) an ambient temperature of 40 °C, or the maximum RATED ~~operating~~ ambient temperature, if higher;
- ~~bb~~2) the temperature of water supply is the maximum as specified by the manufacturer (see 5.4.3);
- ~~cc~~3) a relative humidity not exceeding the limits of 1.4.1 d), or the maximum RATED ~~operating~~ relative humidity at the maximum RATED ~~operating~~ ambient temperature, if higher.

If, as permitted by Note 2 of 1.4.1, a REFRIGERATING SYSTEM has an ~~operating~~ ambient temperature RATING below 40 °C, the NORMAL CONDITION tests shall be performed in an environment that matches the maximum RATED ~~operating~~ ambient temperature, and then repeated at an ~~environmental~~ ambient temperature of 40 °C. See ~~4.3.2.106~~ 4.3.2.114.

4.3.2 State of equipment

4.3.2.1 General

Replacement:

Replace the first paragraph and note by the following:

Unless otherwise specified, each test shall be carried out on the equipment assembled for NORMAL USE, and under the least favourable combination of the conditions given in 4.3.2.2 to 4.3.2.13 and 4.3.2.101 to ~~4.3.2.113~~ 4.3.2.114 if applicable.

When measuring temperatures, pressures, and current draws of equipment incorporating a REFRIGERATING SYSTEM, the tests shall be started from a SOAKED TEMPERATURE CONDITION when all pressures have fully equalized. Tests at the extremes of the input voltage ($\pm 10\%$) shall start under these voltage conditions and achieve a stable state but need not start from a SOAKED TEMPERATURE CONDITION.

In case of doubt, a test may have to be made with more than one combination of conditions, for example, when the equipment is operated at or cycled in between its maximum and minimum ~~operating~~ CONTROLLED TEMPERATURES or operated in combination with excessive humidity, low air pressure, radiation, or conditions of precipitation.

Addition:

Add the following new subclauses:

4.3.2.101 Heat load

Where the equipment or materials being processed require either the provision or extraction of heat, the equipment under test (EUT) shall be loaded with a heat source/sink within the manufacturer's specified conditions of use (including maximum RATED and none).

NOTE DIN 12876 (all parts) provides procedures for determining cooling capacity and efficient heating capacity of the equipment.

4.3.2.102 Humidity and steam

Where equipment generates humidity or is intended for connection to a steam supply, it shall be set to generate or be supplied with them within the manufacturer's specified conditions of use (including maximum RATED and none).

4.3.2.103 Lamp and lamp systems

Illumination that provides part of the primary function (whether it be integral or an accessory), shall be installed and operated within the manufacturer's specified conditions of use (including maximum, off and cycled).

NOTE An example is a Xenon arc lamp used in a weather durability TEST CHAMBER.

4.3.2.104 MECHANICAL MOVEMENT

Equipment with a function of MECHANICAL MOVEMENT (for materials or HEAT TRANSFER MEDIUM) shall be set to expose the equipment and any materials being processed to the worst conditions (including maximum, off and cycled).

4.3.2.105 Spray generating systems

Spray generating systems of equipment shall be operated within the manufacturer's specified conditions of use (including maximum, off and cycled).

4.3.2.106 VENTILATORS

VENTILATORS shall be operated within the manufacturer's specified conditions of use (including maximum, off and cycled).

4.3.2.107 Pressures other than those of REFRIGERANT

Where equipment generates or uses pressures other than local atmospheric it shall be set to generate, or be supplied with pressure(s) within the manufacturer's specified conditions of use (including maximum RATED and none).

4.3.2.108 REFRIGERANT pressure

Where a heating system (or HEAT TRANSFER MEDIUM) can apply a CONTROLLED TEMPERATURE to the REFRIGERATING SYSTEM which is outside its ACC RANGE, the equipment shall be set to apply the maximum CONTROLLED TEMPERATURE allowed by the controls or interlocks with the MOTOR-COMPRESSOR off or maximum ACC RANGE with the MOTOR-COMPRESSOR on, whichever is least favourable.

Where a heating system (or HEAT TRANSFER MEDIUM) can apply a CONTROLLED TEMPERATURE to the REFRIGERATING SYSTEM which could affect the pressure in the system, the most unfavourable condition for pressure shall be established including:

- MOTOR-COMPRESSOR running throughout;
- MOTOR-COMPRESSOR started during test;
- outside its ACC RANGE with the MOTOR-COMPRESSOR off and the equipment set to apply the maximum CONTROLLED TEMPERATURE allowed by the controls or interlocks.

4.3.2.109 Exhaust and condensate

The least favourable conditions which result in production of exhaust, vapours and/or condensates shall be created (including maximum and cycled).

NOTE The TERMINALS of a RESISTANT-HEATING DEVICE exposed to ambient condition are easily condensed after the HEAT TRANSFER MEDIUM has been cooled to below ambient-condition temperature for some time.

4.3.2.110 Filling and draining systems

Filling and draining systems shall be operated within the manufacturer's specified conditions of use (including maximum, minimum and intermediate).

4.3.2.111 Circulating system

CIRCULATING PUMP(s), agitator(s) or CIRCULATING FAN(s) shall be operated within the manufacturer's specified conditions of use (including maximum and off).

4.3.2.112 Gas HEAT TRANSFER MEDIUM

The equipment shall be operated with the gas HEAT TRANSFER MEDIUM, whether it is air or other designated gases, at the percentage of content and pressure within the manufacturer's specified conditions of use (including maximum, minimum and none).

4.3.2.113 Properties of liquid HEAT TRANSFER MEDIUM

For equipment with a wide ~~operating~~ CONTROLLED TEMPERATURE range, the effect of contraction, expansion, evaporating, condensing, oxidizing, boiling and freezing of the liquid and its allowable ~~operating~~ CONTROLLED TEMPERATURE range should be considered. HEAT TRANSFER MEDIA which change states during NORMAL USE shall be simulated to generate state change both from solid to liquid and vice versa.

4.3.2.114 Abnormal test to simulate the failure of the controlled environment

For REFRIGERATING SYSTEMS intended to operate in an ambient environment that is more restricted than that specified in 1.4.1, this additional abnormal test shall be applied to simulate the failure of the controlled environment in which the equipment is located.

Having determined the least favourable test conditions for the temperature and pressure tests under 10.4.1, the equipment is operated under these conditions until a steady state has been achieved. The test environment conditions are then increased to the levels set out in 1.4.1 (40 °C, 50 % RH) and the equipment is allowed to stabilize before the maximum temperatures and pressures are recorded. Protective devices shall not be bypassed or disabled. If the equipment does not reach steady state due to the operation of protective devices, then the maximum values recorded for this test shall be either:

- a) the maximum temperatures and pressures at the point of operation of non-resettable or manually resettable devices, which do not need to be reset during this test; or
- b) the maximum temperatures and pressures achieved after continued cycling of automatically resetting protective devices, which shall be allowed to cycle until it is clear that successive cycles will not develop higher maximum values.

4.4.2 Application of fault conditions

4.4.2.10 Cooling

Addition:

Add the following items and notes after item d):

- aa) for an air-cooled CONDENSING UNIT, each CONDENSER fan shall be stalled one at a time unless a single fault could disable all CONDENSER fans simultaneously, ~~and also~~ or with the CONDENSER airflow restricted, ~~whichever is the worst case~~, until maximum stabilized pressure is attained or until representative maximum temperatures are attained under cycling load. The temperatures and pressures shall be monitored at short intervals throughout the test to ensure that peak values are captured. This test is conducted at ~~a room~~ an ambient temperature of 25 °C ± 3 °C.

- bb) for a water-cooled CONDENSING UNIT, the REFRIGERATING SYSTEM shall be operated with the condensing water shut off, ~~and also~~ or with the condensing water restricted, **whichever is the worst case**, until maximum stabilized pressure is attained or until representative maximum temperatures are attained under cycling load. The temperatures and pressures shall be monitored at short intervals throughout the test to ensure that peak values are captured. This test is conducted at ~~a room~~ **an** ambient temperature, and a water temperature of $25\text{ °C} \pm 3\text{ °C}$.

If a manual reset PRESSURE-LIMITING DEVICE is relied upon to limit the maximum and/or minimum pressure for the HIGH-PRESSURE SIDE or LOW-PRESSURE SIDE, then it shall be reset manually within 6 s of operation for 10 cycles.

NOTE 101 The running state of the MOTOR-COMPRESSOR is not relevant after the manual high PRESSURE-LIMITING DEVICE has operated.

If an automatic reset PRESSURE-LIMITING DEVICE is relied upon to limit the maximum and/or minimum pressure for the HIGH-PRESSURE SIDE or LOW-PRESSURE SIDE, then it shall be permitted to cycle automatically until it can be demonstrated that peak temperatures and pressures have been achieved.

NOTE 102 It is possible that a MOTOR-COMPRESSOR designed to be cooled by cycling of the REFRIGERANT would overheat enough to cause HAZARDS, if leakage of REFRIGERANT occurs and the PRESSURE-LIMITING DEVICE for LOW-PRESSURE SIDE is triggered repeatedly.

NOTE 103 The correct specification or appropriate setting of the pressure differential (hysteresis) of an automatic reset PRESSURE-LIMITING DEVICE is important for MOTOR-COMPRESSORS which require a longer STANDSTILL (off cycle) period.

If it can be demonstrated that a PRESSURE-LIMITING DEVICE will operate during the tests of **MAXIMUM ALLOWABLE PRESSURE (PS)**, the manufacturer may elect to waive the test, but shall set the PS for the HIGH-PRESSURE SIDE of the MOTOR-COMPRESSOR to the RATING of the PRESSURE-LIMITING DEVICE.

For equipment with both air-cooled and water-cooled CONDENSERS, faults are applied one at a time only, unless the equipment is designed so that the OPERATOR can select to run either an air-cooled or a water-cooled CONDENSER (for example, some equipment is equipped with a water-cooled CONDENSER as an auxiliary for the air-cooled CONDENSER).

For a CASCADE SYSTEM, where an EVAPORATOR from the first stage REFRIGERATING SYSTEM acts as a CONDENSER to the second stage REFRIGERATING SYSTEM, the manufacturer may elect to run each CONDENSING UNIT individually under the tests of 4.4.2.10. In this case, disabling the first REFRIGERATING SYSTEM is considered to simulate the second stage CONDENSING UNIT running under the conditions of aa) and bb) above.

4.4.2.11 Heating devices

Addition:

Add the following ~~second~~ paragraph after item b):

If a HAZARD could be caused by over-filling or under-filling with a liquid HEAT TRANSFER MEDIUM, the equipment shall be tested when empty, partially filled, or overfilled, whichever is least favourable. In case of doubt, the test shall be carried out in more than one condition. The HEAT TRANSFER MEDIUM used for the test shall be of a type specified for NORMAL USE.

Addition:

Add the following new subclauses:

4.4.2.101 MOTOR-COMPRESSOR

Housing and winding temperatures of MOTOR-COMPRESSORS that do not conform with IEC 60335-2-34 (including IEC 60335-2-34:2012, IEC 60335-2-34:2012/AMD1:2015 and IEC 60335-2-34:2012/AMD2:2016, Annex AA), shall be measured under the conditions of 19.101, 19.102 and 19.103 of IEC 60335-2-34:2012/AMD1:2015.

Housing and winding temperatures of MOTOR-COMPRESSORS conforming with IEC 60335-2-34 (including IEC 60335-2-34:2012, IEC 60335-2-34:2012/AMD1:2015 and IEC 60335-2-34:2012/AMD2:2016, Annex AA), are not measured.

4.4.2.102 Fluid leakage in the equipment

Internal leaks of fluids shall be simulated.

4.4.2.103 Solenoid valve and motorized valve

Equipment where the failure of a solenoid or motorized valve could cause a HAZARD shall be tested with the valve held in the worst likely failed state (including fully open, fully closed, anywhere in-between and changing state at the wrong time).

4.4.2.104 Failure of temperature control

The BATH TANK or other liquid vessel of the equipment shall be filled to its maximum level with the HEAT TRANSFER MEDIUM for NORMAL USE as specified by the manufacturer. The following faults shall then be applied, fault a) is applied on its own but if the conditions for c) are true then c) is applied immediately after b).

- a) Uncontrolled heating – For equipment where there is an opening over the BATH TANK and where the boiling of the HEAT TRANSFER MEDIUM could cause a HAZARD, the temperature controllers shall be overridden so that the HEAT TRANSFER MEDIUM is kept boiling until any TEMPERATURE-LIMITING DEVICE for overtemperature protection is triggered, or boiling is terminated by the loss of the liquid.
- b) Uncontrolled cooling – Temperature controllers shall be overridden to produce uncontrolled cooling until the HEAT TRANSFER MEDIUM becomes coagulated, solidified or frozen, or until there is no evidence of further increases in the kinematic viscosity of the HEAT TRANSFER MEDIUM, or operation of the MOTOR-COMPRESSOR is automatically terminated by a protective device.
- c) Return to control – This test shall be applied to equipment incorporating an immersed or flow-through REFRIGERATING SYSTEM EVAPORATOR and/or a CIRCULATING PUMP and where the HEAT TRANSFER MEDIUM has become frozen, solidified or coagulated and the MOTOR-COMPRESSOR is still operational or could be made operational by resetting its protective device without the use of a TOOL. Under these conditions the MOTOR-COMPRESSOR's protective device shall be reset (if required) and the temperature control shall be re-activated with the CONTROLLED TEMPERATURE set to a value where the HEAT TRANSFER MEDIUM would be a liquid at its normal viscosity. The test terminates when all of the HEAT TRANSFER MEDIUM is at the specified CONTROLLED TEMPERATURE and normal viscosity.

4.4.2.105 HUMIDIFIER

HUMIDIFIERS that are not RATED to operate continuously shall be forced to operate continuously.

The container of an electrode-type HUMIDIFIER shall be filled with a saturated solution of sodium chloride in water, at a temperature of $20\text{ }^{\circ}\text{C} \pm 5\text{ }^{\circ}\text{C}$. The HUMIDIFIER shall be supplied at its RATED voltage.

NOTE The solution is saturated when no more salt can be dissolved in the water at a particular temperature.

If flexible tubing or hose is used for the steam or mist outlet, the test shall be performed with the tubing or hose unobstructed, partially blocked, and fully blocked.

If the equipment depends on a differential pressure between the inlet and outlet of the HUMIDIFIER to drive the steam or mist into the equipment, the HUMIDIFIER shall be operated with the equipment running at or cycling between its maximum and minimum ~~working~~ CONTROLLED TEMPERATURES, whichever is least favourable.

In case of doubt, tests shall be carried out with more than one combination of conditions.

~~4.4.2.106~~ ~~Extreme operating ambient abnormal~~

~~For REFRIGERATING SYSTEMS intended to operate in an ambient environment that is more restricted than specified in 1.4.1, this additional abnormal test shall be applied to simulate the failure of the controlled environment in which the equipment is located.~~

~~Having determined the least favourable test condition for the temperature and pressure tests under 10.4.1 the equipment is operated under these conditions until a steady state has been achieved. The test environment is then increased to the levels of 1.4.1 (40 °C, 50 % RH) and the equipment is allowed to stabilize before the maximum temperatures and pressures are recorded. Protective devices shall not be bypassed or disabled. If the equipment does not reach steady state due to the operation of protective devices, then the maximum values recorded for this test shall be either:~~

- ~~a) the maximum temperatures and pressures at the point of operation of non-resettable or manually resettable devices, which do not need to be reset during this test; or~~
- ~~b) the maximum temperatures and pressures achieved after continued cycling of automatically resetting protective devices, which shall be allowed to cycle until it is clear that successive cycles will not develop higher maximum values.~~

4.4.2.106 Speed controller

If a HAZARD could arise in case of a single fault of a speed controller, then such faults shall be applied, one at a time.

NOTE As examples, speed controllers are sometimes used to control MOVEMENT FREQUENCY in a SHAKER or COMBINED TEST CHAMBER, and to control pressure and flow rate of a CIRCULATING PUMP. Under a SINGLE FAULT CONDITION of the speed controller, a HAZARD might arise if the pressure developed by the pump exceeds the MAXIMUM ALLOWABLE PRESSURE of an APPLICATION SYSTEM, or if excessive MOVEMENT FREQUENCY of a SHAKER or COMBINED TEST CHAMBER results in loosening, tumbling, ejection, or destruction of the SPECIMEN.

4.4.3 Duration of tests

4.4.3.1 General

Replacement:

Replace the text with the following:

The equipment shall be operated until further change as a result of the applied fault is unlikely. Each test is normally limited to 1 h since a secondary fault arising from a SINGLE FAULT CONDITION will usually manifest itself within that time. If there is an indication that a HAZARD of electric shock, spread of fire or injury to persons ~~may~~ can eventually occur, the test shall be continued until it is clear that stable conditions have been maintained for at least 1 h, unless one of these HAZARDS arises before then.

4.4.4 Conformity after application of fault conditions

4.4.4.1 General

Addition:

Add the following text below item c):

Conformity with the requirements for temperature protection of MOTOR-COMPRESSORS is checked as specified in 4.4.2.101.

5 Marking and documentation

This clause of Part 1 is applicable except as follows:

5.1 Marking

5.1.3 MAINS supply

Addition:

Add the following new symbols to Table 1:

Table 1 – Symbols

Number	Symbol	Reference	Description
101		ISO 7010-W010 (2011-0605)	Warning; low temperature/freezing conditions, frostbite HAZARD
102		ISO 7010-W021 (2011-0605)	Warning; flammable material/FLAMMABLE LIQUID
103		ISO 7010-W009 (2011-0605)	Warning; biological HAZARD
104		ISO 7010-W027 (2011-0605)	Warning; optical radiation
105		ISO 7010-W011 (2011-0605)	Warning; slippery surface
106		ISO 7010-W024 (2011-0605)	Warning; crushing of hands

5.1.5 TERMINALS, connections and operating devices

Addition:

Add the following new subclauses:

5.1.5.101 LIQUID CONNECTIONS for HEAT TRANSFER MEDIUM

LIQUID CONNECTIONS for HEAT TRANSFER MEDIUM shall be marked with graphical symbols or text to identify the outlet and inlet of the HEAT TRANSFER MEDIUM.

NOTE For refrigerating CIRCULATORS, symbols 107 through 109 can be used and, for refrigerating and heating CIRCULATORS, symbols 110 through 112 can be used (see Table AA.1).

Additionally, consideration may be given to mark the following:

- A) if the outlet pressure of the liquid is greater than 0,03 MPa or 0,02 MPa with a maximum flow rate of more than 10 l/min, the maximum pressure in Pa, in association with symbol 108 or 111;
- B) for a CIRCULATOR with a liquid suction pressure ~~lower~~ greater than 0,02 MPa, the maximum pressure in Pa preceded by a minus sign, in association with symbol 109 or 112;
- C) for an enclosed CIRCULATOR intended for connection to a sealed APPLICATION SYSTEM, and if the LIQUID CONNECTIONS ~~will~~ need to withstand pressure exceeding 0,03 MPa, the maximum pressure for each LIQUID CONNECTION, in association with symbols 108 and 109, or 111 and 112.

Symbols 107 to 112 are found in Table AA.1.

Where there is insufficient space near the LIQUID CONNECTIONS, symbol 14 of Table 1 may be used and explanations shall be ~~detailed~~ given in the instructions provided with the equipment.

Conformity is checked by inspection.

5.1.5.102 LIQUID CONNECTION for filling of BATH TANKS with enclosed CIRCULATORS

Where the mis-setting of controls or valves associated with the LIQUID CONNECTION for filling a BATH TANK with an enclosed CIRCULATOR could cause a HAZARD, symbol 14 shall be placed close to the LIQUID CONNECTION and the instructions for use (see 5.4.4) shall clearly explain the necessary settings to ensure safety under different operating conditions.

Conformity is checked by inspection.

5.1.5.103 Other LIQUID CONNECTIONS and exhaust opening

LIQUID CONNECTIONS for filling, water supply, draining, overflowing and exhaust opening shall be marked as follows:

- a) for equipment intended for manual filling of liquid, if the area of the opening for the BATH TANK or other liquid vessel is smaller than 80 cm² or it is not self-evident, a text marking or symbol 116 to indicate the location of the opening for filling;
- b) for equipment intended for direct connection to the water supply, a text marking or symbol 113 for each LIQUID CONNECTION for water source, and optionally including, as applicable, auxiliary text to indicate the RATED pressure, flow rate, and maximum temperature of the water supply;
- c) for equipment incorporating a water-cooled CONDENSING UNIT, or LIQUID CONNECTIONS for circulating water, a text marking or symbol 113 to identify the inlet, and a text marking or symbol 114 to identify the outlet, one or both of which also indicate the direction of liquid flow, and including as applicable, auxiliary text to indicate the RATED pressure, flow rate, and maximum temperature of the water supply;
- d) for LIQUID CONNECTION for condensate, a text marking or symbol 115;
- e) for LIQUID CONNECTION for draining, a text marking or symbol 117;
- f) for LIQUID CONNECTION for overflowing, a text marking or symbol 118;
- g) markings in association with a VENTILATOR include:
 - 1) symbol 119 for the adjustment handle or shaft of the VENTILATOR,
 - 2) symbol 120 for the fresh air inlet accompanied by, where necessary, the following text or its equivalent, "Fresh air inlet. Do not block.";
 - 3) symbol 121 for the exhaust opening.

NOTE Symbols 113 to 121 can be found in Table AA.1.

Where there is insufficient space near the LIQUID CONNECTIONS and/or exhaust openings, symbol 14 of Table 1 may be used and additional explanation shall be included in the instructions.

Conformity is checked by inspection.

5.1.5.104 Equipotential TERMINALS

Each equipotential TERMINAL shall be marked with the symbol for equipotentiality of IEC 60417-5021 (2002-10). The marking shall not be marked on a screw, bolt, removable washer, or any other part that is removable when a connection is being made to conductors or wires.

Conformity is checked by inspection.

Addition:

Add the following new subclauses at the end of 5.1:

5.1.101 Marking for equipment incorporating a REFRIGERANT CONDENSING UNIT

For equipment incorporating a REFRIGERANT CONDENSING UNIT, the following information shall be marked:

- A) the total mass of REFRIGERANT for each separate REFRIGERANT circuit;
- B) for a single component REFRIGERANT, at least one of the following:
 - 1) the chemical name,
 - 2) the chemical formula,
 - 3) the REFRIGERANT number;
- C) for a blended REFRIGERANT, at least one of the following:
 - 1) the chemical name and nominal proportion of each of its components,
 - 2) the chemical formula and nominal proportion of each of its components,
 - 3) the REFRIGERANT number and nominal proportion of each of its components,
 - 4) the REFRIGERANT number of the REFRIGERANT blend;

NOTE 1 REFRIGERANT numbers are quoted in accordance with ISO 817 or other REFRIGERANT classification standard, for example ANSI/ASHRAE 34.

- D) MAXIMUM ALLOWABLE PRESSURE (PS) under NORMAL CONDITION, HIGH-PRESSURE SIDE and LOW-PRESSURE SIDE for each REFRIGERANT stage.

NOTE 2 The collation of the test results that define PS is detailed in 11.7.1.

Conformity is checked by inspection.

5.1.102 Marking for equipment incorporating MECHANICAL MOVEMENT

For SHAKERS and COMBINED TEST CHAMBERS incorporating a function of MECHANICAL MOVEMENT, the maximum safe load of the SPECIMEN holder shall be marked.

Conformity is checked by inspection.

5.2 Warning markings

~~Replacement:~~

~~Replace the first paragraph with the following:~~

~~Warning markings specified in this standard shall meet the following requirements.~~

Addition:

Add the following text after item b):

Warning markings for particular HAZARDS which exist only when performing equipment maintenance shall be marked so that they are visible only when the particular maintenance is being performed. For example, the marking of the type of FLAMMABLE REFRIGERANT and of the flammable insulation blowing gas, shall be visible when gaining access to the MOTOR-COMPRESSORS, and, in the case of equipment with a remote REFRIGERANT CONDENSING UNIT, the pipe connections. The symbol 102 of Table 1 shall be at least 15 mm in height.

5.4.1 General

Replacement:

Replace item d) by the following:

- d) the information specified in 5.4.2 to 5.4.6, 5.4.101 and 5.4.102;

5.4.2 Equipment RATINGS

Replacement:

Replace the first paragraph by the following text:

Where applicable the documentation shall include the following:

Addition:

Add the following items after f):

- aa) the maximum and minimum ~~operating~~ CONTROLLED TEMPERATURES;
- bb) the ACC RANGE and RATED cooling capacity for REFRIGERATING SYSTEM;
- cc) RATED PRESSURE and flow rate for LIQUID CONNECTIONS between CIRCULATOR and an APPLICATION SYSTEM;
- dd) the maximum additive relative humidity;
- ee) the minimum air pressure;
- ff) the maximum radiation strength;
- gg) RATED PRESSURE, flow rate for connections to liquid and air supplies;
- hh) maximum ~~MECHANICAL~~ MOVEMENT FREQUENCY, ~~MECHANICAL~~ MOVEMENT AMPLITUDE versus the mass of the load.

5.4.3 Equipment installation

Replacement:

Replace items a) to g) with the following:

- a) assembly, location and mounting requirements. Space requirements, in particular the minimum distance to all the ventilating holes or grid, LIQUID CONNECTIONS and/or exhaust opening. Additional requirements for the rigidity and non-~~slippery~~ slip characteristics of the floor and/or laboratory bench. If a HAZARD could be caused by hot items falling from the

equipment, for example when a door is opened, there shall be a warning that the equipment shall not be mounted on a surface of flammable material. Assembling the equipment away from overhead fire sensors, where opening of the door or lid or, exhausting of the fume is possible for NORMAL USE;

- b) for equipment incorporating lockable swivel casters and/or levellers, the requirements to lock the casters and adjust the levellers;
- c) ventilation requirements: if the operating of the equipment could lead to liberation of hazardous air or gas mixture, installation instructions shall warn of the need for an extraction system, **and of** additional TEMPERATURE-LIMITING DEVICES relating to safe temperatures for the materials, etc.;
- d) requirements for liquid filling, draining or overflowing (see 10.1 b));
- e) connection to the power source:
 - 1) instructions for protective grounding;
 - 2) for equipment intended for WET LOCATIONS (see 1.4.2) and in which HAZARDOUS LIVE parts may need to be ACCESSIBLE (see 6.1.2), warning symbol and statement that power socket with appropriate IP protection is used and whether external residual current circuit breaker (RCD) with RATED breaking capacity is necessary;
 - 3) warning symbol and statement which are necessary when permanent connection to the supply source is essential;
 - 4) for PERMANENTLY CONNECTED EQUIPMENT:
 - supply wiring requirements;
 - requirements for any external switch or circuit-breaker (see 6.11.3.1) and external overcurrent protection devices (see 9.6.2), and a recommendation that the switch or circuit-breaker be near the equipment;
- f) requirements for special **external** services, for example, air **and** cooling liquid. Characteristics necessary for safety shall be specified, for example, maximum and minimum temperature, pressure ~~for~~, or flow of air **or** cooling ~~water~~ **liquid**;
- g) requirements for installation of and/or connection to vacuum pump, air compressor and/or steam source;
- h) instructions relating to sound pressure level (see 12.5.1); the maximum sound power level produced by equipment which emits sound, if measurement is required by 12.5.1;
- i) requirements for DRYING-OUT and/or STANDSTILL (see 5.4.3.101);
- j) requirements for connecting a remote CONDENSING UNIT to the equipment, in particular, requirements for location, space, pipes, tubes, accessories (see 14.101), detailed specifications for REFRIGERANT (see 5.1.101), ventilation, water ~~mains~~ **supply**, and detailed procedures for connection and adjustment;
- k) requirements for connecting a CIRCULATOR to the APPLICATION SYSTEM, in particular requirements for location, space, tubes, accessories (see 14.102), insulation, liquid HEAT TRANSFER MEDIUM, ventilation, water ~~mains~~ **supply**, and detailed procedures for connection and adjustment;
- l) requirements for installing any functional lamp source, in particular recommended lamps and accessories, measures for protection against rupture of the lamp and its disposal, precautions for protection against HAZARDS of possible electric shock, hot surface, excessive optical and/or UV radiations, requirements for ventilation and water source, and detailed procedures for installation and adjustment;
- m) requirements for connecting HUMIDIFIER or steam source to the equipment, in particular recommended type and specifications of the HUMIDIFIER, equivalent evaporation of the steam source, requirements for tubes, accessories, insulation, ventilation, water ~~mains~~ **supply**, and precautions for protection against HAZARDS of possible electric shock, hot surface, mechanical injury in association with the installation, and detailed procedures for installation and adjustment;
- n) requirements for installation and adjustment for the MECHANICAL MOVEMENT.

Conformity is checked by inspection.

Addition:

Add the following new subclause:

5.4.3.101 DRYING-OUT and STANDSTILL

The instructions shall include a warning that the equipment cannot be assumed to meet all the safety requirements of this document during the DRYING-OUT and/or STANDSTILL.

Conformity is checked by inspection.

5.4.4 Equipment operation

Addition:

Add the following items after item j):

- aa) requirements for the liquid HEAT TRANSFER MEDIUM and warning against HAZARDS related to improper use of the liquid;
 - specifications of the liquid applicable to the equipment, in particular the CONTROLLED TEMPERATURE range, flammability, viscosity, FLASH POINT, FIRE POINT, AUTO IGNITION TEMPERATURE, specific gravity and specific heat capacity and their effect on applications (see 4.3.2.113);
 - procedures and precautions for filling, draining and replacing (see 10.1 b));
 - chemical HAZARD and instructions for disposal and emergency treatment;
 - special requirements for HEAT TRANSFER MEDIA which change states during NORMAL USE, in particular the HEAT TRANSFER MEDIA in a salt BATH;
- bb) instructions for how to calculate the cooling capacity and/or effective heating capacity for SPECIMENS and the APPLICATION SYSTEM;

NOTE 101 Cooling capacity is a measurement of the heat flow that a REFRIGERATING SYSTEM withdraws from the HEAT TRANSFER MEDIUM, as determined according to standard testing procedures, for example, DIN 12876-2.

NOTE 102 Effective heating capacity is a measurement of the heat flow that heating sources radiate to the HEAT TRANSFER MEDIUM.

- cc) requirements for SPECIMEN loading, distributing and fixing within the working space for BATH, INCUBATOR or TEST CHAMBER or over the holder of MECHANICAL MOVEMENT;
- dd) procedures to be followed to shut down the equipment safely and leave it in a safe state;
- ee) warning against access to WALK-IN EQUIPMENT (see also Annex BB) for untrained personnel or children. Requirements for access to WALK-IN EQUIPMENT, in particular the use of personal protective equipment, presence of a second OPERATOR, unlocking mechanism and clearance of the door, and indicating device when the OPERATOR is inside the equipment;
- ff) requirements for the ventilating device, access port (hatch) and LIQUID CONNECTIONS; warning against HAZARDS from high and low temperatures (see 10.1), liberated hazardous gas, liquid or solid (see 13.1);
- gg) requirements for regular inspection and its intervals with regard to SPECIMEN fixing and potential HAZARDS during the shaking process;
- hh) instructions for proper operation of and warning against HAZARDS from lamps and lamp systems, HUMIDIFIER or steam source and MECHANICAL MOVEMENT;
- ii) instructions for use of personal protective equipment, protective measures or requirement for training.

Conformity is checked by inspection.

Addition:

Add the following new subclause:

5.4.4.101 Cleaning and decontamination

The instructions shall include conditions and intervals for cleaning and, where necessary, decontamination. The recognized generic names of recommended materials for cleaning and decontamination shall be given as well as an indication of any materials which could be likely to be used but which are incompatible with parts of the equipment or with material contained in it.

The instructions shall also state that the RESPONSIBLE BODY shall ensure that:

- a) appropriate decontamination is carried out if a hazardous substance is spilt onto or into the equipment;
- b) no decontamination or cleaning agents are used which could cause a HAZARD as a result of a reaction with parts of the equipment or with material contained in it;
- c) the manufacturer or his agent is consulted if there is any doubt about the compatibility of decontamination or cleaning agents with parts of the equipment or with material contained in it.

If a manufacturer claims that an item can be decontaminated by steam sterilization, it shall be capable of withstanding steam sterilization under at least one of the time-temperature conditions given in Table 101.

Manufacturers should be aware of the internationally recognized "Laboratory Biosafety Manual", published by the World Health Organization in Geneva, which gives information on decontaminants, their use, dilutions, properties and potential applications. There are also national guidelines which cover these areas.

Cleaning and decontamination may be necessary as a safeguard when equipment intended for biological application and any accessories are maintained, repaired, or transferred. Manufacturers are required to provide a format for the RESPONSIBLE BODY to certify that such treatment has been carried out.

Table 101 – Time-temperature conditions

Absolute pressure kPa	Corresponding steam temperature		Minimum hold time min
	Nominal °C	Range °C	
325	136,0	134 to 138	3
250	127,5	126 to 129	10
215	122,5	121 to 124	15
175	116,5	115 to 118	30
NOTE "Minimum hold time" means the time during which the containment is at steam temperature.			

Conformity is checked by inspection.

5.4.5 Equipment maintenance and service

Replacement:

Replace the text with the following:

Where continued safe operation is dependent on regular scheduled maintenance, inspection and/or ~~maintenance~~ testing of the equipment, the instructions to the RESPONSIBLE BODY shall detail the required maintenance, inspection and ~~maintenance~~/or testing procedures, and provide information to assist the RESPONSIBLE BODY in determining a suitable maintenance schedule.

In particular the following details shall be included if applicable:

- Detailed specifications for the REFRIGERANT (see 5.1.101), HEAT TRANSFER MEDIUM, flexible tubing, hose, fittings, insulation materials, lamps, door gaskets which are specific to the equipment.
- Intervals, detailed procedures for checking the function of safety-related mechanisms of MECHANICAL MOVEMENT, specific consumable parts and accessories.
- Intervals, detailed procedures for inspecting the function of the TEMPERATURE-LIMITING DEVICE, LIQUID LEVEL CUT OUT, PRESSURE-LIMITING DEVICE and similar protective devices.
- Intervals and detailed procedures for cleaning of the piezo-electric transducer used in an ultrasonic HUMIDIFIER, RESISTANCE-HEATING DEVICE, water heat exchanger, and filters in the heat exchanging system.
- Statement that maintenance operations ACCESSIBLE by means of a TOOL shall be carried out only by trained personnel approved by the manufacturer.
- Where applicable, instructions shall specify procedures for the RESPONSIBLE BODY to check the effective operation of devices or systems for overtemperature protection, liquid level protection, high or low pressure protection, the unlocking or interlocking mechanism of a door or lid for escaping from within the WALK-IN EQUIPMENT (see Annex BB) which are necessary for safety, and shall state how often the checks need to be made.

If applicable, the manufacturer's documentation shall instruct against replacing detachable MAINS supply cords by inadequately RATED cords.

For equipment using replaceable batteries, the specific battery type shall be stated.

The instructions shall specify any parts which are required to be examined or supplied only by the manufacturer or his agent to ensure that safety is not compromised. Listing the manufacturer's part number is considered sufficient when the manufacturer does not wish to allow alternatives to be used.

The RATING and characteristics of replaceable fuses shall be stated.

Where special procedures are required to prepare equipment for periods of inactivity, storage or for decommissioning, these procedures shall be detailed in the instructions.

If the equipment is to be kept idle and/or stored under freezing ambient conditions, instructions for power disruption, liquid draining and DRYING-OUT shall be given.

Precaution statements and warnings against HAZARDS related to procedures for maintenance and inspection shall be given.

Instructions on the following subjects shall be provided for service personnel, as necessary to permit safe servicing and continued safety of the equipment after servicing if the equipment is suitable to be serviced:

- a) ~~product-specific~~ RISKS, specific to the equipment, that ~~may~~ can affect the service personnel;

- b) protective measures for these RISKS;
- c) verification of the safe state of the equipment after repair.

Instructions for service personnel need not be supplied to the RESPONSIBLE BODY, but should be made available to service personnel.

Conformity is checked by inspection.

Addition:

Add the following new subclauses:

5.4.101 Additional instructions for refrigerating equipment that use FLAMMABLE REFRIGERANT

For refrigerating equipment that uses FLAMMABLE REFRIGERANT, the instructions shall include sufficient information to ensure the safe handling, servicing and disposal of the equipment.

The instructions shall include the substance of the following warnings as necessary:

- **WARNING:** ~~Keep clear of obstruction all ventilation openings in the ENCLOSURE or in the structure for building in~~ Ensure all ventilation openings are not obstructed;
- **WARNING:** Do not use mechanical devices or other means to accelerate the defrosting process, other than those recommended by the manufacturer;
- **WARNING:** Do not damage the refrigerant circuit;
- **WARNING:** Do not use electrical appliances within the equipment, other than those recommended by the manufacturer.

NOTE For the US, additional marking and informational requirements exist for refrigerating equipment which employs FLAMMABLE REFRIGERANTS. See Annex DD for detailed information.

For equipment which uses flammable gas for insulation blowing, the instructions shall include information regarding disposal of the equipment.

The instructions for equipment incorporating a remote REFRIGERANT CONDENSING UNIT that uses a FLAMMABLE REFRIGERANT shall include the substance of the following warning:

- **WARNING:** In order to reduce fire hazards, the installation of this equipment shall only be carried out by qualified personnel approved by the manufacturer.

The marking of the type of FLAMMABLE REFRIGERANT and of the flammable gas for insulation blowing shall be visible when gaining access to the MOTOR-COMPRESSORS, and, in the case of equipment with a remote REFRIGERANT CONDENSING UNIT, the pipe connections.

Symbol 102 of Table 1, ~~Warning: FLAMMABLE LIQUID~~ shall be placed on the nameplate of the equipment near the declaration of the REFRIGERANT type and charge information. It shall be clearly visible after installation of the equipment.

Conformity is checked by inspection.

5.4.102 Additional instructions for equipment intended for use with a FLAMMABLE LIQUID HEAT TRANSFER MEDIUM

For BATHS, CIRCULATORS and shaking BATHS intended for use with a FLAMMABLE LIQUID HEAT TRANSFER MEDIUM, the instructions shall include sufficient information to ensure the safe handling, servicing and disposal of the equipment.

The instructions shall include the substance of the following warnings as necessary:

- WARNING: ~~Keep clear of obstruction all ventilation openings in the ENCLOSURE, the APPLICATION SYSTEM or in the structure for building in~~ Ensure all ventilation openings are not obstructed;
- WARNING: No smoking! No flame! Do not use electrical parts which ~~may~~ can produce spark when operating around the equipment and the application system;
- WARNING: Drain and recover the liquid when the equipment idles, if the liquid heat transfer medium is used with open bath tank and if it is highly volatile at ambient temperature.

A label carrying symbol 102 shall be provided with the equipment which can be used with a FLAMMABLE LIQUID HEAT TRANSFER MEDIUM along with instructions for the RESPONSIBLE BODY to affix the label visibly on the equipment if it is to be used with a FLAMMABLE LIQUID HEAT TRANSFER MEDIUM.

The instructions shall be provided with detailed information for procedures to reduce the RISK with regard to the use of a FLAMMABLE LIQUID HEAT TRANSFER MEDIUM, including how the adjustable TEMPERATURE-LIMITING DEVICE is adequately set so that the surface temperature in contact with the liquid is below the limit of 9.5 a).

Conformity is checked by inspection.

6 Protection against electric shock

This clause of Part 1 is applicable except as follows:

6.1.1 Requirements

Addition:

Add the following after the conformity statement:

If the installation instructions specify a STANDSTILL or DRYING-OUT (see 5.4.3.101), this is carried out before making the measurements set out in 6.3, 6.7.2.2 and 6.8. STANDSTILL or DRYING-OUT is followed by a rest period of 2 h, with the equipment de-energized, before the measurements are taken.

Measurements are made with the equipment at ambient temperature. If there is doubt whether the permissible limits could be exceeded at the least favourable combined operating conditions, the relevant measurements are repeated at these conditions and the higher values are used.

6.3.1 Levels in NORMAL CONDITION

Addition:

Add the following ~~second paragraph~~ to item b) 1):

Levels for PERMANENTLY CONNECTED EQUIPMENT are 1,5 times these values.

6.3.2 Levels in SINGLE FAULT CONDITION

Addition:

Add the following ~~second paragraph~~ to item b) 1):

Levels for PERMANENTLY CONNECTED EQUIPMENT are 1,5 times these values.

6.7.2.2 Solid insulation

Addition:

Add the following new subclause:

6.7.2.2.101 DRYING-OUT

If the performance requirements of the equipment cannot be achieved without the use of hygroscopic heater insulation, it is permissible for equipment to require a period of operation to dry out the insulation before meeting the requirements of 6.7.2.2, 6.3.1 and 6.8.2 provided that the OPERATOR is made aware of this (see 5.4.3.101).

Conformity is checked by performing the DRYING-OUT specified in the OPERATOR manual (see 5.4.3.101) before conducting the tests of 6.3.1 and 6.8.2.

6.8.1 General

Addition:

Add the following paragraph after the second paragraph:

If a DRYING-OUT is specified (see 6.7.2.2.101), this is carried out in accordance with the OPERATOR manual (see 5.4.3.101) before the tests of 6.8.3. DRYING-OUT is followed by a rest period of 2 h with the equipment de-energized. The tests are then performed and completed within 1 h at the end of the rest period.

6.8.2 Humidity preconditioning

Addition:

Add the following at the end of the last paragraph:

Equipment for which a DRYING-OUT is specified (see 5.4.3.101) shall not be subjected to humidity preconditioning.

6.9.1 General

Addition:

Add the following paragraph after the note:

Bare HAZARDOUS LIVE parts and insulated wiring and connections shall be so routed and arranged that the CLEARANCES and CREEPAGE DISTANCES are not reduced below acceptable values by:

- 1) liquids, vapours or impurities condensed, accumulated or leaking inside the equipment;
- 2) contact with hot or cold parts;
- 3) mechanical stress or abrasion by sharp edges.

6.10.1 MAINS supply cords

Replacement:

Replace the third and fourth paragraphs as follows:

If a cord is likely to come into contact with hot or cold external parts of the equipment, it shall be made of suitably temperature-resistant material or, alternatively, additional protection shall

be provided to prevent the cord ~~contacting~~ from coming into contact with the heated or cold surface.

If the cord is detachable, both the cord and the appliance inlet shall have adequate temperature RATINGS. The cord and the appliance inlet shall have a temperature RATING above the maximum temperatures measured under NORMAL CONDITION on any part of the appliance inlet itself.

The appliance coupler shall have a mechanism which prevents the cord of a lower temperature RATING from being inserted into the appliance inlet featuring a higher temperature RATING.

NOTE An appliance coupler in compliance with IEC 60320 (all parts), such as that with style C15 and C16, or C21 and C22 for hot conditions, or C15A and C16A for super hot conditions is an example of a required mechanism.

7 Protection against mechanical HAZARDS

This clause of Part 1 is applicable except as follows:

7.3.5.1 Gap limitations between moving parts – Access normally allowed

Addition:

Add the following paragraphs after the first paragraph:

If the width of the gap ~~may~~ can decrease from a value larger than the minimum gap ~~of~~ specified in Table 13 for that body part to a value smaller than the minimum gap in NORMAL CONDITION and SINGLE FAULT CONDITION, for example the door and/or locking device of TEST CHAMBERS or INCUBATORS, including WALK-IN EQUIPMENT (see Annex BB), the door or locking device shall be provided with a handle or shaft so that hand, wrist, fist and fingers are kept away from the moving gap during the operation of closing and/or locking the door. If twin doors are used, they may be so constructed that closing and/or locking of one door is possible only after the other door is closed, where the HAZARD of crushing is minimized.

Additional warning marking is necessary in proximity to the moving gap and where the locking device is located by using symbol 106 of Table 1.

Addition:

Add the following new subclause:

7.3.101 Warning markings for MECHANICAL MOVEMENT

The MECHANICAL MOVEMENT area in a SHAKER or COMBINED TEST CHAMBER shall be marked with symbol 14 of Table 1 or the applicable symbol 122 to 127 of Table AA.1.

The SPECIMEN holder of the MECHANICAL MOVEMENT shall be marked with symbol 14 of Table 1.

Conformity is checked by inspection.

7.4 Stability

Addition:

Add the following new subclauses:

7.4.101 Movement during operation

The equipment shall not change position during NORMAL USE.

Conformity is checked by inspection and test.

The equipment shall be operated according to the manufacturer's specifications, at the setting and load condition representing the worst case normal operating condition. Operating time is 10 min, or one operation cycle, whichever is shorter.

Movement shall be limited either by design, or by fastening to the mounting surface, or a combination of both, so that no part of the equipment moves outside a clearance envelope extending 5 mm, or less if stated by the manufacturer, in any direction from the outermost parts of the equipment in its original position.

During the tests the equipment shall remain in position. Any flexible tubing or other mechanical connection between the equipment and the APPLICATION SYSTEM shall withstand stress which could cause HAZARD.

For equipment intended for long-term continuous operation, the maximum excursion and test period is to be determined through the RISK assessment of Clause 17.

7.4.102 Removable SPECIMEN holder for MECHANICAL MOVEMENT

If a HAZARD, such as abnormal noise or mechanical injury from the imbalance or uncoupling of the SPECIMEN holder for MECHANICAL MOVEMENT during NORMAL USE could result during its removal or reengagement, the removable SPECIMEN holder shall be marked with an appropriate warning symbol in close proximity to the handles of the holder and an explanation shall be included in the documentation.

Conformity is checked by inspection.

7.5 ~~Lifting devices and supporting parts~~ Provisions for lifting and carrying

7.5.1 General

Addition:

Add the following text after the first paragraph:

Where the physical construction is such that parts which are not designed to be used as handles, grips, lifting devices or supporting parts could be mistaken as such, **they** shall:

- have a strength identical to or higher than that required for normal lifting devices or supporting parts, or
- have a warning marking (see 5.2) **located adjacent to the relevant part(s), indicating that ~~the parts they~~ shall not be used as handles, grips, lifting devices or supporting parts adjacent to the part(s).** Symbol 14 of Table 1 and additional explanations in the documentation are considered to meet the requirements.

Replacement:

Replace the conformity statement as follows:

Conformity is checked by inspection and as specified in 7.5.2 and 7.5.3.

8 Resistance to mechanical stresses

This clause of Part 1 is applicable except as follows:

8.1 General

Replacement:

Replace the text of item 3) by the following:

- 3) except for FIXED EQUIPMENT, for equipment with a mass over 100 kg, or for equipment whose size and weight make unintentional movement unlikely and which is not moved in NORMAL USE.

8.2.1 Static test

Replacement:

Replace the second paragraph by the following:

An ENCLOSURE which is non-metallic or has glass as part of its construction is operated until a steady-state condition is reached at the least favourable of the following conditions:

- a) *at maximum or minimum ambient temperature; or*
- b) *at extended maximum or minimum ambient temperature; or*
- c) *over the maximum or minimum ~~operating~~ CONTROLLED TEMPERATURE; or*
- d) *cycled between the maximum and minimum CONTROLLED TEMPERATURE range; or*
- e) *with all the lamps on and at maximum power input for radiation.*

The equipment is disconnected from the supply source before the test is performed.

8.2.2 Impact test

Replacement:

Replace the ~~second~~ first paragraph after the Note by the following:

An ENCLOSURE which is non-metallic or has glass as part of its construction is operated until a steady-state condition is reached at the least favourable of the following conditions:

- a) *at maximum or minimum ambient temperature; or*
- b) *at extended maximum or minimum ambient temperature; or*
- c) *over the maximum or minimum ~~operating~~ CONTROLLED TEMPERATURE; or*
- d) *cycled between the maximum and minimum CONTROLLED TEMPERATURE range; or*
- e) *with all the lamps on and at maximum power input for radiation.*

The equipment is disconnected from the supply source and then tested within 10 min.

9 Protection against the spread of fire

This clause of Part 1 is applicable except as follows:

9.5 Requirements for equipment containing or using FLAMMABLE LIQUIDS

Addition:

Add the following text after the first paragraph:

This subclause 9.5 applies to FLAMMABLE LIQUIDS other than FLAMMABLE REFRIGERANTS. The requirements for FLAMMABLE REFRIGERANTS are covered in 5.4.101 and 11.7.101.

Replacement:

Replace item a) and Note 1 by the following:

- a) The equipment shall be so constructed that it complies with items 1), 2) and 3) as follows:
- 1) In NORMAL CONDITION and SINGLE FAULT CONDITION, the surface temperature of the FLAMMABLE LIQUID shall not exceed the FLASH POINT of the liquid being exposed to the air.
 - 2) In NORMAL CONDITION and SINGLE FAULT CONDITION, the surface temperature of any RESISTANCE-HEATING DEVICE at the surface of the FLAMMABLE LIQUID and in contact with air shall not exceed $(t - 25) ^\circ\text{C}$, where t is the FIRE POINT of the liquid.
 - 3) For equipment where ~~a user~~ an OPERATOR setting could expose a FLAMMABLE LIQUID to a condition where the temperatures in a) 1) or 2) could be exceeded in the case of a SINGLE FAULT CONDITION during REASONABLY FORESEEABLE MISUSE, additional measures shall be provided to protect the OPERATOR from this HAZARD.
 - For example, a LIQUID LEVEL CUT OUT that disables the RESISTANCE-HEATING DEVICE before the temperature requirements of a) 1) or 2) are exceeded is considered to comply with this requirement.
 - Consideration should be given to any scenario that ~~may~~ can expose any permitted FLAMMABLE LIQUID to a temperature that could exceed $t_a - 100 ^\circ\text{C}$, where t_a is the AUTO IGNITION TEMPERATURE.
 - The use of a FLAMMABLE LIQUID not approved by the manufacturer for use in the equipment is not considered as an OPERATOR setting and is therefore beyond the evaluation of Clause 16.

NOTE 101 Guidance on what is considered REASONABLY FORESEEABLE MISUSE is provided in 16.1.

It is not sufficient to limit the surface temperature of the FLAMMABLE LIQUID and parts in contact with the surface solely by the temperature control system. Overtemperature protection meeting the requirements of 10.101 achieved by an independent, adjustable TEMPERATURE-LIMITING DEVICE shall be used.

NOTE 102 The surface temperature of a RESISTANCE-HEATING DEVICE used to heat a liquid can be considerably higher than the temperature of the liquid.

NOTE 103 Additional instructions for equipment intended for use with a FLAMMABLE LIQUID HEAT TRANSFER MEDIUM are detailed in 5.4.102.

Addition:

Add the following note after item c):

NOTE 104 Where FLAMMABLE LIQUID is present in the equipment, symbol 102 can be used as a warning marking.

Replacement:

Replace the first paragraph of the conformity statement by the following:

Conformity is checked by inspection, including nameplate, documentation and function of the equipment and, if necessary, by the tests and measurements of temperature as specified in 10.4 and 10.101.

10 Equipment temperature limits and resistance to heat

This clause of Part 1 is applicable except as follows:

10.1 Surface temperature limits for protection against burns

Replacement:

Replace the title by the following:

10.1 Surface temperature limits for protection against burns and frostbite

Replace the third paragraph by the following:

If easily touched heated surfaces are necessary for functional reasons, whether because they are intended to deliver heat or they are hot because of proximity to heating parts, they are permitted to exceed the values of Table 19 in NORMAL CONDITION and to exceed 105 °C in SINGLE FAULT CONDITION, provided that they are recognizable as such by appearance or function or are marked with symbol 13 of Table 1 (see 5.2). Equipment heated by its environment to temperature values exceeding the values in Table 19 in NORMAL CONDITION and 105 °C in SINGLE FAULT CONDITION need not be marked with symbol 13.

NOTE The limit for the maximum surface temperature of the housing of the discharge pipe in proximity to the MOTOR-COMPRESSOR conforming to IEC 60335-2-34 (including IEC 60335-2-34:2012, IEC 60335-2-34:2012/AMD1:2015 and IEC 60335-2-34:2012/AMD2:2016, Annex AA) is 150 °C when tested at 43 °C ambient.

If the minimum temperature of the easily touched cold surfaces exceeds the value of –30 °C, the cold surface shall be marked with symbol 101 of Table 1 to warn the OPERATOR ~~against~~ of the HAZARD of frostbite (see 5.2). Equipment cooled by its environment to temperature values lower than –30 °C need not be marked with symbol 101.

Additionally, where the liquid temperature could be higher than +60 °C or lower than –30 °C, or where the temperature of air or gas mixture could be higher than +70 °C or lower than –40 °C, consideration should be given to mark the following ~~for warning~~ to warn against possible burn and/or frostbite HAZARDS:

- a) ~~for~~ movable immersion CIRCULATOR during movement for NORMAL USE, the surface of the equipment in close proximity to the wetted parts may be marked with symbol 13 and/or symbol 101.
- b) LIQUID CONNECTIONS for circulating, draining or overflowing of the HEAT TRANSFER MEDIUM may be marked with symbol 13 and/or symbol 101, and/or ~~with~~ the maximum and/or minimum ~~working~~ CONTROLLED TEMPERATURES of the equipment in association with symbols 108, 111, 117 or 118.
- c) The exhaust opening may be marked with symbol 13 and/or symbol 101 and/or, the maximum and/or minimum ~~working~~ CONTROLLED TEMPERATURES of the equipment in association with symbol 121.
- d) If an enclosed CIRCULATOR is intended for a hydraulically sealed APPLICATION SYSTEM, the LIQUID CONNECTION for filling the BATH TANK or the exhaust of a PRESSURE-RELIEF DEVICE may be marked with symbol 13 and/or symbol 101 and/or the maximum and/or minimum ~~working~~ CONTROLLED TEMPERATURES of the equipment in association with symbol 116.

Addition:

Add the following paragraph after the fourth paragraph:

For TEST CHAMBERS, INCUBATORS, and similar equipment with heating functions for high temperatures, there shall be an indication of the "ON" condition on each side of the equipment which has a door in it or has any other opening intended for loading of the SPECIMEN.

Replacement:

Replace the conformity statement with the following:

Conformity is checked by inspection and by measurement as specified in 10.4, and by inspection of barriers to check that protection against accidentally touching surfaces exceeding temperatures above the values of Table 19 is appropriate, and that they cannot be removed without the aid of a TOOL.

10.2 Temperatures of windings

Addition:

Add the following text and table after Table 20:

Conformity for MOTOR-COMPRESSORS is checked by measurement as specified in 10.4, in NORMAL CONDITION and in the applicable SINGLE FAULT CONDITIONS of 4.4.2.10, 4.4.2.101 and also in any other SINGLE FAULT CONDITIONS that could cause a HAZARD as a result of excessive temperature or pressure. The temperature limits for MOTOR-COMPRESSORS are defined in Table 102. The pressures are recorded for use in accordance with 11.7.2.

Table 102 – Maximum temperatures for MOTOR-COMPRESSORS

Part of the MOTOR-COMPRESSOR	Temperature (°C)
Windings with	
– synthetic insulation	140
– cellulosic insulation or the like	130
Housing	150

10.4 Conduct of temperature tests

10.4.1 General

Replacement:

Replace the text with the following:

Maximum temperature is determined by measuring the temperature rise under reference test conditions defined by 4.3.1 of this document. Linear extrapolation is not permitted. Unless a particular SINGLE FAULT CONDITION specifies otherwise, the NORMAL USE of the equipment as defined in 4.3.2 of this document and the manufacturer's instructions concerning ventilation, cooling liquid, limits for intermittent use, etc., are followed. Any cooling liquid shall be at the highest RATED temperature. Operating pressures shall be monitored and recorded during all the temperature ~~runs~~ tests for use in the evaluation of the PS.

Alternatively, temperature measurements are made at the least favourable ambient temperature within the RATED ambient temperature range of the equipment if this represents a less favourable condition. Measures are taken to eliminate errors caused by the method of achieving the test ambient temperature (e.g. suitable baffling or ENCLOSURE if the test is conducted in an environmental testing TEST CHAMBER and the forced air movements would cool the exterior of the equipment).

When measuring temperatures and pressures for REFRIGERATING SYSTEMS, the tests shall be started from a SOAKED TEMPERATURE CONDITION when all pressures have been fully equalized. Tests at the extremes of the input voltage ($\pm 10\%$) shall start under these voltage conditions and achieve a stable state but need not start from a SOAKED TEMPERATURE CONDITION. At the

termination of the test, the monitoring shall continue after the equipment is switched off until the pressures from each REFRIGERANT stage have equalized or clearly demonstrate that maximum values have been reached.

During the test, protective devices other than self-resetting thermal motor-protectors for MOTOR-COMPRESSORS shall not operate. When steady conditions have been established, thermal motor-protectors for MOTOR-COMPRESSORS shall not operate.

Unless thermocouples are embedded in the windings of the MOTOR-COMPRESSOR, winding temperatures shall be taken using the change of resistance method in accordance with Annex E of IEC 60950-1:2005, and should be recorded at initial conditions and at steady-state. All other temperature and pressure measurements shall be taken continuously and the maximum temperatures and pressures recorded.

For MOTOR-COMPRESSORS conforming with IEC 60335-2-34 (including IEC 60335-2-34:2012, IEC 60335-2-34:2012/AMD1:2015 and IEC 60335-2-34:2012/AMD2:2016, Annex AA), the temperatures of the following parts are not measured:

- MOTOR-COMPRESSOR housing;
- MOTOR-COMPRESSOR windings and other accessories, such as parts for protection, start-up, and any other parts that are tested with MOTOR-COMPRESSORS in accordance with IEC 60335-2-34 (including IEC 60335-2-34:2012, IEC 60335-2-34:2012/AMD1:2015 and IEC 60335-2-34:2012/AMD2:2016, Annex AA).

For MOTOR-COMPRESSORS not conforming with IEC 60335-2-34 (including IEC 60335-2-34:2012, IEC 60335-2-34:2012/AMD1:2015 and IEC 60335-2-34:2012/AMD2:2016, Annex AA), the temperatures of the following parts shall not exceed the limits as specified in Table 102:

- MOTOR-COMPRESSOR housing;
- MOTOR-COMPRESSOR windings.

Addition:

Add the following new subclauses:

10.101 Overtemperature protection

When a single fault in the equipment could lead to a HAZARD from overheating of the equipment or material being processed, a non-self-resetting TEMPERATURE-LIMITING DEVICE or system meeting the requirements of 14.3 shall de-energize the RESISTANCE-HEATING DEVICE and any other parts which could cause a HAZARD.

If an insufficient quantity of liquid HEAT TRANSFER MEDIUM could cause a HAZARD, a self-resetting or non-self-resetting LIQUID LEVEL CUT OUT shall de-energize the RESISTANCE-HEATING DEVICE and any other parts which could cause a HAZARD. When the temperature of a surface in direct contact with the FLAMMABLE LIQUID HEAT TRANSFER MEDIUM exceeds $t_a - 100\text{ °C}$, where t_a = AUTO IGNITION TEMPERATURE, the LIQUID LEVEL CUT OUT shall operate before this surface can be exposed to air.

If a HAZARD could result from an incorrect immersion depth, movable immersion CIRCULATORS, when combined with either an open BATH TANK or a refrigerating BATH resulting in a BATH or CIRCULATOR, shall be marked with the maximum and minimum depth of immersion. These markings may be horizontal lines if additional explanation is included in the documentation.

For equipment designed to contain FLAMMABLE LIQUIDS, either for treatment or for heat-transfer, TEMPERATURE-LIMITING DEVICES or systems shall ensure, when set as directed in the manufacturer's instructions, that the temperature of the liquid shall not exceed the value as specified in 9.5 a) in NORMAL USE or SINGLE FAULT CONDITION.

The equipment as a whole, or the relevant parts, shall be de-energized by one of the following methods:

- a) For single-phase equipment, the proposed circuit and physical construction shall be examined to identify possible single faults. The TEMPERATURE-LIMITING DEVICE shall be placed in the pole of the supply that provides the better protection from single faults that could defeat the overtemperature protection in the event of a subsequent failure of the temperature control system. A device which isolates both phase and neutral conductors at the same time ~~may~~ can provide double fault protection (depending on application) and should be considered if the residual RISK is unacceptable.

Conformity is checked by inspection of the circuit diagram, the data sheet for the TEMPERATURE-LIMITING DEVICE, and the method in which it is installed in the equipment, and, if necessary, by the tests specified in 14.3.

- b) For polyphase equipment, either by one single device or a system disconnecting all phases ~~or, an individual device or system for each phase.~~

~~c) a device or system providing disconnection from all poles of the supply.~~

Consideration shall be given to the following:

- In equipment designed for the cooling and/or heating of materials, HAZARDS ~~may~~ can arise from the overheating of materials being processed or overheating of the liquid HEAT TRANSFER MEDIUM as well as from the overheating of parts of the equipment itself. For this reason a higher level of safety may ~~be needed to provide~~ need to be provided in case of a SINGLE FAULT CONDITION in the equipment.
- In some cases, a fall in the CONTROLLED TEMPERATURE of a heated medium (for example liquid in a BATH or CIRCULATOR air in an oven or heating cabinet) could cause a HAZARD. If this could occur as a result of the operation of a TEMPERATURE-LIMITING DEVICE, ~~or system after failure of the TEMPERATURE controller, a second temperature controller may be fitted to maintain a safe temperature without the operation of a TEMPERATURE-LIMITING DEVICE~~ an additional independent system may be used to prevent the CONTROLLED TEMPERATURE from falling to a hazardous level.

NOTE NORMAL USE (which is use in accordance with the manufacturer's instructions) includes the correct setting of any adjustable TEMPERATURE-LIMITING DEVICE. If the OPERATOR is instructed to change the set point of the TEMPERATURE-LIMITING DEVICE (including providing the TOOL if required) then the incorrect setting of the TEMPERATURE-LIMITING DEVICE ~~may~~ can be considered REASONABLY FORESEEABLE MISUSE. Refer to 16.1 for additional guidance.

TEMPERATURE-LIMITING DEVICES necessary for safety shall be separate from any temperature controller. This applies not only to the temperature sensing means but also to all disconnecting devices in the circuits to be de-energized. Whether operated by temperature, pressure, liquid level, airflow or other means, they shall meet the requirements of 14.3.

Adjustable TEMPERATURE-LIMITING DEVICES and system shall be adjustable only with the aid of a TOOL or similar means that prevents unintended adjustment.

Conformity is checked by inspection and during the fault tests specified in 4.4.2.10, 4.4.2.11 and as applicable, the tests in 4.4.2.101 to ~~4.4.2.107~~ 4.4.2.106.

10.102 Restarting after interruption of cooling and/or heating

According to applications, a HAZARD could arise either by re-starting or by not re-starting after interruption of the cooling and/or heating as result of the termination of the circulating or agitating in a BATH or CIRCULATOR and in an oven or TEST CHAMBER. Equipment shall be incorporated with the appropriate means to re-start or not re-start, and instructions shall specify whether the equipment will re-start or not re-start, both in the case of MAINS interruption and in the case of a SINGLE FAULT CONDITION.

NOTE In some cases, it ~~may~~ can be appropriate for an audible or visible signal to warn that an interruption has occurred.

Conformity is checked by inspection and test.

11 Protection against HAZARDS from fluids and solid foreign objects

This clause of Part 1 is applicable except as follows:

11.1 General

Addition:

Add the following paragraph and Note 101 after the conformity statement:

Equipment intended to be connected to the water ~~mains~~ supply shall be constructed to prevent backsiphonage of non-potable water into the water ~~mains~~ supply.

NOTE 101 IEC 61770 gives requirements for preventing backsiphonage of non-potable water into the water ~~mains~~ supply and tests.

Conformity is checked by inspection.

11.3 Spillage

Addition:

Add the following text after the conformity statement:

The construction of a draining valve, nozzle and any other similar device shall be designed to prevent them from being opened or pulled out unintentionally.

Conformity is checked by inspection.

11.4 Overflow

Replacement:

Replace the title and text of 11.4 with the following:

11.4 Overflow and low level

Liquid overflowing from any container in the equipment which can be overfilled or overflowed, whether by the OPERATOR or for functional reasons as part of equipment operation, shall not cause a HAZARD during NORMAL USE or in SINGLE FAULT CONDITION, for example, as a result of the wetting of insulation or of internal uninsulated parts that are HAZARDOUS LIVE.

Equipment likely to be moved while a vessel is full of liquid shall be protected against liquid surging out of the vessel.

Equipment containing liquid, whether as the HEAT TRANSFER MEDIUM or as a result of treatment, experiencing expansion and contraction, evaporation, spray, rain or ~~collecting~~ dripping when being heated, cooled, atomized, irrigated or condensed shall be provided with means to protect against any HAZARD associated with the overflow or low level during NORMAL USE or in SINGLE FAULT CONDITION.

Conformity is checked by inspection and by carrying out each of the following treatments and tests, if applicable. Immediately after the treatment, the CLEARANCE and solid insulation shall pass the voltage tests of 6.8 (without humidity preconditioning) applicable to the type of

insulation (see 6.7), and ACCESSIBLE parts shall not exceed the limits of 6.3.1 for NORMAL USE and 6.3.2 under SINGLE FAULT CONDITION.

For BATHS, CIRCULATORS and similar equipment incorporating a liquid vessel, operate the equipment as follows:

Fill the BATH TANK or any other liquid vessel of the equipment to its maximum level with water unless otherwise specified, following the instructions of the manufacturer.

a) Spillage from overflow

The filling is continued for an additional amount equal to 20 % of the vessel capacity, but not less than 0,25 l, or for 1 min after the first evidence of overflow. Where no spillage occurs due to the function of the LIQUID CONNECTION for overflow that prevents such spillage, the filling is continued for a further amount equal to 30 % of the vessel capacity, or for 5 min following the overflow through the LIQUID CONNECTION.

The LIQUID CONNECTION for overflow, if so equipped, shall be connected and fitted as instructed in the manual. If not specified by the manufacturer, use a filling rate of 10 l/min.

Take the value resulting from the least favourable situation. There shall be no wetting of conductive live parts.

For a remotely controlled automatic refill system, a RISK assessment shall be carried out according to Clause 17.

b) Splash from low level

Drain the BATH TANK or any other liquid vessel of the equipment to its minimum level or just prior to the evidence of the triggering of the low LIQUID LEVEL CUT OUT, if so equipped, while keeping the equipment running and the functional assembly relying on appropriate liquid level operating, for example, by ensuring that the CIRCULATING PUMP and HUMIDIFIER are working.

There shall be no wetting of conductive live parts.

c) Spillage from expansion and contraction

Use the HEAT TRANSFER MEDIUM with the widest CONTROLLED TEMPERATURE range and ~~higher~~ highest coefficient of expansion applicable for the equipment as instructed by the manufacturer.

Set the ~~working~~ CONTROLLED TEMPERATURE of the equipment at ambient and keep the CIRCULATING PUMP running until the CONTROLLED TEMPERATURE is stabilized, and:

- 1) set the CONTROLLED TEMPERATURE of the equipment to its minimum, then to its maximum applicable for the same liquid, and finally to ambient. Change the setting only if the CONTROLLED TEMPERATURE is stabilized at its setting or there is no evidence of further significant changing. Refill the BATH TANK if necessary with the same liquid to its maximum level for NORMAL USE prior to subsequent tests;
- 2) set the CONTROLLED TEMPERATURE of the equipment to its maximum, then to its minimum, and finally to ambient. Change the setting only if the CONTROLLED TEMPERATURE is stabilized at its setting or there is no evidence of further significant changing. Refill the BATH TANK if necessary with the same liquid to its maximum level for NORMAL USE prior to subsequent tests;
- 3) program the setting for the CONTROLLED TEMPERATURES of the equipment to its maximum, minimum and time for the change that maximum difference of the CONTROLLED TEMPERATURE changing is possible. Run the program with two repetitions or until no evidence of a more unfavourable situation is expected.

d) Surging from movement

Remove the plug from the power supply, and operate the equipment as follows:

- 1) For equipment with castors, or provided with accessory trolleys specified by the manufacturer:
 - The equipment is moved in the forward direction on a smooth and solid surface at a speed of 0,5 m/s $\pm$ 0,1 m/s for 2 m, and then with one of the castors against a solid

vertical plane obstacle. The obstacle shall have a rectangular cross section with a height of $10\text{ mm} \pm 0,5\text{ mm}$ and a width of at least 80 mm with a radius of $2\text{ mm} \pm 0,1\text{ mm}$ at the top edges. Unless the direction of movement is mechanically restricted or explicitly specified by the manufacturer, the longest side of the equipment should be aligned with the direction of travel.

- Equipment intended to be moved when the fluid-containing vessel is emptied shall be filled to 50 % of the maximum level.
- Operate the equipment with the obstacle against different castors, and repeat each test three times.

Take the value resulting from the least favourable situation. There shall be no wetting of conductive live parts, or if a HAZARD could result, no wetting of the OPERATOR's grips or handles.

A BATH TANK or any other liquid vessel incapable of sealed operation is left open. Equipment with fully enclosed fluid containing vessels is exempted from this test.

2) For equipment with lifting devices:

- equipment up to 18 kg , including liquid, is subjected to a cycling 10° tilt-test ~~as described below~~, across the short side of the equipment, or
- equipment over 18 kg , including liquid, is subjected to a cycling 5° tilt-test ~~as described below~~, across the long side of the equipment.

In either case, the equipment is subjected to 3 tilt-test cycles, where one cycle consists of the positions flat, tilted left, flat, tilted right, cycled within 10 s .

There shall be no wetting of conductive live parts, and if a HAZARD could result, no spillage outside the equipment or wetting of the OPERATOR's grips or handles.

A BATH TANK or any other liquid vessel incapable of sealed operation is left open. Equipment with fully enclosed fluid containing vessels is exempted from this test.

e) Spillage from condensate and simulated spraying, irrigating or raining

For equipment incorporating a drip pan, operate the equipment as follows:

Block the outlet of the drip pan. Fill the pan with water carefully to the brim without splashing. The drip pan is then subjected to a continuous overflow, the rate of which is adjusted to approximately $17\text{ cm}^3/\text{s}$, or to its maximum RATING specified by the manufacturer. Apply an airflow of $1\text{ m}^3/\text{s}$ if the overflow is influenced by the airflow of the cooling or CIRCULATING FAN(S). The test is continued for a period of 30 min , or until water drains from the equipment.

Equipment incorporating a defrosting device is subjected to a complete cycle of defrosting ~~process~~ under the least favourable conditions.

Equipment ~~completed with~~ incorporating a spraying, irrigating or raining device is subjected to a complete cycle of spraying, irrigating or raining ~~process~~ under the most unfavourable conditions.

Addition:

Add the following new subclauses:

11.4.101 Salt mist, thawing, condensate and spray

Where a HAZARD could result by direct exposure to the spray, the saturated compressed-air for salt-solution atomizing of the salt-spray-corrosion TEST CHAMBER shall be designed to be interlocked by the mechanism of the cover, so that it stops automatically or so that it will not start with the cover opened.

It is permissible for the interlock detailed above to be overridden where necessary for operation or maintenance and when spray is desired with the cover opened, only where

activation of the spray is controlled by a device that needs to be continuously held in the active state by the OPERATOR and the following warning symbol and statement is placed on the equipment:

Hazardous chemicals, use protective respirator, face mask, coveralls or gloves!

Conformity is checked by inspection and evaluation of the interlock according to Clause 15 if relied upon to mitigate the RISK.

The refrigerating subassembly and piping, where necessary for safety, shall be properly insulated and protected against occurrence of condensate or accumulation of frost for NORMAL USE. Salt mist, thawing, condensing and spraying water shall be collected and discharged, ensuring that no leakage, spillage or overflow occurs.

Conformity is checked by inspection. In case of doubt, the CLEARANCES and solid insulation shall pass the voltage tests of 6.8 (without humidity preconditioning) applicable to the type of insulation (see 6.7) and ACCESSIBLE parts shall not exceed the limits of 6.3.1

11.4.102 HAZARDS from liquids in relation to the SPECIMEN and APPLICATION SYSTEM

Fixing devices, tube racks or insulated vessels, and flexible tubing and clamps, if necessary for safety, shall be provided with the equipment to fix the SPECIMENS or for connection to the APPLICATION SYSTEM to protect them from ~~getting in~~ coming into contact with the HEAT TRANSFER MEDIUM.

Where a HAZARD could be caused by excessive torque or pressure applied to a high-viscosity liquid HEAT TRANSFER MEDIUM or to a pressure-sensitive APPLICATION SYSTEM, for example through rupture of a jacketed glass reactor, a CIRCULATOR with a discharge pressure exceeding 0,08 MPa shall be incorporated with pressure-indicating and adjusting devices. A safety device ~~may~~ can be ~~incorporated~~ integrated to interrupt the CIRCULATING PUMP and initiate an alarm signal if the torque or pressure rises above a pre-set value.

According to the applications, a HAZARD could arise either by re-starting or by not re-starting after interruption of the circulation of the liquid ~~circulating~~. Equipment shall be incorporated with the appropriate means to re-start or not re-start, and instructions shall specify whether equipment will re-start or not re-start, both in the case of MAINS or mechanical interruption and in the case of a SINGLE FAULT CONDITION.

Conformity is checked by inspection and in case of doubt by measurement of pressure.

11.4.103 HAZARDS from liquids in relation to the SHAKER

Safety devices or means shall be provided with the SHAKER to protect against HAZARDS from splash and/or spillage of the liquids, accumulation of released volatile or hazardous substances, or condensation of the volatile substances. The safety device shall be independent of the controllers for MECHANICAL MOVEMENT and/or the temperature, humidity ~~etc.~~

Conformity is checked by inspection.

11.4.104 Construction and warning markings related to manual filling or draining

Equipment incorporating a BATH TANK or other liquid container intended for manual filling or incorporating a reservoir for collecting condensate that requires manual draining, if the liquid level is not visible in construction or location, shall be equipped with a clearly visible liquid level indicator. Alternatively, if the liquid level indicator cannot be made available, a warning marking shall be applied and clearly visible in close proximity to the LIQUID CONNECTION for filling or draining. Additional explanations including instructions for operation and maintenance requirements for the warning marking shall be included in the documentation.

Conformity is checked by inspection.

11.4.105 Movable immersion CIRCULATOR

~~Movable immersion CIRCULATOR when removed from the BATH TANK and placed horizontally or up-side down or during movement for NORMAL USE, if HAZARDS could arise because of the liquid penetrating or spillage, shall be marked with symbol 12 or symbol 14 of Table 1 for warning of electric or liquid HAZARD.~~

If HAZARDS could arise from liquid penetration or spillage when the movable immersion CIRCULATOR is removed from the BATH TANK and placed horizontally or upside down or during movement for NORMAL USE, it shall be marked with symbol 12 or symbol 14 of Table 1 to warn of electric or liquid HAZARD.

Conformity is checked by inspection.

11.4.106 Removable SPECIMEN holder for MECHANICAL MOVEMENT

If a HAZARD, such as spillage or overflow of the liquid, could result during the removal or re-insertion, the removable SPECIMEN holder for MECHANICAL MOVEMENT shall be marked with an appropriate warning symbol and text in close proximity to the handles of the holder, and an explanation shall be included in the documentation.

Conformity is checked by inspection or by operation in accordance with instructions.

11.7.1 Maximum pressure

Addition:

Add the following after the conformity statement:

The maximum pressure to which a part of the REFRIGERATING SYSTEM can be subjected under NORMAL CONDITION or SINGLE FAULT CONDITION shall not exceed the RATED MAXIMUM ALLOWABLE PRESSURE for the part. The RATED MAXIMUM ALLOWABLE PRESSURE of a component is determined either by its RATING if certified to the component requirements of 14.101 or by its design if the parts can pass the tests of 11.7.2.

The MAXIMUM ALLOWABLE PRESSURE (PS) of REFRIGERATING SYSTEMS shall be determined by test or by applying the saturated REFRIGERANT pressures at the minimum specified temperatures given in Table 103. When saturated REFRIGERANT pressures are used to define the PS, the manufacturer is exempted from the requirement to recording the pressures during tests for NORMAL USE and under SINGLE FAULT CONDITIONS. If the start-to-discharge pressure of a PRESSURE RELIEF DEVICE or the set pressure of a ruptured member used in the REFRIGERATING SYSTEM is less than the SATURATED-VAPOUR PRESSURE in Table 103, it can be used to limit the PS for that system. The value of the PS when determined by test shall be considered to be the highest of the following:

- a) the maximum pressure developed during the temperature test as defined in 10.4;
- b) the maximum pressure developed during the abnormal test to simulate the failure of the controlled environment in accordance with 4.3.2.114, if applicable;
- c) the maximum pressure developed during the test in SINGLE FAULT CONDITION for cooling as specified in 4.4.2.10;
- ~~c) the maximum pressure developed during the test in SINGLE FAULT CONDITION for extreme operating ambient abnormal in accordance with 4.4.2.106, if applicable;~~
- d) the maximum pressure developed during the temperature test for transportation and storage as defined in 11.7.102.

NOTE 101 For a single REFRIGERATING SYSTEM, the pressure can be separated into two sections, the HIGH-PRESSURE SIDE and LOW-PRESSURE SIDE of each MOTOR-COMPRESSOR; the PS value can be different for each HIGH-PRESSURE SIDE and LOW-PRESSURE SIDE.

NOTE 102 It is possible that equipment meeting the requirements of 11.7 may will not be accepted as conforming to national requirements relating to high pressures. There are notes applied to the relevant requirements which detail the modification of these requirements in order to be accepted as evidence of conformity with national regulations in the USA, in Canada, and in some other countries.

Table 103 – Minimum temperature for the determination of SATURATED-VAPOUR PRESSURE of the REFRIGERANT

Ambient conditions	≤ 43 °C	≤ 55 °C
HIGH-PRESSURE SIDE with air-cooled CONDENSER	63 °C	67 °C
HIGH-PRESSURE SIDE with water-cooled CONDENSER	Maximum leaving water temperature + 8 °C	
HIGH-PRESSURE SIDE with evaporative CONDENSER in a CASCADE SYSTEM	43 °C	55 °C
LOW-PRESSURE SIDE with heat exchanger exposed to the outdoor ambient temperature	43 °C	55 °C
LOW-PRESSURE SIDE with heat exchanger exposed to the indoor ambient temperature	38 °C	38 °C
NOTE 1 For the HIGH-PRESSURE SIDE, the specified temperatures are considered the maximum which will occur during operation. These temperatures are higher than those during the off cycle of the MOTOR-COMPRESSOR. For the LOW-PRESSURE SIDE and/or intermediate pressure side, it is sufficient to base the calculation of pressure on the expected temperature during the off cycle of the MOTOR-COMPRESSOR. These temperatures are minimum temperatures and thus determine that the system will not be designed for a MAXIMUM ALLOWABLE PRESSURE lower than the REFRIGERANT SATURATED-VAPOUR PRESSURE corresponding to these minimum temperatures. NOTE 2 The use of specified temperatures does not always result in REFRIGERANT SATURATED-VAPOUR PRESSURE within the system, for example a limited-charge REFRIGERATING SYSTEM or a system working at or above critical temperature, CO₂ in particular. NOTE 3 For zeotropic blends, the MAXIMUM ALLOWABLE PRESSURE (PS) is the pressure at the bubble point.		

Conformity is checked by inspection of the RATINGS of the parts and, if necessary, by measuring the pressures.

11.7.2 Leakage and rupture at high pressure

Addition:

Add the following new subclauses:

11.7.2.101 Leakage and rupture of REFRIGERATING SYSTEMS

11.7.2.101.1 General

REFRIGERANT-containing parts of a REFRIGERATING SYSTEM shall not cause a HAZARD through rupture or leakage. The specific requirements for REFRIGERATING SYSTEMS using FLAMMABLE REFRIGERANT or FLAMMABLE REFRIGERANT blends are addressed in 11.7.101.

For components subject to the pressure at the HIGH-PRESSURE SIDE or LOW-PRESSURE SIDE of the REFRIGERATING SYSTEM, the structural strength of the fluid-containing parts shall comply with three times the PS as defined in 11.7.1 for the HIGH-PRESSURE SIDE or LOW-PRESSURE SIDE.

Conformity is checked by inspection of the RATINGS of the components exposed to this pressure and, if a HAZARD could arise, by the pressure test in 11.7.2.101.2 and 11.7.2.101.3. Components that are certified to the component requirements in 14.101 and are used within their RATINGS (component pressure RATING ≥ PS) are deemed to comply with this requirement without test.

NOTE 1 For evidence of conformity with national regulations in the USA, in Canada, and in some other countries, the structural strength of components is identical but the design RATING of the component is different based on the safety margin required in the national regulations. For example, in the USA, the design RATING for a component complying with the ASME boiler code is 1/5 of the structural strength of the component.

NOTE 2 In conjunction with NOTE 1, the minimum structural strength RATING of REFRIGERANT-containing components in the USA and Canada is 5 times the PS measured during normal pressure tests and 3 times the PS measured during abnormal pressure tests, where PS is derived from tests in 10.4 for the HIGH-PRESSURE SIDE or LOW-PRESSURE SIDE and the test in 4.4.2.10 for the HIGH-PRESSURE SIDE only. Note the fact of these certification differences during selection of certified components from North America based on the testing conducted in this document.

11.7.2.101.2 Pressure test

The pressure of the component or assembly (equipment under test (EUT)) is raised gradually, by air or non-hazardous gas or via a hydrostatic pressure test, to the specified test value and is held at that value for 1 min. If the continuously ~~operating~~ CONTROLLED TEMPERATURE for the EUT is less than or equal to 125 °C for copper or aluminium, or 200 °C for steel, the test temperature of the EUT during this test shall be at least 20 °C. If the continuously ~~operating~~ CONTROLLED TEMPERATURE for the EUT exceeds 125 °C for copper or aluminium, or 200 °C for steel, the test temperature of the EUT during this test shall be at least 150 °C for copper or aluminium and 260 °C for steel. For other materials or higher CONTROLLED TEMPERATURES, the effects of temperature on the material fatigue characteristics shall be evaluated.

The EUT is considered to comply with the requirements of 11.7.2.101 if it can withstand the pressure test without rupture. If the EUT does not comply, then an alternative method to demonstrate compliance is to subject the EUT to the test in 11.7.2.101.3.

11.7.2.101.3 Fatigue test

If the continuously ~~operating~~ CONTROLLED TEMPERATURE of the EUT exceeds 125 °C for copper or aluminium, or 200 °C for steel, the fatigue test temperature of the parts or assemblies that are at these CONTROLLED TEMPERATURES, shall be at least 10 K above the continuously ~~operating~~ CONTROLLED TEMPERATURE. The static test pressure shall be increased by the ratio of the allowable stress of the material at ~~room ambient~~ temperature to that at the highest continuously ~~operating~~ CONTROLLED TEMPERATURE. For other materials, the effects of the CONTROLLED TEMPERATURE on the fatigue characteristics shall be evaluated to determine the test conditions.

Three test samples shall be filled with fluid, and shall be connected to a pressure-driving source. The pressure shall be raised and lowered between the upper and lower cyclic values at a rate specified by the manufacturer for a total number of 250 000 cycles. The entire specified pressure excursion shall occur during each cycle.

The following test pressures shall be applied:

For safety purposes, it is suggested that a non-compressible fluid be used.

- For components at the LOW-PRESSURE SIDE, the ~~maximum~~ PS for the LOW-PRESSURE SIDE shall be applied for the first cycle. For components at the HIGH-PRESSURE SIDE, the ~~maximum~~ PS for the HIGH-PRESSURE SIDE shall be applied for the first cycle.

The pressure for the test cycles shall be as follows:

- The upper pressure value shall not be less than 0,7 times the PS and the lower pressure value shall not be greater than 0,7 times the PS. The upper pressure shall be 0,9 times the PS, for water-cooled condensers.
- For the final test cycle, the test pressure shall be increased to 1,4 times the PS ($2 \times 0,7 \times PS$). The pressure shall be 1,8 times the PS ($2 \times 0,9 \times PS$), for water-cooled CONDENSERS.

The component shall not rupture, burst or leak during this test.

A strength pressure test at 2 times the PS is to be performed on three samples other than the samples used for the fatigue test.

The component shall not rupture, burst or leak during this test.

11.7.3 Leakage from low-pressure parts

Addition:

Add the following text after the ~~second paragraph~~ conformity statement:

For REFRIGERATING SYSTEMS, the requirements of 11.7.2 address the low-pressure leakage evaluation.

Addition:

Add the following new subclauses:

11.7.101 Additional requirements for REFRIGERATING SYSTEMS that use FLAMMABLE REFRIGERANT

11.7.101.1 General

This document addresses the requirements for REFRIGERATING SYSTEMS which use FLAMMABLE REFRIGERANT when the amount of REFRIGERANT is limited to a maximum of 150 g in each separate REFRIGERANT circuit. For equipment that uses a REFRIGERANT charge of FLAMMABLE REFRIGERANT that exceeds this amount, additional requirements shall apply.

NOTE ISO 5149-1 or EN 378 (all parts) are standards that address the requirements for REFRIGERATING SYSTEMS that utilize ~~greater~~ more than 150 g of FLAMMABLE REFRIGERANT and can be used to identify what the additional requirements ~~may~~ can be.

11.7.101.2 Protected REFRIGERATING SYSTEM

Equipment with a protected REFRIGERATING SYSTEM is that:

- without any part of the REFRIGERATING SYSTEM inside an OPERATOR access compartment;
- where any part of the REFRIGERATING SYSTEM which is located inside an OPERATOR access compartment is constructed so that the REFRIGERANT is contained within an ENCLOSURE with at least two layers of metallic materials separating the REFRIGERANT from the OPERATOR access compartment, each layer having a thickness of at least 0,1 mm. The ENCLOSURE has no joints other than the bonded seams of the EVAPORATOR where the bonded seam has a width of at least 6 mm;
- where any part of the REFRIGERATING SYSTEM which is located inside an OPERATOR access compartment has the REFRIGERANT contained in an ENCLOSURE which itself is contained within a separate protective ENCLOSURE. If leakage from the containing ENCLOSURE occurs, the leaked REFRIGERANT is contained within the protective ENCLOSURE and the REFRIGERATING SYSTEM will not function as in NORMAL USE. The protective ENCLOSURE shall also withstand the test of 11.7.2.101. No critical point in the protective ENCLOSURE shall be located within the OPERATOR access compartment.

Separate compartments with a common air circuit are considered to be a single compartment.

Equipment with a protected REFRIGERATING SYSTEM and which uses FLAMMABLE REFRIGERANT shall be so constructed as to avoid any fire or explosion HAZARD in the event of leakage of the REFRIGERANT from the REFRIGERATING SYSTEM.

Separate components such as thermostats which contain less than 0,5 g of FLAMMABLE REFRIGERANT are not considered to cause a fire or explosion HAZARD in the event of a leakage from the component itself.

For equipment with a protected REFRIGERATING SYSTEM, no additional requirements apply to electrical components located inside OPERATOR access compartments.

Equipment with a protected REFRIGERATING SYSTEM which, when tested, is found not to comply with the requirements specified for a protected REFRIGERATING SYSTEM, may be considered as having an unprotected REFRIGERATING SYSTEM if it is tested in accordance with 11.7.101.5 and found to comply with the requirement for an unprotected REFRIGERATING SYSTEM.

Compliance is checked by inspection and by the tests of 11.7.101.3 and 11.7.101.4

11.7.101.3 Leakage test for FLAMMABLE REFRIGERANT

Critical points are only considered to be the interconnecting joints between parts of the REFRIGERANT circuit, including the gasket of a semi-hermetic MOTOR-COMPRESSOR. Welded telescopic joints of the MOTOR-COMPRESSOR, the welding of the pipes through the compressor housing and the welding of the fusite are not considered critical points.

To find the most critical point of the REFRIGERATING SYSTEM, it ~~may~~ can be necessary to perform more than one test.

The method for simulating a leakage is to inject the REFRIGERANT vapour through a capillary tube at the critical point. The capillary tube shall have a bore of 0,7 mm $\pm$ 0,05 mm and a length between 2 m and 3 m.

Care should be taken that the installation of the capillary tube does not unduly influence the results of the test and that foreign material does not enter the capillary tube during insulation or assembly for the test. The capillary tube may need to be positioned before the equipment is insulated.

During this test the equipment is tested with doors and lids closed, and is switched off or operated under NORMAL CONDITION at RATED voltage, whichever gives the more unfavourable result.

During a test in which the equipment is operated, gas injection is started at the same time as the equipment is first switched on.

The quantity of REFRIGERANT of the type indicated by the manufacturer to be injected is equal to 80 % of the nominal charge of the REFRIGERANT $\pm$ 1,5 g or the maximum that can be injected in 1 h, whichever is the smaller.

The quantity injected is taken from the vapour side of a gas bottle which shall contain enough liquid REFRIGERANT to ensure that, at the end of the test, there is still liquid REFRIGERANT left in the bottle.

If a REFRIGERANT blend can fractionate, the test is performed using the fraction that has the smallest value of the LOWER EXPLOSIVE LIMIT.

The gas bottle is kept at a temperature of:

- a) 32 °C $\pm$ 2 °C for leakage simulation on the LOW-PRESSURE SIDE;
- b) 70 °C $\pm$ 2 °C for leakage simulation on the HIGH-PRESSURE SIDE.

The quantity of gas injected should preferably be measured by weighing the bottle.

The concentration of leaked REFRIGERANT is measured at least every 30 s from the beginning of the test and for at least 1 h after injection of the gas has stopped, inside and outside OPERATOR ACCESSIBLE areas, as close as possible to the electrical components which, during NORMAL USE or abnormal operation, produce sparks or arcs.

The concentration is not measured close to:

- non-self-resetting protective devices necessary for compliance with single fault testing under 4.4 even if they produce arcs or sparks during operation;
- intentionally weak parts that become permanently open-circuited during the single fault testing under 4.4 even if they produce arcs or sparks during operation;
- an electrical device that has been tested and found to comply with at least the requirements in Annex EE.

The instrument used for monitoring gas concentrations (such as those which use infrared sensing techniques) should have a fast response, typically 2 s to 3 s and not unduly influence the result of the test.

If gas chromatography is to be used, the gas sampling in the confined areas should occur at a rate not exceeding 2 ml every 30 s.

Other instruments are not precluded from being used provided that they do not unduly influence the results.

The measured value shall not exceed 75 % of the LOWER EXPLOSIVE LIMIT of the REFRIGERANT as specified in Table 104, and shall not exceed 50 % of the LOWER EXPLOSIVE LIMIT of the REFRIGERANT as specified in Table 104 for a period exceeding 5 min.

Substitution of an inert gas for leak test purposes is permitted if it can be demonstrated that the molecular mass of an inert gas matches that of the FLAMMABLE REFRIGERANT in question.

11.7.101.4 Scratch test for protected REFRIGERATING SYSTEMS

All ACCESSIBLE surfaces of protected REFRIGERATING SYSTEMS, including ACCESSIBLE surfaces in intimate contact with the protected REFRIGERATING SYSTEMS, are scratched using the TOOL, the tip of which is shown in Figure 103.

The TOOL is applied using the following parameters:


- force at right angles to the surface to be tested 35 N $\pm$ 3 N;
- force parallel to the surface to be tested not exceeding 250 N.

The TOOL is drawn across the surface to be tested at a rate of approximately 1 mm/s.

The surface to be tested is scratched at three different positions in a direction at right angles to the axis of the channel and at three different positions on the channel in a direction parallel to it. In the latter case, the length of the scratch shall be approximately 50 mm.

The scratches shall not cross each other.

The appropriate parts of the REFRIGERATING SYSTEM shall withstand the test of 11.7.2.101 with the test pressure reduced by 50 %.

**Key**

- A Hard-soldered carbide tip K10
- B Direction of movement

Figure 103 – Details of scratching TOOL tip**11.7.101.5 Unprotected REFRIGERATING SYSTEMS**

Equipment with an unprotected REFRIGERATING SYSTEM is that where at least one part of the REFRIGERATING SYSTEM is placed inside an OPERATOR ACCESSIBLE compartment or that which does not comply with 11.7.101.2.

For equipment with an unprotected REFRIGERATING SYSTEM and which uses a FLAMMABLE REFRIGERANT, any electrical component located inside the OPERATOR ACCESSIBLE compartment, which during NORMAL CONDITION or SINGLE FAULT CONDITION produces arcs or sparks, and luminaries, shall be tested and found at ~~least~~ a minimum to comply with the requirements of Annex EE for group IIA gases or for the REFRIGERANT used.

This requirement does not apply to:

- non-self-resetting protective devices necessary for compliance with 4.4; nor to
- intentionally weak parts that become permanently open-circuited during the tests of 4.4, even if they produce arcs or sparks during operation.

REFRIGERANT leakage into OPERATOR ACCESSIBLE compartments shall not result in an EXPLOSIVE GAS ATMOSPHERE outside the OPERATOR ACCESSIBLE compartments in areas where electrical components that produce arcs and sparks during NORMAL USE or abnormal operation, or luminaries, are mounted, when doors or lids remain closed or when opening or closing doors or lids, unless these components have been tested and found at ~~least~~ a minimum to comply with Annex EE for group IIA gases or for the REFRIGERANT used.

This requirement does not apply to:

- non-self-resetting protective devices necessary for compliance with 4.4; nor to
- intentionally weak parts that become permanently open-circuited during the tests of 4.4, even if they produce arcs or sparks during operation.

Separate components such as thermostats which contain less than 0,5 g of flammable gas are not considered to cause a fire or explosion HAZARD in the event of a leakage from the component itself.

Other types of protection for electrical devices for potentially EXPLOSIVE GAS ATMOSPHERES covered by IEC 60079 (all parts) are also acceptable.

Changing of a lamp is not considered a potential explosion HAZARD, because the door or lid is open during this operation.

Compliance is checked by inspection, by the appropriate tests of IEC 60079-15:2010 and by the following test.

The tests contained in Annex EE may be carried out using the stoichiometric concentration of the REFRIGERANT used. However, a device which has been independently tested and found to comply with Annex EE using the gas specified for group IIA need not be tested.

Irrespective of the requirements given in IEC 60079-15:2010, Clause 5, surface temperature limits are specified in 11.7.101.7.

The test is performed in a draught-free location with the equipment switched off or operated under conditions of NORMAL USE at RATED voltage, whichever gives the more unfavourable result.

During a test in which the equipment is operated, gas injection is started at the same time as the equipment is first switched on.

The test is performed twice and is repeated a third time if one of the first tests gives more than 40 % of the LOWER EXPLOSIVE LIMIT.

Through an appropriate orifice, 80 % of the nominal REFRIGERANT charge $\pm 1,5$ g, in the vapour state, is injected into an OPERATOR ACCESSIBLE compartment in a time not exceeding 10 min. The orifice is then closed. The injection shall be as close as possible to the centre of the back wall of the compartment at a distance from the top of the compartment approximately equal to one-third of the height of the compartment. Thirty minutes after the injection is completed, the door or lid is opened at a uniform rate in a time between 2 s and 4 s, to an angle of 90° or to the maximum possible, whichever is less.

For equipment having more than one door or lid, the most unfavourable sequence or combination of opening the lids or doors is used.

For equipment fitted with fan motors, the test is performed with the most unfavourable combination of motor operation.

The concentration of leaked REFRIGERANT is measured every 30 s from the beginning of the test, at positions as close as possible to the electrical components. However, it is not measured at the ~~positions~~ locations of:

- non-self-resetting protective devices necessary for compliance with 4.4; nor ~~to~~ at
- intentionally weak parts that become permanently open-circuited during the tests of 4.4, even if they produce arcs or sparks during operation.

The concentration values are recorded until they tend to go down.

The measured value shall not exceed 75 % of the LOWER EXPLOSIVE LIMIT of the REFRIGERANT as specified in Table 104, and shall not exceed 50 % of the LOWER EXPLOSIVE LIMIT of the REFRIGERANT as specified in Table 104 for a period exceeding 5 min.

The above test is repeated, except that the door or lid is subjected to an open/close sequence at a uniform rate in a time of between 2 s and 4 s, the door or lid being opened to an angle of 90° or to the maximum possible, whichever is less, and closed during the sequence.

11.7.101.6 Stagnation of leaked FLAMMABLE REFRIGERANT

Equipment which uses FLAMMABLE REFRIGERANT shall be constructed so that leaked REFRIGERANT will not stagnate and thus cause a fire or explosion HAZARD in areas outside the OPERATOR ACCESSIBLE compartment where components producing arcs or sparks or luminaires are mounted.

This requirement does not apply to areas where:

- non-self-resetting protective devices necessary for compliance with 4.4; or
- intentionally weak parts that become permanently open-circuited during the test of 4.4

are mounted, even if they produce arcs and sparks during operation.

Separate components such as thermostats that contain less than 0,5 g of flammable gas are not considered to cause a fire or explosion HAZARD in the event of a leakage of the component itself.

Compliance is checked by the following test, unless luminaires and components that produce arcs and sparks during NORMAL USE and which are mounted in the areas under consideration, have been tested and found ~~at least~~ to comply at a minimum with the requirements in Annex EE for group IIA gases or for the REFRIGERANT used.

Irrespective of the requirements given in IEC 60079-15:2010, Clause 5, the surface temperature limits are specified in 11.7.101.7.

Other types of protection for electrical devices for potentially EXPLOSIVE GAS ATMOSPHERES covered by IEC 60079 (all parts) are also acceptable.

The test is performed in a draught-free location with the appliance switched off or operated under NORMAL USE at RATED voltage, whichever gives the more unfavourable result when an ignition source is present.

During a test in which the equipment is operated, gas injection is started at the same time as the equipment is first switched on.

A quantity equal to 50 % of the REFRIGERANT charge $\pm 1,5$ g is injected into the considered area.

Injection is to be at a constant rate over a period of 1 h and is to be at the point of closest approach of:

- pipe-work joints in external parts of the refrigerating circuit,
- the gaskets of semi-hermetic MOTOR-COMPRESSORS,

to the electrical component under consideration. Any direct injection shall be avoided.

Welded telescopic joints of the MOTOR-COMPRESSOR, the welding of the pipes through the compressor housing and the welding of the fusite are not considered to be pipework joints.

The concentration of leaked REFRIGERANT as close as possible to the electrical component is measured continuously from the beginning of the test until it starts to decrease.

The measured value shall not exceed 75 % of the LOWER EXPLOSIVE LIMIT of the REFRIGERANT as specified in Table 104, and shall not exceed 50 % of the LOWER EXPLOSIVE LIMIT of the REFRIGERANT as specified in Table 104 for a period exceeding 5 min.

11.7.101.7 Surface temperature limits

Temperatures on surfaces that ~~may~~ can be exposed to leakage of FLAMMABLE REFRIGERANT shall not exceed the AUTO IGNITION TEMPERATURE of the REFRIGERANT as specified in Table 104, reduced by 100 K.

Compliance is checked by measuring the appropriate surface temperatures during the tests specified in 4.4 and Clause 10.

Temperatures of

- *non-self-resetting protective devices that operate during the tests specified in 4.4; or*
- *intentionally weak parts that become permanently open-circuited during the tests specified in 4.4*

are not measured during those tests specified in 4.4 that cause these devices to operate.

Table 104 – REFRIGERANT flammability parameters

REFRIGERANT number	REFRIGERANT name	REFRIGERANT formula	REFRIGERANT AUTO IGNITION TEMPERATURE ^{a,c} °C	REFRIGERANT LOWER EXPLOSIVE LIMIT ^{b,c,d,e} % V/V
R50	Methane	CH ₄	645	4,9
R170	Ethane	CH ₃ CH ₃	515	3,1
R290	Propane	CH ₃ CH ₂ CH ₃	470	1,7
R600	n-Butane	CH ₃ CH ₂ CH ₂ CH ₃	365	1,5
R600a	Isobutane	CH(CH ₃) ₃	494 460	1,8
R1150	Ethene	CH ₂ =CH ₂	425	3,1
R1270	Propylene	CH ₂ =CHCH ₃	455	2,3

^a Values for other FLAMMABLE REFRIGERANTS ~~can~~ shall be obtained from ~~IEC 60079-20 and~~ IEC 60079-20-1.

^b Values for other FLAMMABLE REFRIGERANTS ~~can~~ shall be obtained from IEC 60079-20-1 and ISO 5149-1.

^c IEC 60079-20-1 is the reference standard. ISO 5149-1 may be used if the required data is not contained in IEC 60079-20-1.

^d Concentration of REFRIGERANT in dry air.

^e In some standards, the term "flammability limit" is used for "LOWER EXPLOSIVE LIMIT".

11.7.102 Temperature test for storage and transport

11.7.102.1 General

Pressures developed from SOAKED TEMPERATURE CONDITIONS resulting from the temperatures the REFRIGERATING SYSTEM is exposed to during storage and/or transport shall not cause a HAZARD.

These pressures are used as one input for determining the PS (11.7.1) and are derived by the test below or from the REFRIGERANT SATURATED-VAPOUR PRESSURES at a storage and/or transport ambient temperature of 55 °C for NORMAL CONDITION or 70 °C for storage and/or transport under tropical conditions.

For pressures in parts protected by a PRESSURE-RELIEF DEVICE, the test pressure shall not exceed 0,9 times the setting of that device during storage and/or transport.

For refrigerating equipment that uses FLAMMABLE REFRIGERANT, the storage and/or transport ambient temperature shall be 70 °C.

Conformity is checked by inspection of the RATINGS of the components exposed to this pressure and, if a HAZARD could arise, by the tests of 11.7.2.

If there is any doubt as to the SATURATED-VAPOUR PRESSURE of the REFRIGERANT in use, then the test pressure shall be derived by one of the following test methods: 11.7.102.2 or 11.7.102.3, or the calculation of 11.7.102.4.

11.7.102.2 Test of charge-to-volume ratio

The steps for the test of charge-to-volume ratio are as follows:

- a) *calculate the total volume of the REFRIGERATING SYSTEM in question;*
- b) *calculate the charge-to-volume ratio for the design charge;*
- c) *take a charging cylinder of known volume and charge it to give the same volume-to-mass ratio as the system to be simulated;*
- d) *place the cylinder with a pressure gauge or transducer in a controlled ambient environment defined by the storage and/or transport ambient temperature and allow the cylinder to soak;*
- e) *record the maximum pressure and use this value as the test pressure for the REFRIGERATING SYSTEM.*

11.7.102.3 Test by pressure under the SOAKED TEMPERATURE CONDITION

The steps for test by pressure under the SOAKED TEMPERATURE CONDITION are as follows:

- a) *measure the pressure of the REFRIGERATING SYSTEM under the SOAKED TEMPERATURE CONDITION;*
- b) *use an evacuated cylinder and heat it up to the SOAKED TEMPERATURE CONDITION;*
- c) *charge the cylinder with the same REFRIGERANT used in the REFRIGERATING SYSTEM under the SOAKED TEMPERATURE CONDITION until it has the same pressure as the REFRIGERATING SYSTEM in the SOAKED TEMPERATURE CONDITION;*
- d) *place the cylinder with a pressure gauge or transducer in a controlled ambient environment defined by the storage and/or transport ambient temperature and allow the cylinder to soak;*
- e) *record the maximum pressure and use this value as the test pressure for the REFRIGERATING SYSTEM.*

11.7.102.4 Calculation by using the ideal gas law

FLAMMABLE REFRIGERANTS are assumed to be ideal gases. Calculate the pressure at transport and storage conditions by using the ideal gas law, based on the pressure and temperature in the SOAKED TEMPERATURE CONDITION.

11.7.103 Internal fluid leaks

Where, in a SINGLE FAULT CONDITION, fluid can leak within the equipment, this shall not cause a HAZARD.

Fluid-containing parts meeting the construction requirements of IEC 60079-15:2010 can be assumed not to leak. Other fluid-containing parts and seals shall be assumed to leak.

In particular, leaked FLAMMABLE LIQUID shall not come into contact with any ignition sources. Equipment containing no spark-generating parts (see Annex EE) and where no surface temperature exceeds $t_a - 100$ K (see 9.5 a) and 11.7.101.7), where t_a is the AUTO IGNITION TEMPERATURE of the liquid, is considered to meet this requirement.

Conformity is checked by inspection, by performing the tests of 4.4.2.102 and 10.4.

12 Protection against radiation, including laser sources, and against sonic and ultrasonic pressure

This clause of Part 1 is applicable except as follows:

12.1 General

Replacement:

Replace the text with the following:

The equipment shall provide protection against the effects of internally generated optical, ultraviolet, ionizing and microwave radiation as well as laser sources, and sonic and ultrasonic pressure.

Conformity tests are carried out if the equipment is likely to cause such HAZARDS.

12.2.1.3 Equipment not intended to emit radiation

Addition:

Add the following paragraph and Note 101 after the conformity statement:

The equipment intended for application to radioactive substances, for example chemicals in a jacketed reactor, or a plant, seed or insect treated with radioactive chemicals, shall be isolated to provide protection against transmission of ionizing radiation, and the operation of the equipment shall be strictly supervised to follow the rules and regulations for radiation laboratories to reduce the amount of ionizing radiation to an acceptable level (see also 5.4.4.101). The RESPONSIBLE BODY or the OPERATOR shall apply the symbol 17 of Table 1 with the signature of the OPERATOR. ~~At least,~~ The symbol shall at the minimum be in close proximity to where the SPECIMEN is kept and easily visible for NORMAL USE.

NOTE 101 Examples of such equipment include the BATH, CIRCULATOR and climatic TEST CHAMBER for biological applications, etc.

Conformity is checked by inspection.

~~12.3 Ultraviolet (UV) radiation~~

Replacement:

Replace the title and text in 12.3 with the following:

12.3 Optical radiation

Addition:

Add the following text after the first paragraph:

~~Equipment with lamp and lamp systems emitting ultraviolet, visible, or infrared radiation, including light emitting diodes, shall not expose the OPERATOR or environment to radiation that could cause a HAZARD.~~

Where the exposure to hazardous radiation is inevitable for functional reasons, the equipment shall incorporate protective measures to limit exposure to a safe level. Equipment incorporating a lamp and lamp systems that can produce hazardous effects shall be marked with symbol 104 to warn of optical radiation, with symbol 13 to warn of a burn HAZARD, or with symbol 14 to warning of other HAZARDS, as applicable.

~~Information on protective measures, restrictions on use and operating instructions that may be necessary shall be provided, including the applicable conditions of use of Table 106.~~

~~The radiation sources shall be assessed in accordance with IEC 62471 except for sources considered to be safe (Table 105), or conditionally safe (Table 106). Lamp and lamp systems assessed to be in Risk Groups 1, 2 or 3 of IEC 62471 shall be labeled in accordance with IEC TR 62471-2.~~

~~NOTE Additional guidelines or requirements may be specified by national or other authorities.~~

~~Conformity is checked by inspection, by review of the technical specifications of the lamp manufacturer, and if necessary by measurement of the optical radiation, followed by determination of the applicable risk groups according to IEC 62471.~~

~~Table 105 – Lamp or lamp systems considered photobiologically safe~~

~~Lamp or lamp system~~
~~Indicator LED's~~
~~Personal digital device screens~~
~~LCD screens~~
~~Computer displays~~
~~Photographic flash lamps~~
~~Interactive whiteboard presentation equipment~~
~~Task lighting with tungsten filament lamps, compact fluorescent tubes, or fluorescent tubes with diffusers~~

Table 106 – ~~Lamp or lamp systems considered photobiologically safe under certain conditions~~

Lamp or lamp system	Conditions of use
~~Fluorescent lighting without diffusers over the lamps~~	<del>Safe at normal illumination levels (~600 lux)</del>
~~Metal halide/high-pressure mercury flood lights~~	~~Safe if the front cover glass is intact and if the lamp is not in line of sight~~
~~Desktop projectors~~	~~Safe if the beam is not looked into~~
~~Low-pressure UVA black lights~~	~~Safe if not in line of sight and hands are not irradiated while holding the black light~~
~~Any Class 1 Laser (to IEC 60825-1)~~	~~Safe if covers intact. May be unsafe if covers removed.~~
~~Any 'Exempt Group' equipment (to IEC 62471)~~	~~Safe if not in line of sight. May be unsafe if covers removed.~~

13 Protection against liberated gases and substances, explosion and implosion

This clause of Part 1 is applicable except as follows:

13.1 Poisonous and injurious gases and substances

Addition:

Add a new sentence at the end of the first paragraph.

For example, the high temperature decomposition products of the oil HEAT TRANSFER MEDIUM.

13.2.1 Components

Replacement:

Replace the title and text in 13.2.1 with the following:

13.2.1 Components of the equipment and materials being treated

If components liable to explode are not provided with a PRESSURE-RELIEF DEVICE, or if the equipment is intended to treat materials in such a way that explosion or implosion ~~may~~ can occur, protection for the OPERATOR shall be incorporated with the equipment (see 7.7) or otherwise personal protective measures shall be included in the OPERATOR instructions. PRESSURE-RELIEF DEVICES shall be located so that a discharge will not cause HAZARD to the OPERATOR. The construction shall be such that the PRESSURE-RELIEF DEVICE cannot be obstructed.

Addition:

Add the following new subclauses:

13.2.101 Implosion of low air pressure equipment

A low air pressure TEST CHAMBER or vacuum oven, ~~etc.~~ shall be incorporated with protection for the OPERATOR and the surroundings against the effects of implosion.

Conformity is checked by inspection of the equipment and of the design information and, in case of doubt, by provoking an implosion.

13.2.102 Explosion and implosion of lamps

The lamps or lamp systems shall be incorporated and constructed to provide protection against explosion and implosion, whether for normal operation or for maintenance, under mechanical and thermal stresses resulting from shaking, vibrating, thermal shocking over the ~~operating~~ CONTROLLED TEMPERATURE range, or unexpected contact with a cold liquid.

Lamps liable to explode or implode when vibrated, shaken, heated, cooled or thermal shocked over ~~operating~~ the CONTROLLED TEMPERATURE range and, where a HAZARD could arise when ruptured, shall be protected with an explosion-proof transparent shield which is ACCESSIBLE only with the aid of a TOOL. If glass is used, it shall not ~~get~~ be in contact with the surface of the lamps and it shall be subjected to the tests of 8.2, and meet the pass criteria of 8.1 of this document.

Conformity is checked by inspection.

Addition:

Add the following new subclauses:

13.101 Biohazardous substances

Equipment that can be potentially infectious, whether from the SPECIMEN itself or as a result of treatment with biohazardous agents or formulations, shall be prominently marked with symbol 103 of Table 1. At a minimum, the symbol shall be in close proximity to where the SPECIMEN or biohazardous substance is kept and easily visible during NORMAL USE.

Symbol 103 shall be placed near any biohazardous area ACCESSIBLE during OPERATOR maintenance and visible only during this maintenance.

Where applicable, symbol 103 shall also be attached to disposal bags or containers for biologically hazardous materials removed from the equipment, and to any LIQUID CONNECTIONS or exhaust openings where the liberation of biohazardous substances ~~may~~ can occur during NORMAL USE.

Equipment that can be hazardous due to the use of hazardous substances shall be marked with an appropriate international symbol, or (if none is available) symbol 14 of Table 1.

See also 5.4.3 c) for details of instructions relating to ventilation requirements.

NOTE Local, national or regional regulations concerning the collection or discharge of biohazardous material can apply.

Conformity is checked by inspection.

13.102 Warning requirements related to chemical HAZARD

Equipment intended for chemical applications, such as BATHS, CIRCULATORS, SHAKERS, climatic TEST CHAMBERS and salt spray corrosion TEST CHAMBERS, and which could present chemical HAZARDS to the OPERATOR and the environment, shall be marked with a symbol or text suitable to the chemical HAZARD. The symbol shall be in close proximity to where the SPECIMEN is kept and easily visible during NORMAL USE. Where applicable, the symbol or text shall also be attached to glassware such as flasks for shaking or immersion applications, APPLICATION SYSTEMS such as jacketed reactors containing hazardous chemicals, or LIQUID CONNECTIONS and exhaust openings where liberating of chemical contaminants ~~may~~ can occur during NORMAL USE.

See also 5.4.3 c) for details of instructions relating to ventilation requirements.

NOTE Examples of chemical HAZARDS presented by these types of equipment are salt mist, salt solutions, SPECIMENS treated with salt spray, pest insects, microorganisms or plants treated with pesticides, radioactive substances and chemical mixtures.

Symbol 102 of Table 1 is used for warnings pertaining to flammable materials. Symbols for other chemical HAZARDS may be selected from ISO 7010, as follows:

- a) for explosive materials, W002:2011-05
- b) for radioactive materials, W003:2011-05
- c) for toxic materials, W016:2011-05
- d) for corrosive materials, W023:2011-05
- e) for oxidizing substances, W028:2011-05
- f) for other chemical HAZARDS, other appropriate symbols from ISO 7010.

If there is no appropriate symbol for the particular chemical HAZARD, symbol 14 of Table 1 shall be used and additional explanations of the chemical HAZARD shall be included in the documentation.

Conformity is checked by inspection.

14 Components and subassemblies

This clause of Part 1 is applicable except as follows:

14.3 Overtemperature protection devices

Replacement:

Replace the text by the following:

TEMPERATURE-LIMITING DEVICES and systems for overtemperature protection designed to operate in SINGLE FAULT CONDITION shall meet all of the following requirements:

- a) be constructed and tested to ensure reliable function. Devices of the capillary type shall be so designed that the protection is kept complete in the event of leakage from the capillary tube;
- b) be RATED to interrupt the maximum voltage and current of the circuit in which they are employed;
- c) do not operate in NORMAL USE.

LIQUID LEVEL CUT OUTS used to protect against overtemperature shall meet the same requirements as TEMPERATURE-LIMITING DEVICES and systems.

Conformity is checked by studying the operating principle of the device or system or by fracturing the capillary tube and by performing adequate reliability tests with the equipment operated in SINGLE FAULT CONDITION. Ensure that the capillary tube is not obstructed when it is being fractured.

The number of operations is as follows:

- 1) *non-resetting devices are caused to operate once;*
- 2) *non-self-resetting devices and systems, except thermal fuses, are reset after each operation and thus caused to operate 10 times;*
- 3) *self-resetting devices are caused to operate 200 times.*

NOTE Forced cooling and resting periods can be introduced to prevent damage to the equipment.

During the test, resetting devices shall operate each time the SINGLE FAULT CONDITION is applied and non-resetting devices shall operate once to provide the expected protection. After the test, the resetting devices shall show no sign of damage which could prevent their operation in a further SINGLE FAULT CONDITION.

Addition:

Add the following new subclauses:

14.101 Components and subassemblies for REFRIGERATING SYSTEMS

Components and piping that are part of the REFRIGERATING SYSTEM shall comply with the related standards or requirements as indicated in Annex CC or be evaluated according to the pressure RATING requirements of this document (see 11.7.2).

Conformity is checked by inspection or as specified in 11.7.2, as applicable.

14.102 Flexible tubing and hose subjected to liquid pressure other than that of the REFRIGERANT

Flexible tubing and hose subjected to the RATED PRESSURE of the equipment shall be of sufficient mechanical strength.

The construction and materials of the flexible tubing and hose, including fittings and thermal insulation for subassemblies if any, shall withstand mechanical, chemical and thermal stresses encountered for NORMAL USE.

Conformity is checked by the following tests and, in case of doubt, by tests repeated at RATED PRESSURE and temperature:

The high pressure flexible tubing and hose for liquid circulating shall be subjected to a static pressure test of four times the RATED PRESSURE at ~~room~~ ambient temperature and under the maximum ~~operating~~ CONTROLLED TEMPERATURE range of the intended application, whereby the test pressure shall be reached between 15 s and 30 s after starting at zero pressure.

NOTE The PRESSURE-RELIEF DEVICE and/or alternative sensing devices can be rendered inoperative in this test.

The flexible tubing and hose used for water supply, if any, shall be subjected to a static pressure test of two times the maximum inlet pressure for 5 min at ~~room~~ ambient temperature.

During the test there shall be no leakage or rupture.

15 Protection by interlocks

This clause of Part 1 is applicable except as follows:

15.1 General

Replacement:

Replace the text with the following:

Interlocks used to protect OPERATORS from HAZARDS shall prevent an OPERATOR from being exposed to the HAZARD before the HAZARD is removed and shall meet the requirements of 15.2, 15.3 and 15.101 to 15.104 as applicable.

Conformity is checked by inspection and by performing all the relevant tests of this document.

Addition:

Add the following new subclauses:

15.101 Mechanism of door and/or lock for WALK-IN EQUIPMENT

It shall be possible to escape from the WALK-IN EQUIPMENT at all times.

The door for WALK-IN EQUIPMENT shall be so designed and constructed that its opening is possible both from the outside and from within the equipment, with the priority assigned to the unlocking and opening from within the equipment.

NOTE 1 A separate door or exit independent of the main entrance which is locked and opened from outside the equipment, when ACCESSIBLE only from within the equipment and when open to the outside, is considered to meet this requirement.

NOTE 2 Additional requirements for WALK-IN EQUIPMENT can apply in accordance with Annex BB.

When the door is closed and/or locked from within the equipment, there shall be an illuminated indication in proximity to the controller outside the equipment, which reads: "equipment in operation, OPERATOR inside the room!" The indication shall be interlocked to one or more of the following settings ACCESSIBLE from outside:

- 1) the maximum ~~operating~~ CONTROLLED TEMPERATURE not exceeding: +40 °C
- 2) the minimum ~~operating~~ CONTROLLED TEMPERATURE not exceeding: –30 °C
- 3) start the VENTILATOR or any other similar devices;
- 4) disable the initiation of vacuum pump or any evacuating system;
- 5) limit the number of lamps or the light emitting intensity in accordance with 12.3 and/or warn the OPERATOR of the HAZARD and the necessity for protective eyewear if hazardous optical radiation exists.

Conformity is checked by inspection of the documentation and in accordance with 15.2 and 15.3.

15.102 Interlock between the CIRCULATING PUMP, agitator and heating, cooling, MECHANICAL MOVEMENT and/or operation of the APPLICATION SYSTEM

The RESISTANCE-HEATING DEVICE and/or MOTOR-COMPRESSOR of the BATH and CIRCULATOR shall be interlocked with the CIRCULATING PUMP, agitator and, where applicable, the APPLICATION SYSTEM, if HAZARDS could arise due to one or more of the following:

- the ~~operating~~ CONTROLLED TEMPERATURE of the equipment deviates from its setting to some extent, resulting in overheating or deep cooling of the SPECIMEN or APPLICATION SYSTEM;
- localized overheating or deep cooling of the liquid HEAT TRANSFER MEDIUM occurs as a result of the termination of the CIRCULATING PUMP or agitator;
- obstruction or leakage of the external liquid circulating occurs between the equipment and the APPLICATION SYSTEM.

Depending on the related HAZARD, the RESISTANCE-HEATING DEVICE or the MOTOR-COMPRESSOR, or both, shall be de-energized if the CIRCULATING PUMP and/or agitator is interrupted and if the CONTROLLED TEMPERATURE deviates from its setting to some extent, and the operation of the APPLICATION SYSTEM shall be controlled to prevent the developing of the HAZARD.

NOTE Whether the RESISTANCE-HEATING DEVICE or the MOTOR-COMPRESSOR alone, or both, ~~shall be~~ are de-energized depends on the related HAZARD. It is advantageous to provide the equipment with means such that either or both of these could be interlocked and available to the OPERATOR with additional instructions for the configuration of the function.

Conformity is checked by inspection and by operating the interlocks as specified in the documentation and in accordance with 15.2 and 15.3.

15.103 Interlock between CIRCULATING FAN, door or lid and heating, cooling and/or radiation, humidifying and MECHANICAL MOVEMENT

The RESISTANCE-HEATING DEVICE and/or MOTOR-COMPRESSOR and, where applicable, the radiation, humidifying, MECHANICAL MOVEMENT, shall be interlocked with the CIRCULATING FAN if HAZARDS could arise due to one or more of the following:

- the ~~operating~~ CONTROLLED TEMPERATURE of the equipment deviates from its setting to some extent, resulting in overheating or deep cooling of the SPECIMEN;
- where the RESISTANCE-HEATING DEVICE and/or EVAPORATOR are located, localized overheating and/or deep cooling occur(s) resulting from the termination of the CIRCULATING FAN;
- with the door or lid open, continuous heating and/or cooling, and humidifying ~~may happen~~ can occur if the settings ~~are away~~ deviate from the ambient temperature and humidity;
- with the door or lid open, the OPERATOR or the surroundings ~~may~~ can be exposed to excessive optical radiation or any other hazardous radiation;
- with the door or lid open, the OPERATOR ~~may~~ can be exposed to mechanical HAZARD if MECHANICAL MOVEMENT continues.

Depending on the related HAZARD, the RESISTANCE-HEATING DEVICE or the MOTOR-COMPRESSOR, or both, shall be de-energized if the CIRCULATING FAN is interrupted and if the CONTROLLED TEMPERATURE deviates from its setting to some extent. The CIRCULATING FAN shall be switched off while or some time after the door or lid is opened, while the HUMIDIFIER, lamp or lamp systems (see 12.3) and MECHANICAL MOVEMENT shall be terminated or reduced to a safe level with the door or lid opened.

NOTE Whether the RESISTANCE-HEATING DEVICE or the MOTOR-COMPRESSOR alone or both ~~shall be~~ are de-energized depends on the related HAZARD. It is advantageous to provide the equipment with means that either or both of them could be interlocked and available to the OPERATOR with additional instructions for the configuration of the function.

Conformity is checked by inspection and by operating the interlocks as specified in the documentation and, in accordance with 15.2 and 15.3.

15.104 Interlock between salt spray and cover of salt spray corrosion TEST CHAMBER

The mechanism of the cover for the salt spray corrosion TEST CHAMBER shall meet the requirements specified in 11.4.101 of this document. The activation of the saturated compressed-air for salt solution atomizing shall be interlocked by the mechanism of the cover.

Conformity is checked by inspection and by operating the interlocks as specified in the documentation and in accordance with 15.2 and 15.3.

16 HAZARDS resulting from application

This clause of Part 1 is applicable except as follows.

16.1 REASONABLY FORESEEABLE MISUSE

Replacement:

Replace the text as follows:

The equipment shall comply with the requirements of this document during NORMAL USE, including mistakes, lapses, slips or use of an equipment or system in a way not intended by

the manufacturer, but which can result from readily predictable human behaviour. Such acts to consider would include well-meant optimization or readily available shortcuts.

No HAZARD shall arise in NORMAL USE or SINGLE FAULT CONDITION, through readily available adjustments, knobs, or other software-based or hardware-based controls are set in a way not intended, or not described in the instructions.

Reckless use, unqualified use or use outside the specifications—~~specified~~ ~~set~~ by the manufacturer is not considered as part of this document. Similarly, intended acts or intended omissions of an act by the OPERATOR of the equipment as a result of conduct that is beyond any reasonable means of RISK control by the manufacturer are similarly excluded from the scope of this document.

Other possible cases of REASONABLY FORESEEABLE MISUSE that are not addressed by specific requirements in this document shall be addressed by the RISK assessment (see Clause 17).

Addition:

Add the following new subclause:

16.101 Slip HAZARD

For WALK-IN EQUIPMENT (see Annex BB), where the ground or floor ~~may~~ ~~can~~ be slippery when wet or icy, the equipment shall be designed and constructed in such a way as to minimize the RISK of slipping. Where a slip HAZARD remains, appropriate means including personal protective measures which enable the OPERATOR to maintain their stability and safety shall be ~~fitted~~ ~~provided~~ (for example handholds that are fixed relative to the OPERATOR) and the equipment shall be permanently marked with symbol 105 of Table 1, warning of slippery surface and against the HAZARD of falling. The symbol shall be placed on the door or on the inside wall of the equipment, where it is clearly visible for the OPERATOR during NORMAL USE.

Conformity is checked by inspection.

17 Risk assessment

This clause of Part 1 is applicable.

Annexes

The annexes of Part 1 are applicable except as follows:

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV

Annex K (normative)

Insulation requirements not covered by 6.7

K.1.3 Solid insulation for MAINS CIRCUITS

K.1.3.1 General

Addition:

Add the following paragraph after Note 1:

If the performance of the equipment requires the use of a hygroscopic insulated RESISTANCE-HEATING DEVICE, it is permissible for equipment to require a period of operation to dry out the insulation before meeting the requirements of 6.3.1 and 6.8.3, provided that the OPERATOR is made aware of this (see 5.4.3.101).

Addition:

Add the following paragraph after the conformity statement:

If a DRYING-OUT is specified, conformity is checked by performing the DRYING-OUT specified in the OPERATOR manual (see 5.4.3.101) before conducting the tests of a) and b) above.

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV

Annex L (informative)

Index of defined terms

Addition:

Add the following terms:

Term	Definition
ACC RANGE	3.5.104
ACTIVE COOLING CONTROL RANGE	3.5.104
APPLICATION SYSTEM	3.2.125
AUTO IGNITION TEMPERATURE	3.5.107
BATH	3.1.101
BATH TANK	3.2.113
CASCADE SYSTEM	3.2.103
CIRCULATING FAN	3.2.111
CIRCULATING PUMP	3.2.110
CIRCULATOR	3.1.102
COMBINED TEST CHAMBER	3.1.104
CONDENSER	3.2.105
CONDENSING UNIT	3.2.106
CONTROLLED TEMPERATURE	3.5.114
DRYING-OUT	3.1.108
EVAPORATOR	3.2.107
EXPLOSIVE GAS ATMOSPHERE	3.5.109
FIRE POINT	3.5.106
FLAMMABLE LIQUID	3.2.120
FLAMMABLE REFRIGERANT	3.2.123
FLASH POINT	3.5.105
HEAT TRANSFER MEDIUM	3.2.121
HIGH-PRESSURE SIDE	3.2.108
HUMIDIFIER	3.2.112
INCUBATOR	3.1.105
LIQUID CONNECTION	3.2.114
LIQUID LEVEL CUT OUT	3.2.117
LOW-PRESSURE SIDE	3.2.109
LOWER EXPLOSIVE LIMIT	3.2.108
MAXIMUM ALLOWABLE PRESSURE	3.5.102
MECHANICAL MOVEMENT	3.5.111
MOTOR-COMPRESSOR	3.2.104
MOVEMENT AMPLITUDE	3.5.113
MOVEMENT FREQUENCY	3.5.112
PRESSURE-LIMITING DEVICE	3.2.118

PRESSURE-RELIEF DEVICE	3.2.119
PS	3.5.102
RATED PRESSURE	3.5.103
REFRIGERANT	3.2.122
REFRIGERATING SYSTEM	3.2.102
RESISTANCE-HEATING DEVICE	3.2.101
SATURATED-VAPOUR PRESSURE (of REFRIGERANT)	3.5.101
SHAKER	3.1.106
SOAKED TEMPERATURE CONDITION	3.5.110
SPECIMEN	3.2.124
STANDSTILL	3.1.109
TEST CHAMBER	3.1.103
TEMPERATURE-LIMITING DEVICE	3.2.116
VENTILATOR	3.2.115
WALK-IN EQUIPMENT	3.1.107

Addition:

Add the following new annexes:

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV







Annex AA (informative)

Useful symbols

The symbols in Table AA.1 are useful for identification and documentation related to the safe operation of the equipment. These symbols may be used as specified in 5.1.5.101, 5.1.5.103, 5.4.101, 5.4.102, 7.3.5.1, 7.3.101, 10.1, 12.3, 13.101, 13.102 and 16.101.

Table AA.1 – Useful symbols

Number	Symbol	Reference	Description
107		~~ISO 7000 — 0880 (1989)~~ ^a	Use with a refrigerating BATH and CIRCULATOR with a liquid CIRCULATING PUMP and LIQUID CONNECTIONS for external circulating.
108		~~ISO 7000 — 0880 (1989)~~ ^a	LIQUID CONNECTION for a CIRCULATING PUMP outlet of the liquid HEAT TRANSFER MEDIUM (coolant only) in refrigerating CIRCULATORS. The minimum CONTROLLED TEMPERATURE of the liquid ~~may~~ can be accompanied with the symbol if it is lower than -30 °C. The maximum exit pressure ~~may~~ can also be marked if it is ~~either~~ higher than 0,03 MPa or 0,02 MPa with a flow rate of more than 10 l/min.
109		~~ISO 7000 — 0880 (1989)~~ ^a	LIQUID CONNECTION for return of the liquid HEAT TRANSFER MEDIUM (coolant only) in refrigerating CIRCULATORS. For an enclosed CIRCULATOR or CIRCULATOR equipped with suction CIRCULATING PUMP, and when the suction pressure is ~~lower~~ greater than 0,02 MPa, the minimum suction pressure ~~may~~ can be marked in association with the symbol.
110		~~ISO 7000 — 0880 (1989)~~ ^b	Use with refrigerating and heating BATH and CIRCULATOR with a liquid CIRCULATING PUMP and LIQUID CONNECTIONS for external circulating.
111		~~ISO 7000 — 0880 (1989)~~ ^b	LIQUID CONNECTION for a CIRCULATING PUMP outlet of the liquid HEAT TRANSFER MEDIUM (both heating and cooling) in refrigerating and heating CIRCULATORS. The maximum and/or minimum CONTROLLED TEMPERATURE(S) of the liquid ~~may~~ can be accompanied with the symbol if they are higher than +60 °C and/or lower than -30 °C. The maximum exit pressure ~~may~~ can also be marked if it is ~~either~~ higher than 0,03 MPa or 0,02 MPa with a flow rate of more than 10 l/min.
112		~~ISO 7000 — 0880 (1989)~~ ^b	LIQUID CONNECTION for return of the liquid HEAT TRANSFER MEDIUM (both heating and cooling) in refrigerating and heating CIRCULATORS. For an enclosed CIRCULATOR or CIRCULATOR equipped with a suction pump and when the suction pressure is ~~lower~~ greater than 0,02 MPa, the minimum suction pressure ~~may~~ can be marked in association with the symbol.

Number	Symbol	Reference	Description
113		ISO 7000-0794 (2004-01)	Input or entrance, for example, LIQUID CONNECTIONS for a water-cooled CONDENSER, water supply, salt solution, and connections for a steam source, compressed air, etc. The MAXIMUM ALLOWABLE PRESSURE (PS) in pascal, and the maximum and/or minimum temperatures in centigrade, ~~may~~ can be accompanied with the symbol where applicable.
114		ISO 7000-0795 (2004-01)	Output or exit, for example, LIQUID CONNECTION for water-cooled CONDENSER and connection for vacuum source, etc.
115		IEC 60417-5595 (2002-10)	Condensate collector
116		ISO 7000-0028 ~~(2015-06)~~ (2004-01)	Filling device
117		ISO 7000-0029 ~~(2016-06)~~ (2004-01)	Draining device
118		ISO 7000-0030 ~~(2016-06)~~ (2004-01)	Overflow device
119		~~ISO 7000 – 1604 (2015-06)~~ ~~ISO 7000 – 1605 (2015-06)~~ ^c	VENTILATOR
120		ISO 7000-1604 ~~(2015-06)~~ (2004-01)	Intake air
121		ISO 7000-1605 ~~(2015-06)~~ (2004-01)	Exhaust gas
122			Orbital movement, maximum MOVEMENT FREQUENCY and MOVEMENT AMPLITUDE ~~may~~ can be accompanied with the symbol where applicable.
123			Reciprocating movement, maximum MOVEMENT FREQUENCY and MOVEMENT AMPLITUDE ~~may~~ can be accompanied with the symbol where applicable.
124			Hand and wrist movement, maximum MOVEMENT FREQUENCY and MOVEMENT AMPLITUDE ~~may~~ can be accompanied with the symbol where applicable.

Number	Symbol	Reference	Description
125			Vortex movement, maximum MOVEMENT FREQUENCY ~~may~~ can be accompanied with the symbol where applicable.
126			Rocking movement, maximum MOVEMENT FREQUENCY and MOVEMENT AMPLITUDE may be accompanied with the symbol where applicable.
127			Rotating movement, maximum MOVEMENT FREQUENCY and MOVEMENT AMPLITUDE ~~may~~ can be accompanied with the symbol where applicable.
^a These symbols are created based on ISO 7000-0880 (1989) for circulating equipment with coolant pump. The big circle in connection with the coolant pump (ISO 7000-0355 ~~(2015-06)~~ (2004-01)) is cut into two parts, with one representing the outlet and the other the return of the liquid. An arrow is added to make it clear for identification of the liquid outlet or return. ^b These symbols are created based on symbols 107, 108 and 109, by removing the symbol for cooling (ISO 7000-0027 ~~(2015-06)~~ (2004-01)). ^c This symbol is created by combining the symbol for intake air (ISO 7000-1604 ~~(2015-06)~~ (2004-01)) and that for exhaust gas (ISO 7000-1605 ~~(2015-06)~~ (2004-01)). ~~In avoidance of being confused~~ To prevent any confusion, the combination is turned at an angle of 90°.			

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV

Annex BB (informative)

Protection ~~for~~ of people who are inside WALK-IN EQUIPMENT

BB.1 General

In order to minimize the HAZARD for people who get locked in WALK-IN EQUIPMENT with extreme temperatures, ~~sometimes along~~ or with a controlled atmosphere, exhausted gas mixtures, fume or mist, suspension of particles or aerosols, as well as excessive optical radiation, measures as described in Clauses BB.2 and BB.3 should be taken. Care should be taken to ensure that no personnel is locked in WALK-IN EQUIPMENT at the end of the working day. Annex BB is limited to WALK-IN EQUIPMENT operating at CONTROLLED TEMPERATURES below zero or over 35 °C.

BB.2 Emergency switch or signal

According to the operating conditions, the following devices should be provided with the WALK-IN EQUIPMENT:

- 1) alarm switch operated by illuminated push buttons near the floor or by chains hanging near the floor, installed in a suitable place in the equipment, the operation of which initiates an audible signal and a visual signal, in a place where the permanent presence of a person is guaranteed. It should not be possible to stop this signal except by means of a specific operation;
- 2) signal devices connected to an electric circuit with a voltage of at least 12 V. Batteries for this purpose should have an operating time of at least 10 h and be connected to a MAINS supplied automatic charging device. If a transformer is used, it should be supplied with current from a different circuit to the one used for other equipment inside the WALK-IN EQUIPMENT. Furthermore, the device should be of such design that it does not cease to function due to corrosion, frost or the formation of ice on contact surfaces;
- 3) light switch inside the WALK-IN EQUIPMENT in parallel with light switches located outside this equipment so that the lighting turned on by means of the inside switch cannot be turned off by means of the outside switch;
- 4) plug switch or other systems giving the same result for the CIRCULATING FANS located inside the WALK-IN EQUIPMENT in series with the switches located on the outside so that the fans turned off by means of the inside switch cannot be turned on by means of the outside switch;
- 5) light switches ~~should have~~ having permanently illuminated buttons;
- 6) in the event of failure of the lighting, independent lighting or other approved means of indicating the routes towards the door which is intended ~~for~~ to open from the inside (and/or alarm switch) ~~should be indicated by independent lighting or by other approved means;~~
- 7) permanent emergency lighting system.

BB.3 WALK-IN EQUIPMENT with a controlled atmosphere

In WALK-IN EQUIPMENT with a controlled atmosphere (equipment with an atmosphere in which the concentration of oxygen, carbon dioxide and nitrogen are different from those in normal air), the following additional requirements apply:

- 1) warning that a self-contained breathing apparatus ~~should~~ shall be worn when entering this WALK-IN EQUIPMENT;

- 2) warning that if WALK-IN EQUIPMENT with a controlled atmosphere is entered, another person ~~should~~ shall remain outside the room and in visual contact with those inside through an access door (hatch). The person outside ~~should~~ shall also have a self-contained breathing apparatus at their disposal in case they should have to enter the equipment in order to rescue the person inside in an emergency;
- 3) doors, hatches and other appliances giving access to the WALK-IN EQUIPMENT ~~should~~ shall be provided with a written warning notice against low oxygen level in the equipment.

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV

Annex CC (informative)

Safety requirements for components and piping

CC.1 Overview

The applicable component requirements for sealed system components and the associated piping are defined differently for geographical regions depending on the classification of the pressure vessels in question.

For Europe, the sealed system components ~~may~~ can be considered pressure vessels in accordance with the Pressure Equipment Directive (PED) ~~97/23/EC~~ 2014/68/EU depending on the classification in Tables CC.1 and CC.2. If the components or piping are classified as a category II or higher pressure vessel according to the PED then the requirements of Table CC.3 ~~shall~~ apply including the use of a Notified Body according to the PED. Table CC.4 sets out the minimum wall thickness for copper and steel tubing.

For USA and Canada, the component requirements of Clause CC.2 apply.

Table CC.1 – Parameters of pressure vessels according to EN 14276-1

Fluid	Nature	PS (bar) ^a	V (L)	PS × V (bar × L)	Category/Article
if	and	and	and	and	then
Group 1	Gas	≤ 0,5	—	—	Not-submitted subjected to PED ^b
		> 0,5 and ≤ 200	≤ 1	—	Art.-3 4.3 ^c
			> 1	≤ 25	Art.-3 4.3 ^c
				> 25 and ≤ 50	I
				> 50 and ≤ 200	II
		> 200 and ≤ 1 000	≤ 1	—	III
		≤ 1 000	> 1	> 200 and ≤ 1 000	III
				> 1 000	IV
	> 1 000	—	—	IV	
	Liquid ^d	≤ 0,5	—	—	Not-submitted subjected to PED ^b
		> 0,5 and ≤ 500	≤ 1	—	Art.-3 4.3 ^c
			≤ 200	Art.-3 4.3 ^c	
		> 0,5 and ≤ 10	> 1	> 200	I
		> 10 and ≤ 500		II	
		> 500		< 1	—
> 500		> 1	—	III	
Group 2	Gas	≤ 0,5	—	—	Not-submitted subjected to PED ^b
		> 0,5 and ≤ 1 000	≤ 1	—	Art.-3 4.3 ^c
			> 1	≤ 50	Art.-3 4.3 ^c
				> 50 and ≤ 200	I
				> 200 and ≤ 1 000	II
		> 1 000 and ≤ 3 000	≤ 1	—	III
		> 1 000 and ≤ 3 000	> 1 000 and ≤ 3 000	III	

Fluid	Nature	PS (bar) ^a	V (L)	PS × V (bar × L)	Category/Article
if	and	and	and	and	then
		> 0,5 and ≤ 4	> 1	> 1 000	III
		> 4		> 3 000	IV
		> 3 000	—	—	IV
	Liquid ^d	≤ 0,5	—	—	Not-submitted subjected to PED ^b
		> 0,5 and ≤ 10	—	—	Art.-3 4.3 ^c
		> 10 and ≤ 1 000	≤ 10	—	Art.-3 4.3 ^c
		> 10 and ≤ 1 000	> 10	≤ 10 000	Art.-3 4.3 ^c
		> 10 and ≤ 500	—	> 10 000	I
		> 1 000	< 10	—	I
	> 500	> 10	> 10 000	II	

^a 1 bar = 0,1 Mpa.

^b PED = Pressure Equipment Directive.

^c Art.-3 4.3 = reference to Article-3 4.3 of the Pressure Equipment Directive.

^d Liquids are considered to be fluids having a vapour pressure of not more than 0,5 bar above the normal atmospheric pressure (1 013 mbar).

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV

Table CC.2 – Parameters of piping according to EN 14276-2

Fluid	Nature	PS (bar) ^a	DN	PS × DN (bar) ^a	Category/Article
if	and	and	and	and	then
Group 1	Gas	≤ 0,5	—	—	Not-submitted subjected to PED ^b
		> 0,5	≤ 25	—	Art.-3 4.3 ^c
			> 25 and ≤ 100	≤ 1 000	I
			> 100 and ≤ 350	> 1 000 and ≤ 3 500	II
			> 350	> 3 500	III
	Liquid ^d	≤ 0,5	—	—	Not-submitted subjected to PED ^b
		> 0,5	≤ 25	—	Art.-3 4.3 ^c
			—	≤ 2 000	Art.-3 4.3 ^c
		> 0,5 and ≤ 10	—	> 2 000	I
		> 10 and ≤ 500	> 25		II
> 500		—		III	
Group 2	Gas	≤ 0,5	—	—	Not-submitted subjected to PED ^b
		> 0,5	≤ 32	—	Art.-3 4.3 ^c
			—	≤ 1 000	Art.-3 4.3 ^c
			> 32 and ≤ 100	> 1 000 and ≤ 3 500	I
			> 100 and ≤ 250	> 3 500 and ≤ 5 000	II
			> 250	> 5 000	III
	Liquid ^d	≤ 0,5	—	—	Not-submitted subjected to PED ^b
		> 0,5 and ≤ 10	—	—	Art.-3 4.3 ^c
		—	—	≤ 5 000	Art.-3 4.3 ^c
		—	≤ 200	—	Art.-3 4.3 ^c
		> 10 and ≤ 500	> 200	> 5 000	I
		> 500		—	II

^a 1 bar = 0,1 Mpa.

^b PED = Pressure Equipment Directive.

^c Art.-3 4.3 = reference to Article-3 4.3 of the Pressure Equipment Directive.

^d Liquids are considered to be fluids having a vapour pressure of not more than 0,5 bar above the normal atmospheric pressure (1 013 mbar).

Table CC.3 – Components and piping requirements

Components	Related standards and requirements
Heat exchangers: – pipe coil without air (tube in tube) – multi-tubular (shell and tubes)	EN 14276-1 or EN 13445 if applicable combined with 11.7.2 of this document
Plate heat exchangers	EN 14276-1 or EN 13445 if applicable combined with 11.7.2 of this document
Headers and coils with air as secondary fluid	EN 14276-2 combined with a production leak tightness test based on guidance from EN 1779:1999
Receiver/accumulator/economizer	EN 14276-1 or EN 13445 if applicable combined with 11.7.2 of this document
Oil separator	EN 14276-1 or EN 13445 if applicable combined with 11.7.2 of this document
Drier	EN 14276-1 or EN 13445 if applicable combined with 11.7.2 of this document
Filter	EN 14276-1 or EN 13445 if applicable combined with 11.7.2 of this document
Muffler	EN 14276-1 or EN 13445 if applicable combined with 11.7.2 of this document
Hermetic positive displacement compressor	~~EN~~ IEC 60335-2-34 or ~~pr~~ EN 12693
Semi-hermetic positive displacement compressor	~~EN~~ IEC 60335-2-34 or ~~pr~~ EN 12693
Open positive displacement compressor	EN 12693
Non-positive displacement compressor	EN 14276-1 or EN 13445 if applicable combined with ~~EN~~ IEC 60204-1
Pump General requirements Additional requirements for pumps in REFRIGERATING SYSTEMS and heat pumps with R717	EN 809 combined with ~~EN~~ IEC 60204-1, and combined with a production leak tightness test based on guidance from EN 1779:1999 and the marking requirements from 5.1.101 of this document
Piping	EN 14276-2 or EN 13480
Piping joints Permanent joints Detachable joints	EN 14276-2 combined with a production leak tightness test based on guidance from EN 1779:1999 and an evaluation of the suitability of the joint for the pipe, piping material, pressure, temperature and fluid
Flexible piping	EN 1736
Valves	EN 12284
Safety valve	EN 13136 and ~~EN~~ ISO 4126-1 combined with a production leak tightness test based on guidance from EN 1779:1999
Safety switching devices for limiting the pressure	EN 12263 combined with a production leak tightness test based on guidance from EN 1779:1999
Isolating valves	EN 12284
Hand operated valves	EN 12284
Valves with seal cap	EN 12284
Bursting disc	~~EN~~ ISO 4126-2 and EN 13136 combined with a production leak tightness test based on guidance from EN 1779:1999
Fusible plug	EN 13136 combined with a production leak tightness test based on guidance from EN 1779:1999 and marked with the melting temperature and working pressure of the fusible material.
Liquid level indicators	EN 12178 combined with a production leak tightness test based on guidance from EN 1779:1999
Gauges	EN 837-1, EN 837-2 and EN 837-3 combined with a production leak tightness test based on guidance from EN 1779:1999
Brazing and soldering materials	Soldering alloys shall not be used for ~~REFRIGERANT containing purposes~~ REFRIGERANTS for uses where strength is a factor. Brazing alloys shall only be used when their compatibility with REFRIGERANTS and lubricants has been proven by test or experience
Welding materials	EN 14276-2

CC.2 Component and subassembly requirements for switches and controls used in REFRIGERATING SYSTEMS for North America

The minimum rating for the number of operations for switches and controls used in a REFRIGERATING SYSTEM shall be as follows:

- | | |
|---|---------|
| a) quick freeze switches | 300 |
| b) manual and semi-automatic defrost switches | 300 |
| c) door switches | 50 000 |
| d) on/off switches | 300 |
| e) thermostats which control MOTOR-COMPRESSORS | 100 000 |
| f) temperature limiters which control defrosting heaters | 100 000 |
| g) MOTOR-COMPRESSOR starting relays | 100 000 |
| h) self-resetting thermal motor-protector for MOTOR-COMPRESSORS | 2 000 |
| NOTE 2 000 or the number of operations during the 15-day locked rotor test, whichever is the greater. | |
| i) non-self resetting thermal motor-protector for MOTOR-COMPRESSORS | 50 |
| j) other automatic thermal motor-protectors except for fan motors | 2 000 |
| k) other manual reset thermal motor-protectors | 30 |
| l) interlock devices | 100 000 |

Table CC.4 – Minimum wall thickness for copper and steel tubing

Outside diameter		Copper				Steel	
		Protected within refrigerator		Unprotected			
inches	(mm)	inches	(mm)	inches	(mm)	inches	(mm)
1/4	(6,35)	0,024 5	(0,623)	0,026 5	(0,673)	0,025	(0,635)
5/16	(7,94)	0,024 5	(0,623)	0,026 5	(0,673)	0,025	(0,635)
3/8	(9,53)	0,024 5	(0,623)	0,026 5	(0,673)	0,025	(0,635)
1/2	(12,70)	0,024 5	(0,623)	0,028 5	(0,724)	0,025	(0,635)
5/8	(15,88)	0,031 5	(0,799)	0,031 5	(0,799)	0,032	(0,813)
3/4	(19,05)	0,031 5	(0,799)	0,038 5	(0,978)	0,032	(0,813)
7/8	(22,23)	0,041 0	(1,041)	0,041 0	(1,041)	0,046	(1,168)
1	(25,40)	0,046 0	(1,168)	0,046 0	(1,168)	—	—
1-1/8	(28,58)	0,046 0	(1,168)	0,046 0	(1,168)	0,046	(1,168)
1-1/4	(31,75)	0,050 5	(1,283)	0,050 5	(1,283)	0,046	(1,168)
1-3/8	(34,93)	0,050 5	(1,283)	0,050 5	(1,283)	—	—
1-1/2	(38,10)	0,055 5	(1,410)	0,055 5	(1,410)	0,062	(1,575)
1-5/8	(41,28)	0,055 5	(1,410)	0,055 5	(1,410)	—	—
2-1/8	(53,98)	0,064 0	(1,626)	0,064 0	(1,626)	—	—
2-5/8	(66,68)	0,074 0	(1,880)	0,074 0	(1,880)	—	—

The nominal wall thickness of the tubing will have to be greater than the thickness indicated to maintain the minimum wall thickness.

Annex DD (informative)

Equipment containing FLAMMABLE REFRIGERANTS – Information and marking requirements

DD.1 Marking, installation and operating instructions (SB6)

NOTE For the US, additional marking and informational requirements exist for refrigerating equipment which utilize FLAMMABLE REFRIGERANTS. The source document reference, UL 471, Annex SB6 (SB6), is included in brackets at the end of each subclause.

DD.1.1 Marking

When a FLAMMABLE REFRIGERANT is used, the markings as outlined in DD.1.2 to DD.1.5, or equivalent shall

- a) be in letters no less than 6,4 mm (1/4 inch) high;
- b) be permanently marked on the refrigerating equipment in the indicated locations (SB6.1.1 revised, November 17, 2014).

DD.1.2 OPERATOR markings

"DANGER – Risk Of Fire Or Explosion. FLAMMABLE REFRIGERANT Used. Do Not Use Mechanical Devices To Defrost Refrigerating Equipment. Do Not Puncture REFRIGERANT Tubing".

This marking shall be provided on or near any EVAPORATORS that can be contacted by the OPERATOR (SB6.1.2 revised, June 28, 2013).

DD.1.3 Service markings

For self-contained refrigerating equipment, the following markings shall be located near the machine compartment. For a remote CONDENSING UNIT, the following markings shall be located ~~by~~ near the inter-connecting REFRIGERANT tubing connections and ~~by~~ the nameplate:

- a) "DANGER – Risk Of Fire Or Explosion. FLAMMABLE REFRIGERANT Used. To Be Repaired Only By Trained Service Personnel. Do Not Puncture REFRIGERANT Tubing".
- b) "CAUTION – Risk Of Fire Or Explosion. FLAMMABLE REFRIGERANT Used. Consult Repair Manual/Owner's Guide Before Attempting To Install or Service This Equipment. All Safety Precautions Must be Followed".

(SB6.1.3 revised, November 30, 2012)

DD.1.4 Disposal

"CAUTION – Risk Of Fire Or Explosion. Dispose Of Properly In Accordance With Federal Or Local Regulations. FLAMMABLE REFRIGERANT Used".

This marking shall be provided on the exterior of the refrigerating equipment.

DD.1.5 Exposed tubing

"CAUTION – Risk Of Fire Or Explosion Due To Puncture Of REFRIGERANT Tubing; Follow Handling Instructions Carefully. FLAMMABLE REFRIGERANT Used"

This marking shall be provided near all exposed REFRIGERANT tubing.

DD.1.6 Accessing the REFRIGERANT circuit

Refrigeration tubing or other devices through which the REFRIGERANT is intended to be serviced shall be painted, coloured, or labelled red, Pantone® Matching System (PMS) No. 185. This colour shall be present at all places where service puncturing or otherwise creating an opening in the REFRIGERANT circuit might be expected. In the case of a process tube on a MOTOR-COMPRESSOR, the colour mark shall extend at least 2,5 cm (1 inch) from the MOTOR-COMPRESSOR (SB6.1.6 revised, November 17, 2014).

DD.1.7 Symbol for warning of flammable materials

The marking in item DD.1.3 a) shall also contain Symbol 102 of Table 1 for warning of flammable materials.

The colour and format of the symbol shall be exactly the same as shown. The perpendicular height of the triangle shall be at least 15 mm (9/16 in) (SB6.1.7 revised, June 28, 2013).

DD.1.8 Equipment containing a remote CONDENSING UNIT

For equipment containing a remote CONDENSING UNIT, the following marking shall be located near the tubing intended for the connection of the field supplied REFRIGERANT tubing: "CAUTION – This equipment is intended for use with FLAMMABLE REFRIGERANT. Install in accordance with the FLAMMABLE REFRIGERANT requirements specified in the ASHRAE 15".

DD.1.9 Refrigerating equipment intended for laboratory use

Refrigerating equipment intended for laboratory use that contains an A3 REFRIGERANT shall be marked:

"This unit is intended for use in commercial, industrial, or institutional occupancies as defined in the Safety Standard for Refrigeration Systems, ASHRAE 15".

(SB6.1.9 added, November 30, 2012)

DD.2 Installation and operating instructions

DD.2.1 Handling and moving

Installation and operating instructions shall be provided with cautionary statements concerning the handling, moving, and use of the refrigerating equipment to avoid either damaging the REFRIGERANT tubing or increasing the RISK of a leak.

DD.2.2 Packaging markings

The shipping carton of a refrigerating equipment that employs a FLAMMABLE REFRIGERANT shall be marked:

"CAUTION – RISK of Fire or Explosion due to FLAMMABLE REFRIGERANT Used. Follow Handling Instructions Carefully in Compliance with U.S. Government Regulations"

The warning marking of Symbol 102 of Table 1 shall also appear on the shipping carton (SB6.2.2 revised, November 17, 2014).

DD.2.3 Replacement components and servicing

The installation and operating instructions shall indicate that component parts shall be replaced with like components and that servicing shall be done by manufacturer-authorised

personnel, so as to minimize the RISK of possible ignition due to incorrect parts or improper service.

DD.2.4 Installation instructions for equipment containing a remote CONDENSING UNIT

In addition to the above, the installation instructions for equipment containing a remote CONDENSING UNIT shall contain the following:

- a) Information for spaces where pipes containing FLAMMABLE REFRIGERANT are allowed, including statements that (1) the pipework shall be protected from physical damage, and (2) compliance with the installation requirements of ASHRAE 15 shall be observed.
- b) The minimum necessary room volume per REFRIGERATING SYSTEM charge allowed. See Table SB6.1. This may be in the form of a table indicating minimum room volume per REFRIGERANT charge amount, but shall not reference a formula.
- c) Information for handling, installation, cleaning, servicing and disposal of REFRIGERANT.
- d) A warning that the equipment shall not be installed in a room with continuously operating open flame or ignition sources.

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV

Annex EE (normative)

Non-sparking "n" electrical device

The numbering of the following clauses and subclauses corresponds to the clause and subclause numbers of IEC 60079-15:2010. The following clauses and subclauses of IEC 60079-15:2010 are applicable except as modified hereafter.

11 Supplementary requirements for non-sparking luminaires

This clause of IEC 60079-15:2010 is applicable, with the exception of the following subclauses: 11.2.4.1, 11.2.4.5, 11.2.5, 11.2.6, 11.2.7, 11.3.4, 11.3.5, 11.3.6 and 11.4.

19 Supplementary requirements for sealed devices ~~or encapsulated devices~~ producing arcs, sparks or hot surfaces

This clause of IEC 60079-15:2010 is applicable, except for 19.1 and 19.6, which are replaced as follows:

19.1 Non-metallic materials

Replacement:

Seals are tested ~~using~~ in accordance with 22.5. However, if the device is tested in the equipment, then 22.5.1 and 22.5.2 are not applicable. However, after the tests of 4.4, an inspection shall reveal no damage of the encapsulation, such as cracks in the resin or exposure of encapsulated parts that could impair the type of protection.

19.6 Type tests

Replacement:

The type tests described in 22.5 shall be performed where relevant.

20 Supplementary requirements for restricted-breathing enclosures protecting ~~apparatus~~ equipment producing arcs, sparks or hot surfaces

This clause of IEC 60079-15:2010 is applicable.

Bibliography

The Bibliography of Part 1 is applicable except as follows:

Addition:

Additional references:

IEC 60050-426:2008, *International Electrotechnical Vocabulary (IEV) – Part 426: Equipment for explosive atmospheres*

IEC 60068-1:~~1988~~, *Environmental testing – Part 1: General and guidance*

~~IEC 60068-1:1992, am1, Environmental testing – Part 1: General and guidance~~

IEC 60068-2-1:~~2007~~, *Environmental testing – Part 2-1: Tests – Test A: Cold*

IEC 60068-2-2:~~2007~~, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60068-2-5:~~2010~~, *Environmental testing – Part 2-5: Tests – Test Sa: Simulated solar radiation at ground level and guidance for solar radiation testing and weathering*

IEC 60068-2-10:~~2005~~, *Environmental testing – Part 2-10: Tests – Test J and guidance: Mould growth*

IEC 60068-2-11:~~1981~~, *Environmental testing – Part 2-11: Tests. Test Ka: Salt mist*

IEC 60068-2-13:~~1983~~, *Environmental testing – Part 2-13: Tests. Test M: Low air pressure*

IEC 60068-2-14:~~2009~~, *Environmental testing – Part 2-14: Tests – Test N: Change of temperature*

IEC 60068-2-30:~~2005~~, *Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60068-2-38:~~2009~~, *Environmental testing – Part 2-38: Tests – Test Z/AD: Composite temperature/humidity cyclic test*

IEC 60068-2-39:~~1976~~, *Environmental testing – Part 2-39: Tests – ~~Test Z/AMD: Combined sequential cold, low air pressure, and damp heat test~~ Tests and guidance: Combined temperature or temperature and humidity with low air pressure tests*

IEC 60068-2-40:~~1976~~, *Environmental testing – Part 2-40: Tests. Test Z/AM: Combined cold/low air pressure tests*

~~IEC 60068-2-40:1983, am1 Environmental testing – Part 2-40: Tests. Test Z/AM: Combined cold/low air pressure tests~~

IEC 60068-2-41:~~1976~~, *Environmental testing – Part 2-41: Tests. Test Z/BM: Combined dry heat/low air pressure tests*

~~IEC 60068-2-41:1983, am1, Environmental testing – Part 2-41: Tests. Test Z/BM: Combined dry heat/low air pressure tests~~

IEC 60068-2-53:~~2010~~, *Environmental testing – Part 2-53: Tests and guidance – Combined climatic (temperature/humidity) and dynamic (vibration/shock) tests*

IEC 60068-2-66:~~1994~~, *Environmental testing – Part 2: Test methods – Test Cx: Damp heat, steady state (unsaturated pressurized vapour)*

IEC 60068-2-67:~~1995~~, *Environmental testing – Part 2-67: Tests – Test Cy: Damp heat, steady state, accelerated test primarily intended for components*

IEC 60068-2-78:~~2001~~, *Environmental testing – Part 2-78: Tests – Test Cab: Damp heat, steady state*

IEC 60068-3-5, *Environmental testing – Part 3-5: Supporting documentation and guidance – Confirmation of the performance of temperature chambers*

IEC 60079 (all parts), *Explosive atmospheres*

IEC 60204-1, *Safety of machinery – Electrical equipment of machines – Part 1: General requirements*

IEC 60335-2-24:2010, *Household and similar electrical appliances – Safety – Part 2-24: Particular requirements for refrigerating appliances, ice-cream appliances and ice makers*
IEC 60335-2-24:2010/AMD2:2017

IEC 60335-2-40:2018, *Household and similar electrical appliances – Safety – Part 2-40: Particular requirements for electrical heat pumps, air-conditioners and dehumidifiers*

IEC 60335-2-41, *Household and similar electrical appliances – Safety – Part 2-41: Particular requirements for pumps*

IEC 60335-2-73:~~2002~~, *Household and similar electrical appliances – Safety – Part 2-73: Particular requirements for fixed immersion heaters*
~~IEC 60335-2-73:2002/AMD1:2006~~

IEC 60335-2-74:~~2002~~, *Household and similar electrical appliances – Safety – Part 2-74: Particular requirements for portable immersion heaters*
~~IEC 60335-2-74:2002/AMD1:2006~~

IEC 60335-2-89, *Household and similar electrical appliances – Safety – Part 2-89: Particular requirements for commercial refrigerating appliances with an incorporated or remote refrigerant unit or compressor*

IEC 60335-2-98:~~2002~~, *Household and similar electrical appliances – Safety – Part 2-98: Particular requirements for humidifiers*
~~IEC 60335-2-98:2002/AMD1:2004~~

IEC 61010-2-010, *Safety requirements for electrical equipment for measurement, control and laboratory use – Part 2-010: Particular requirements for laboratory equipment for the heating of materials*

IEC 61770:~~2008~~, *Electric appliances connected to the water mains – Avoidance of backsiphonage and failure of hose-sets*

ISO 817:2014, *Refrigerants – Designation-system and safety classification*

ISO 4126-1, *Safety devices for protection against excessive pressure – Part 1: Safety valves*

~~ISO 5149:1993, Mechanical refrigerating systems used for cooling and heating – Safety requirements~~

ISO 5149-1:2014, *Refrigerating systems and heat pumps – Safety and environmental requirements – Part 1: Definitions, classification and selection criteria*

ISO 9227, *Corrosion tests in artificial atmospheres – Salt spray tests*

ISO 7000:2015, *Graphical symbols for use on equipment – Index and synopsis* Registered symbols (available from: <http://www.graphical-symbols.info/equipment>)

ANSI/ASHRAE 15, *Safety standard for refrigeration systems*

ANSI/ASHRAE 34, *Designation and classification of refrigerants*

EN 378-1:2008, ~~Refrigerant condensing~~ *Refrigerating systems and heat pumps – Safety and environmental requirements – Part 1: Basic requirements, definitions, classification and selection criteria*
EN 378-1:2008/AMD2:2012

EN 378-2:2008, ~~Refrigerant condensing~~ *Refrigerating systems and heat pumps – Safety and environmental requirements – Part 2: Design, construction, testing, marking and documentation*
~~EN 378-2:2008/AMD2:2012~~

EN 378-3:2008, *Refrigerating systems and heat pumps. Safety and environmental requirements – Part 3: Installation site and personal protection*
~~EN 378-3:2008/AMD1:2012~~

EN 378-4:2008, *Refrigerating systems and heat pumps. Safety and environmental requirements – Part 4: Operation, maintenance, repair and recovery*
~~EN 378-4:2008/AMD1:2012~~

EN 809, *Pumps and pump units for liquids – Common safety requirements*

EN 837-1, *Pressure gauges – Part 1 Bourdon tube pressure gauges – Dimensions, metrology, requirements and testing*

EN 837-2, *Pressure gauges – Part 2: Selection and installation recommendations for pressure gauges*

EN 837-3, *Pressure gauges – Part 3: Diaphragm and capsule pressure gauges – Dimensions, metrology, requirements and testing*

EN 1736, *Refrigerating systems and heat pumps – Flexible pipe elements, vibration isolators, expansion joints and non-metallic tubes – Requirements, design and installation*

EN 1779, *Non-destructive testing. Leak testing. Criteria for method and technique selection*

EN 12178, *Refrigeration systems and heat pumps – Liquid level indicating devices – Requirements, testing and marking*

EN 12263, *Refrigerating systems and heat pumps – Safety – Switching devices for limiting the pressure – Requirements and tests*

EN 12284, *Refrigeration systems and heat pumps – Valves – Requirements, testing and marking*

EN 12693, *Refrigerating systems and heat pumps. Safety and environmental requirements. Positive displacement refrigerant compressors*

DIN 12876-1, *Electrical laboratory devices – Laboratory circulators and baths – Part 1: Terms and classification*

DIN 12876-2, *Electrical laboratory devices – Laboratory circulators and baths – Part 2: Determination of ratings of heating and refrigerated circulators*

DIN 12876-3, *Electrical laboratory devices – Laboratory circulators and baths – Part 3: Determination of ratings of laboratory baths*

EN 13445 (all parts) *Unfired pressure vessels*

EN 13480 (all parts), *Metallic industrial piping*

EN 14276-1, *Pressure equipment for refrigerating systems and heat pumps – Part 1 Vessels – General requirements*

EN 14276-2, *Pressure equipment for refrigerating systems and heat pumps – Part 2 Piping – General requirements*

MIL-STD-810 G, *Environmental Engineering Considerations and Laboratory Tests*

UL 471 – *Standard for Commercial Refrigerators and Freezers; 10th Edition, Annex SB6*

ASME, *Boiler and Pressure Vessel Code 2017*

ICH, *Harmonised Tripartite Guideline, published by the International Conference on Harmonization of Technical Regulations for Registration of Pharmaceuticals for Human Use*

NCR-101, *Plant Growth Chamber Handbook, a publication of NCR-101 on Controlled Environment Technology and Use*

~~97/23/EC, Pressure Equipment Directive~~

World Health Organization, *Laboratory Biosafety Manual*

INTERNATIONAL STANDARD

NORME INTERNATIONALE



GROUP SAFETY PUBLICATION
PUBLICATION GROUPEE DE SÉCURITÉ

**Safety requirements for electrical equipment for measurement, control, and laboratory use –
Part 2-012: Particular requirements for climatic and environmental testing and other temperature conditioning equipment**

Règles de sécurité pour appareils électriques de mesurage, de régulation et de laboratoire –

Partie 2-012: Exigences particulières pour les appareils d'essais climatiques et d'environnement, et autres appareils de conditionnement de température

CONTENTS

FOREWORD	4
INTRODUCTION	7
1 Scope and object	10
2 Normative references	11
3 Terms and definitions	11
4 Tests	17
5 Marking and documentation	23
6 Protection against electric shock	32
7 Protection against mechanical HAZARDS	34
8 Resistance to mechanical stresses	36
9 Protection against the spread of fire	37
10 Equipment temperature limits and resistance to heat	38
11 Protection against HAZARDS from fluids and solid foreign objects	42
12 Protection against radiation, including laser sources, and against sonic and ultrasonic pressure	57
13 Protection against liberated gases and substances, explosion and implosion	58
14 Components and subassemblies	60
15 Protection by interlocks	62
16 HAZARDS resulting from application	64
17 RISK assessment	65
Annexes	66
Annex K (normative) Insulation requirements not covered by 6.7	67
Annex L (informative) Index of defined terms	68
Annex AA (informative) Useful symbols	70
Annex BB (informative) Protection of people who are inside WALK-IN EQUIPMENT	73
Annex CC (informative) Safety requirements for components and piping	75
Annex DD (informative) Equipment containing FLAMMABLE REFRIGERANTS – Information and marking requirements	80
Annex EE (normative) Non-sparking "n" electrical device	83
Bibliography	84
Figure 101 – Schema of a REFRIGERATING SYSTEM incorporating a CONDENSER	8
Figure 102 – Flow chart illustrating the selection process	9
Figure 103 – Details of scratching TOOL tip	52
Table 1 – Symbols	24
Table 101 – Time-temperature conditions	30
Table 102 – Maximum temperatures for MOTOR-COMPRESSORS	40
Table 103 – Minimum temperature for the determination of SATURATED-VAPOUR PRESSURE of the REFRIGERANT	47
Table 104 – REFRIGERANT flammability parameters	56
Table AA.1 – Useful symbols	70

Table CC.1 – Parameters of pressure vessels according to EN 14276-1	76
Table CC.2 – Parameters of piping according to EN 14276-2	77
Table CC.3 – Components and piping requirements	78
Table CC.4 – Minimum wall thickness for copper and steel tubing	79

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT
FOR MEASUREMENT, CONTROL, AND LABORATORY USE –****Part 2-012: Particular requirements for climatic and environmental
testing and other temperature conditioning equipment**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61010-2-012 has been prepared by IEC technical committee 66: Safety of measuring, control and laboratory equipment.

It has the status of a group safety publication in accordance with IEC Guide 104.

This second edition cancels and replaces the first edition published in 2016. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) alignment with changes introduced by Amendment 1 of IEC 61010-1:2010;
- b) changes related to the use of small capitals for defined terms only;
- c) clarifications for cooling tests in 4.4.2.10;

- d) requirements for overtemperature protection in 10.101, including deletion of the second part of the sentence in item b), and the deletion of item c);
- e) changes pertaining to the accurate employment of terms "temperature", "operating temperature", "working temperature", "application temperature", "room temperature" and "ambient temperature" in 3.5.104, 3.5.105, 4.3.1, 4.3.2, 5.4.2, 8.2.1, 8.2.2, 11.7.2.101.2, 11.7.2.101.3, 13.2.102, 14.102, 15.101, 15.102, 15.103, Introduction and many other locations. For the purpose of clarification, the definition of 3.5.114, CONTROLLED TEMPERATURE, is added.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
66/687/FDIS	66/688/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61010 series, published under the general title, *Safety requirements for electrical equipment for measurement, control, and laboratory use*, can be found on the IEC website.

IEC 61010-2-012 is to be used in conjunction with the latest edition of IEC 61010-1. It was established on the basis of the third edition (2010) and its Amendment 1 (2016), hereinafter referred to as Part 1.

This Part 2-012 supplements or modifies the corresponding clauses in IEC 61010-1 so as to convert that publication into the IEC standard: *Particular requirements for climatic and environmental testing and other temperature conditioning equipment*.

Where a particular subclause of Part 1 is not mentioned in this Part 2-012, that subclause applies as far as is reasonable. Where this Part 2-012 states "addition", "modification", "replacement", or "deletion", the relevant requirement, test specification, or note in Part 1 should be adapted accordingly.

In this standard:

- 1) the following print types are used:
 - requirements and definitions: in roman type;
 - NOTES: in smaller roman type;
 - *conformity and tests: in italic type;*
 - terms used throughout this standard which have been defined in Clause 3: SMALL ROMAN CAPITALS.
- 2) subclauses, figures, tables and notes which are additional to those in Part 1 are numbered starting from 101. Additional annexes are lettered starting from AA.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this standard using a colour printer.

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 PLV

INTRODUCTION

This Part 2-012, along with Part 2-010 and Part 2-011, taken together, address the specific HAZARDS associated with the heating and cooling of materials by equipment and are organized as follows:

IEC 61010-2-010	Specifically addresses the HAZARDS associated with equipment incorporating heating systems.
IEC 61010-2-011	Specifically addresses the HAZARDS associated with equipment incorporating REFRIGERATING SYSTEMS.
IEC 61010-2-012	Specifically addresses the HAZARDS associated with equipment incorporating both heating and REFRIGERATING SYSTEMS that interact with each other such that the combined heating and REFRIGERATING SYSTEM yield additional or more severe HAZARDS for the two systems than if treated separately. It also addresses the HAZARDS associated with the treatment of materials by other factors like irradiation, excessive humidity, CO ₂ and MECHANICAL MOVEMENT, etc.

Guidance for the application of the appropriate Part 2 standard(s)

When the equipment includes only a material heating system, and no REFRIGERATING SYSTEM or other environmental factors apply, then Part 2-010 applies without needing Part 2-011 or Part 2-012. Similarly, when the equipment includes only a REFRIGERATING SYSTEM, and no material heating system or other environmental factors apply, then Part 2-011 applies without needing Part 2-010 or Part 2-012. However, when the equipment incorporates both a material heating system, and a REFRIGERATING SYSTEM or the materials being treated in the intended application introduce significant heat into the REFRIGERATING SYSTEM, a determination should be made as to whether the interaction between the two systems will generate additional or more severe HAZARDS than if the systems were evaluated separately (CONTROLLED TEMPERATURE, see flow chart for selection process). If the interaction of the heating and cooling functions yields no additional or more severe HAZARDS, then both Part 2-010 and Part 2-011 apply for their respective functions. Conversely, if additional or more severe HAZARDS result from the combining of the heating and cooling functions, or if the equipment incorporates additional material treatment factors, then Part 2-012 applies, but not Part 2-010 or Part 2-011.

What HAZARDS are applicable for a REFRIGERATING SYSTEM?

The typical HAZARDS for a REFRIGERATING SYSTEM (see Figure 101) consisting of a MOTOR-COMPRESSOR, a CONDENSER, an expansion device and an EVAPORATOR include but are not limited to:

- The maximum temperature of LOW-PRESSURE SIDE (return temperature) to the MOTOR-COMPRESSOR. A MOTOR-COMPRESSOR incorporates a REFRIGERANT cooled motor and it should be established that the maximum temperatures of the LOW-PRESSURE SIDE under least favourable condition do not exceed the insulation RATINGS within the motor.
- The maximum pressure of LOW-PRESSURE SIDE at the inlet to the MOTOR-COMPRESSOR. The housing of the MOTOR-COMPRESSOR is exposed to this pressure and so the design RATING of the MOTOR-COMPRESSOR housing should accommodate the worst-case pressures whilst providing the correct safety margin for a pressure vessel.
- The maximum temperature of HIGH-PRESSURE SIDE to the CONDENSER. The temperatures of the HIGH-PRESSURE SIDE under most unfavourable conditions may present a temperature HAZARD if the OPERATOR is exposed to them or if the electrical insulation is degraded.
- The maximum pressure of HIGH-PRESSURE SIDE at the outlet to the MOTOR-COMPRESSOR. The REFRIGERANT components downstream of the MOTOR-COMPRESSOR up to the expansion device are exposed to this pressure and so the design RATING of these components should accommodate the worst-case pressures whilst providing the appropriate safety margin for a pressure vessel.

- The maximum CONTROLLED TEMPERATURES, namely, the SOAKED TEMPERATURE CONDITIONS, from which the heat is being extracted, may impact the maximum temperature of LOW-PRESSURE SIDE to the MOTOR-COMPRESSOR as well as present a temperature HAZARD if the OPERATOR is exposed to them or if the electrical insulation is degraded. Whether this CONTROLLED TEMPERATURE is derived from an integral heating function of the device or from the heat dissipated from the material being cooled, the impact under worst case conditions should be evaluated.
- The current draw of the equipment should be established when including the worst-case running conditions of the REFRIGERATING SYSTEM including any defrost cycles that may apply.

The worst-case conditions should be determined for the equipment and will include both the least favourable NORMAL USE conditions as well as the most unfavourable testing results under SINGLE FAULT CONDITIONS.





Figure 101 – Schema of a REFRIGERATING SYSTEM incorporating a CONDENSER

The selection process is illustrated in the following flow chart (see Figure 102).



IEC

Figure 102 – Flow chart illustrating the selection process

SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL AND LABORATORY USE –

Part 2-012: Particular requirements for climatic and environmental testing and other temperature conditioning equipment

1 Scope and object

This clause of Part 1 is applicable except as follows:

1.1.1 Equipment included in scope

Replacement:

Replace the second paragraph by the following:

This part of IEC 61010 specifies safety requirements for electrical equipment and its accessories within the categories a) through c), wherever it is intended to be used, whenever that equipment incorporates one or more of the following characteristics:

- A REFRIGERATING SYSTEM that is acted on or impacted by an integral heating function such that the combined heating and REFRIGERATING SYSTEM generates additional and/or more severe HAZARDS than those for the two systems if treated separately.
- The materials being treated in the intended application introduce significant heat into the REFRIGERATING SYSTEM, so that the REFRIGERATING SYSTEM in the application yields additional and/or more severe HAZARDS than those for the REFRIGERATING SYSTEM if operated at the maximum RATED ambient temperature alone.
- An irradiation function for the materials being treated presenting additional HAZARDS.
- A function to expose the materials being treated to excessive humidity, carbon dioxide, salt mist, or other substances which can result in additional HAZARDS.
- A function of MECHANICAL MOVEMENT presenting additional HAZARDS.
- Provision for an OPERATOR to walk in to the operating area to load or unload the materials being treated.

Addition:

Add the following text after the last paragraph:

NOTE 101 Examples of such equipment include environmental testing and plant growth TEST CHAMBERS, refrigerating CIRCULATORS which incorporate heating, and recirculating coolers for extracting heat.

It is possible that all or part of the equipment falls within the scope of one or more other Part 2 standards of IEC 61010 as well as within the scope of this standard. In that case, the requirements of those other Part 2 standards also apply. This document is intended for application when one or more of the additional HAZARDS described in the above dashed listed items are introduced. However, when the equipment incorporates only a REFRIGERATING SYSTEM or only a heating function or a combination of the two without introducing the additional HAZARDS described in the above list, then IEC 61010-2-011 or IEC 61010-2-010 or both, as appropriate, apply instead of this Part 2-012.

See further information in the flow chart (Figure 102) for selection process and guidance in the Introduction.

NOTE 102 Subclause 3.1.107 and Annex BB provide the definition and requirements for the protection of people who are inside WALK-IN EQUIPMENT.

1.1.2 Equipment excluded from scope

Addition:

Add the following items after item j):

- aa) equipment for the heating, cooling, and ventilation of laboratories;
- bb) sterilizing equipment.

1.2 Object

1.2.1 Aspects included in scope

Addition:

Add the following items after item g):

- aa) biohazards (see 13.101);
- bb) hazardous chemical substances (see 13.102).

2 Normative references

This clause of Part 1 is applicable, except as follows:

Addition:

IEC 60079-15:2010, *Explosive atmospheres – Part 15: Equipment protection by type of protection "n"*

IEC 60079-20-1, *Explosive atmospheres – Part 20-1: Material characteristics for gas and vapour classification – Test methods and data*

IEC 60335-2-34:2012, *Household and similar electrical appliances – Safety – Part 2-34: Particular requirements for motor-compressors*

IEC 60335-2-34:2012/AMD1:2015

IEC 60335-2-34:2012/AMD2:2016

IEC 60950-1:2005, *Information technology equipment – Safety – Part 1: General requirements*

ISO 7010, *Graphical symbols – Safety colours and safety signs – Registered safety signs* (available at <https://www.iso.org/obp>)

3 Terms and definitions

This clause of Part 1 is applicable except as follows:

3.1 Equipment and states of equipment

Addition:

Add the following new terms and definitions:

3.1.101

BATH

complete device intended for application of CONTROLLED TEMPERATURES to SPECIMENS by immersion in a temperature-controlled liquid HEAT TRANSFER MEDIUM

3.1.102

CIRCULATOR

equipment intended for application of CONTROLLED TEMPERATURES to an APPLICATION SYSTEM by external circulating of a temperature-controlled liquid HEAT TRANSFER MEDIUM

3.1.103

TEST CHAMBER

ENCLOSURE or space in some part of which specified conditions can be achieved, in particular, temperature, humidity, irradiation, low air pressure, mould growth and salt spray

3.1.104

COMBINED TEST CHAMBER

special TEST CHAMBER combined with the function of MECHANICAL MOVEMENT, for example, for vibration, shock, impact, and similar dynamic tests

3.1.105

INCUBATOR

special TEST CHAMBER, primarily for incubation of microorganisms and tissue culture

3.1.106

SHAKER

equipment to disperse or dissolve one substance in another by MECHANICAL MOVEMENT without the use of blades or stirrers that might destroy the structure of the substance, in particular, shaking BATH and shaking INCUBATOR

3.1.107

WALK-IN EQUIPMENT

TEST CHAMBER or INCUBATOR, the door of which allows the OPERATOR to enter and remain inside the equipment even with the door closed

3.1.108

DRYING-OUT

period to wait or procedure to be carried out before operation to return the equipment to NORMAL CONDITION if it has been transported or stored in humid conditions, or moved from a cold environment to a much warmer one where condensation could occur, and could cause the equipment to then fail to meet all the safety requirements of this document

3.1.109

STANDSTILL

period to wait or procedure to be carried out before operation to return the equipment to NORMAL CONDITION if it has been transported, moved, shaken, tilted or inverted and which could cause the equipment to then fail to meet all the safety requirements of this document

3.2 Parts and accessories

Addition:

Add the following new terms and definitions:

3.2.101**RESISTANCE-HEATING DEVICE**

part of resistance-heating equipment, comprising one or more heating resistors, typically composed of metallic conductors or an electrically conductive compound suitably insulated and protected

[SOURCE: IEC 60050-426:2008, 426-08-08, modified – "resistance-heating unit" has been replaced with "resistance-heating equipment".]

3.2.102**REFRIGERATING SYSTEM**

combination of interconnected REFRIGERANT-containing parts constituting one closed REFRIGERANT circuit in which the REFRIGERANT is circulated for the purpose of extracting and rejecting heat

[SOURCE: ISO 5149-1:2014, 3.1.9, modified – the term "(heat pump)" has been deleted from the term and the words "(i.e. cooling and heating)" have been deleted from the definition and the note.]

3.2.103**CASCADE SYSTEM**

REFRIGERATING SYSTEM consisting of two or more independent refrigeration circuits where the CONDENSER of one system rejects heat directly to the EVAPORATOR of another

[SOURCE: EN 378-1:2008, 3.1.12, modified – "REFRIGERATING SYSTEM consisting of" has been included.]

3.2.104**MOTOR-COMPRESSOR**

refrigerating subassembly consisting of the mechanical mechanism of the compressor and the motor, both of which are enclosed in the same sealed housing, with no external shaft seals, and with the motor operating in a REFRIGERANT atmosphere with or without oil

Note 1 to entry: The housing may be permanently sealed, such as by welding or brazing (hermetic MOTOR-COMPRESSOR), or may be sealed by gasketed joints (semi-hermetic MOTOR-COMPRESSOR). A TERMINAL box, a TERMINAL boxcover, and other electrical components or an electronic control system may be included.

[SOURCE: IEC 60335-2-34:2012, 3.101, modified – "appliance" has been replaced by "refrigerating subassembly".]

3.2.105**CONDENSER**

heat exchanger in which vaporized REFRIGERANT is liquified by removal of heat

[SOURCE: ISO 5149-1:2014, 3.4.4, modified – "refrigerant vapour" has been replaced by "vaporized REFRIGERANT".]

3.2.106**CONDENSING UNIT**

specific refrigerating subassembly combination for a given REFRIGERANT, consisting of one or more MOTOR-COMPRESSORS, CONDENSERS, liquid receivers (when required) and the regularly furnished accessories

3.2.107**EVAPORATOR**

heat exchanger in which liquid REFRIGERANT is vaporized by absorption of heat

[SOURCE: IEC 60335-2-40:2018, 3.110, modified – "refrigerant liquid" has been replaced by "liquid refrigerant".]

3.2.108

HIGH-PRESSURE SIDE

part of a REFRIGERATING SYSTEM operating approximately at the CONDENSER pressure

[SOURCE: ISO 5149-1:2014, 3.1.7]

3.2.109

LOW-PRESSURE SIDE

part of a REFRIGERATING SYSTEM operating approximately at the EVAPORATOR pressure

[SOURCE: ISO 5149-1:2014, 3.1.8]

3.2.110

CIRCULATING PUMP

pressure and/or suction pump transporting the liquid HEAT TRANSFER MEDIUM in a BATH or CIRCULATOR

3.2.111

CIRCULATING FAN

propeller fan or centrifugal impeller designed to circulate the air in a TEST CHAMBER or an INCUBATOR with or without any air duct

3.2.112

HUMIDIFIER

electric device that generates a water mist or steam and releases it into a room, greenhouse or other ENCLOSURE

3.2.113

BATH TANK

open or enclosed vessel containing the HEAT TRANSFER MEDIUM, in a BATH or CIRCULATOR

3.2.114

LIQUID CONNECTION

pipe fitting through which liquid is expelled from or discharged into a vessel or a heat exchanger

3.2.115

VENTILATOR

device for replacing air inside a TEST CHAMBER or an INCUBATOR with outside air

3.2.116

TEMPERATURE-LIMITING DEVICE

temperature-actuated device that is designed to prevent unsafe temperatures

[SOURCE: EN 378-1:2008, 3.6.5]

3.2.117

LIQUID LEVEL CUT OUT

liquid level-actuated device designed to prevent unsafe liquid levels

[SOURCE: EN 378-1:2008, 3.6.12]

3.2.118

PRESSURE-LIMITING DEVICE

pressure-actuated device (for example, a high-pressure switch) which is designed to stop the operation of the pressure-imposing element and may also operate an alarm

3.2.119**PRESSURE-RELIEF DEVICE**

valve or disc designed to relieve excessive pressure automatically

[SOURCE: ISO 5149-1:2014, 3.6.7, modified – "pressure relief valve or bursting disc device" has been replaced with "valve or disc" in the definition.]

3.2.120**FLAMMABLE LIQUID**

liquid capable of producing a flammable gas or vapour which, when mixed with air in certain proportions, will form an EXPLOSIVE GAS ATMOSPHERE under any foreseeable operating conditions

3.2.121**HEAT TRANSFER MEDIUM**

medium used to transfer heat to the material being processed

3.2.122**REFRIGERANT**

fluid used for heat transfer in a REFRIGERATING SYSTEM, which absorbs heat at a low temperature and a low pressure of the fluid and rejects heat at a higher temperature and a higher pressure of the fluid, usually involving changes of state of the fluid

[SOURCE: ISO 817:2014, 3.1.35, modified – the term "phase" has been replaced with "state" in the definition.]

3.2.123**FLAMMABLE REFRIGERANT**

REFRIGERANT with a flammability classification of A2L, A2 or A3 in accordance with ISO 817

[SOURCE: IEC 60335-2-24:2010 and IEC 60335-2-24:2010/AMD2:2017, 3.109]

3.2.124**SPECIMEN**

any material, substance, or product designated to be processed, for example, in a BATH, TEST CHAMBER or an INCUBATOR

3.2.125**APPLICATION SYSTEM**

system or device intended to work with a CIRCULATOR to carry out a functional purpose

3.5 Safety terms

Addition:

Add the following new terms and definitions:

3.5.101**SATURATED-VAPOUR PRESSURE**

<of REFRIGERANT> vapour pressure at which the liquid and vapour can exist in equilibrium at a given temperature

3.5.102**MAXIMUM ALLOWABLE PRESSURE****PS**

maximum pressure for which the equipment is designed, as specified by the manufacturer

Note 1 to entry: This note applies to the French language only.

[SOURCE: EN 378-1:2008, 3.3.2]

3.5.103

RATED PRESSURE

MAXIMUM ALLOWABLE PRESSURE for pressure components of equipment with regard to their ability to withstand pressures as specified by the manufacturer

3.5.104

ACTIVE COOLING CONTROL RANGE

ACC RANGE

CONTROLLED TEMPERATURE range that is achieved by an active REFRIGERATING SYSTEM

Note 1 to entry: This note applies to the French language only.

3.5.105

FLASH POINT

lowest liquid temperature at which, under certain standardized conditions, a liquid gives off vapours in quantity such as to be capable of forming an ignitable vapour/air mixture

Note 1 to entry: At the FLASH POINT, the vapour may cease to burn when the ignition source is removed.

[SOURCE: IEC 60050-426:2008, 426-02-14]

3.5.106

FIRE POINT

lowest temperature at which a substance ignites and continues to burn for at least 5 s after a small flame has been applied to its surface under standardized conditions

3.5.107

AUTO IGNITION TEMPERATURE

lowest temperature at which a substance will spontaneously ignite in a normal atmosphere without an external ignition source, such as a flame or spark

Note 1 to entry: Once ignited, the substance will continue to burn until it is either completely consumed or the temperature of the remainder of the substance is reduced to or below its FIRE POINT.

3.5.108

LOWER EXPLOSIVE LIMIT

LEL

concentration of flammable gas or vapour in air, below which an EXPLOSIVE GAS ATMOSPHERE will not be formed

Note 1 to entry: This note applies to the French language only.

[SOURCE: IEC 60050-426:2008, 426-02-09]

3.5.109

EXPLOSIVE GAS ATMOSPHERE

mixture with air, under atmospheric conditions, of flammable substances in the form of gas or vapour which, after ignition, permits self sustaining flame propagation

[SOURCE: IEC 60050-426:2008, 426-01-07]

3.5.110

SOAKED TEMPERATURE CONDITION

temperature conditions when the ambient temperature of the equipment under test (EUT) equals to $\pm 2,0$ °C of maximum ambient of 1.4.1 for NORMAL USE, storage or transport, and the CONTROLLED TEMPERATURE of the EUT equals to $\pm 2,0$ °C of the maximum ACC RANGE with the MOTOR-COMPRESSOR running or, the maximum RATED CONTROLLED TEMPERATURE with the MOTOR-COMPRESSOR off

Note 1 to entry: This note applies to the French language only.

3.5.111

MECHANICAL MOVEMENT

motion of materials being processed, for example in a SHAKER or COMBINED TEST CHAMBER

3.5.112

MOVEMENT FREQUENCY

number of complete cycles of MECHANICAL MOVEMENT

3.5.113

MOVEMENT AMPLITUDE

maximum radius, distance, or angle of the MECHANICAL MOVEMENT

3.5.114

CONTROLLED TEMPERATURE

temperature where the EVAPORATOR is located and to which the LOW-PRESSURE SIDE of the equipment is exposed, as a result of heat transfer either by active heating or from the APPLICATION SYSTEM or SPECIMEN

Note 1 to entry: For a heat pump system, where a four-way valve is used to shift between heat and cool, the function of CONDENSER and EVAPORATOR is exchanged.

4 Tests

This clause of Part 1 is applicable except as follows:

4.3 Reference test conditions

4.3.1 Environmental conditions

Addition:

Add the following text after item d):

Since the temperatures, pressures and current draw for a REFRIGERATING SYSTEM are significantly impacted by ambient temperatures in a non-linear way, linear extrapolation of test data is not possible. Therefore, tests to establish the temperatures, pressures, and current draw for a REFRIGERATING SYSTEM shall be conducted under the following environmental conditions:

- 1) an ambient temperature of 40 °C, or the maximum RATED ambient temperature, if higher;
- 2) the temperature of water supply is the maximum as specified by the manufacturer (see 5.4.3);
- 3) a relative humidity not exceeding the limits of 1.4.1 d), or the maximum RATED relative humidity at the maximum RATED ambient temperature, if higher.

If, as permitted by Note 2 of 1.4.1, a REFRIGERATING SYSTEM has an ambient temperature RATING below 40 °C, the NORMAL CONDITION tests shall be performed in an environment that matches the maximum RATED ambient temperature, and then repeated at an ambient temperature of 40 °C. See 4.3.2.114.

4.3.2 State of equipment

4.3.2.1 General

Replacement:

Replace the first paragraph and note by the following:

Unless otherwise specified, each test shall be carried out on the equipment assembled for NORMAL USE, and under the least favourable combination of the conditions given in 4.3.2.2 to 4.3.2.13 and 4.3.2.101 to 4.3.2.114 if applicable.

When measuring temperatures, pressures, and current draws of equipment incorporating a REFRIGERATING SYSTEM, the tests shall be started from a SOAKED TEMPERATURE CONDITION when all pressures have fully equalized. Tests at the extremes of the input voltage ($\pm 10\%$) shall start under these voltage conditions and achieve a stable state but need not start from a SOAKED TEMPERATURE CONDITION.

In case of doubt, a test may have to be made with more than one combination of conditions, for example, when the equipment is operated at or cycled in between its maximum and minimum CONTROLLED TEMPERATURES or operated in combination with excessive humidity, low air pressure, radiation, or conditions of precipitation.

Addition:

Add the following new subclauses:

4.3.2.101 Heat load

Where the equipment or materials being processed require either the provision or extraction of heat, the equipment under test (EUT) shall be loaded with a heat source/sink within the manufacturer's specified conditions of use (including maximum RATED and none).

NOTE DIN 12876 (all parts) provides procedures for determining cooling capacity and efficient heating capacity of the equipment.

4.3.2.102 Humidity and steam

Where equipment generates humidity or is intended for connection to a steam supply, it shall be set to generate or be supplied with them within the manufacturer's specified conditions of use (including maximum RATED and none).

4.3.2.103 Lamp and lamp systems

Illumination that provides part of the primary function (whether it be integral or an accessory), shall be installed and operated within the manufacturer's specified conditions of use (including maximum, off and cycled).

NOTE An example is a Xenon arc lamp used in a weather durability TEST CHAMBER.

4.3.2.104 MECHANICAL MOVEMENT

Equipment with a function of MECHANICAL MOVEMENT (for materials or HEAT TRANSFER MEDIUM) shall be set to expose the equipment and any materials being processed to the worst conditions (including maximum, off and cycled).

4.3.2.105 Spray generating systems

Spray generating systems of equipment shall be operated within the manufacturer's specified conditions of use (including maximum, off and cycled).

4.3.2.106 VENTILATORS

VENTILATORS shall be operated within the manufacturer's specified conditions of use (including maximum, off and cycled).

4.3.2.107 Pressures other than those of REFRIGERANT

Where equipment generates or uses pressures other than local atmospheric it shall be set to generate, or be supplied with pressure(s) within the manufacturer's specified conditions of use (including maximum RATED and none).

4.3.2.108 REFRIGERANT pressure

Where a heating system (or HEAT TRANSFER MEDIUM) can apply a CONTROLLED TEMPERATURE to the REFRIGERATING SYSTEM which is outside its ACC RANGE, the equipment shall be set to apply the maximum CONTROLLED TEMPERATURE allowed by the controls or interlocks with the MOTOR-COMPRESSOR off or maximum ACC RANGE with the MOTOR-COMPRESSOR on, whichever is least favourable.

Where a heating system (or HEAT TRANSFER MEDIUM) can apply a CONTROLLED TEMPERATURE to the REFRIGERATING SYSTEM which could affect the pressure in the system, the most unfavourable condition for pressure shall be established including:

- MOTOR-COMPRESSOR running throughout;
- MOTOR-COMPRESSOR started during test;
- outside its ACC RANGE with the MOTOR-COMPRESSOR off and the equipment set to apply the maximum CONTROLLED TEMPERATURE allowed by the controls or interlocks.

4.3.2.109 Exhaust and condensate

The least favourable conditions which result in production of exhaust, vapours and/or condensates shall be created (including maximum and cycled).

NOTE The TERMINALS of a RESISTANT-HEATING DEVICE exposed to ambient condition are easily condensed after the HEAT TRANSFER MEDIUM has been cooled to below ambient temperature for some time.

4.3.2.110 Filling and draining systems

Filling and draining systems shall be operated within the manufacturer's specified conditions of use (including maximum, minimum and intermediate).

4.3.2.111 Circulating system

CIRCULATING PUMP(s), agitator(s) or CIRCULATING FAN(s) shall be operated within the manufacturer's specified conditions of use (including maximum and off).

4.3.2.112 Gas HEAT TRANSFER MEDIUM

The equipment shall be operated with the gas HEAT TRANSFER MEDIUM, whether it is air or other designated gases, at the percentage of content and pressure within the manufacturer's specified conditions of use (including maximum, minimum and none).

4.3.2.113 Properties of liquid HEAT TRANSFER MEDIUM

For equipment with a wide CONTROLLED TEMPERATURE range, the effect of contraction, expansion, evaporating, condensing, oxidizing, boiling and freezing of the liquid and its allowable CONTROLLED TEMPERATURE range should be considered. HEAT TRANSFER MEDIA which change states during NORMAL USE shall be simulated to generate state change both from solid to liquid and vice versa.

4.3.2.114 Abnormal test to simulate the failure of the controlled environment

For REFRIGERATING SYSTEMS intended to operate in an ambient environment that is more restricted than that specified in 1.4.1, this additional abnormal test shall be applied to simulate the failure of the controlled environment in which the equipment is located.

Having determined the least favourable test conditions for the temperature and pressure tests under 10.4.1, the equipment is operated under these conditions until a steady state has been achieved. The test environment conditions are then increased to the levels set out in 1.4.1 (40 °C, 50 % RH) and the equipment is allowed to stabilize before the maximum temperatures and pressures are recorded. Protective devices shall not be bypassed or disabled. If the equipment does not reach steady state due to the operation of protective devices, then the maximum values recorded for this test shall be either:

- a) the maximum temperatures and pressures at the point of operation of non-resettable or manually resettable devices, which do not need to be reset during this test; or
- b) the maximum temperatures and pressures achieved after continued cycling of automatically resetting protective devices, which shall be allowed to cycle until it is clear that successive cycles will not develop higher maximum values.

4.4.2 Application of fault conditions

4.4.2.10 Cooling

Addition:

Add the following items and notes after item d):

- aa) for an air-cooled CONDENSING UNIT, each CONDENSER fan shall be stalled one at a time unless a single fault could disable all CONDENSER fans simultaneously, or with the CONDENSER airflow restricted, whichever is the worst case, until maximum stabilized pressure is attained or until representative maximum temperatures are attained under cycling load. The temperatures and pressures shall be monitored at short intervals throughout the test to ensure that peak values are captured. This test is conducted at an ambient temperature of $25\text{ °C} \pm 3\text{ °C}$.
- bb) for a water-cooled CONDENSING UNIT, the REFRIGERATING SYSTEM shall be operated with the condensing water shut off, or with the condensing water restricted, whichever is the worst case, until maximum stabilized pressure is attained or until representative maximum temperatures are attained under cycling load. The temperatures and pressures shall be monitored at short intervals throughout the test to ensure that peak values are captured. This test is conducted at an ambient temperature, and a water temperature of $25\text{ °C} \pm 3\text{ °C}$.

If a manual reset PRESSURE-LIMITING DEVICE is relied upon to limit the maximum and/or minimum pressure for the HIGH-PRESSURE SIDE or LOW-PRESSURE SIDE, then it shall be reset manually within 6 s of operation for 10 cycles.

NOTE 101 The running state of the MOTOR-COMPRESSOR is not relevant after the manual high PRESSURE-LIMITING DEVICE has operated.

If an automatic reset PRESSURE-LIMITING DEVICE is relied upon to limit the maximum and/or minimum pressure for the HIGH-PRESSURE SIDE or LOW-PRESSURE SIDE, then it shall be permitted to cycle automatically until it can be demonstrated that peak temperatures and pressures have been achieved.

NOTE 102 It is possible that a MOTOR-COMPRESSOR designed to be cooled by cycling of the REFRIGERANT would overheat enough to cause HAZARDS, if leakage of REFRIGERANT occurs and the PRESSURE-LIMITING DEVICE for LOW-PRESSURE SIDE is triggered repeatedly.

NOTE 103 The correct specification or appropriate setting of the pressure differential (hysteresis) of an automatic reset PRESSURE-LIMITING DEVICE is important for MOTOR-COMPRESSORS which require a longer STANDSTILL (off cycle) period.

If it can be demonstrated that a PRESSURE-LIMITING DEVICE will operate during the tests of MAXIMUM ALLOWABLE PRESSURE (PS), the manufacturer may elect to waive the test, but shall set the PS for the HIGH-PRESSURE SIDE of the MOTOR-COMPRESSOR to the RATING of the PRESSURE-LIMITING DEVICE.

For equipment with both air-cooled and water-cooled CONDENSERS, faults are applied one at a time only, unless the equipment is designed so that the OPERATOR can select to run either an air-cooled or a water-cooled CONDENSER (for example, some equipment is equipped with a water-cooled CONDENSER as an auxiliary for the air-cooled CONDENSER).

For a CASCADE SYSTEM, where an EVAPORATOR from the first stage REFRIGERATING SYSTEM acts as a CONDENSER to the second stage REFRIGERATING SYSTEM, the manufacturer may elect to run each CONDENSING UNIT individually under the tests of 4.4.2.10. In this case, disabling the first REFRIGERATING SYSTEM is considered to simulate the second stage CONDENSING UNIT running under the conditions of aa) and bb) above.

4.4.2.11 Heating devices

Addition:

Add the following paragraph after item b):

If a HAZARD could be caused by over-filling or under-filling with a liquid HEAT TRANSFER MEDIUM, the equipment shall be tested when empty, partially filled, or overfilled, whichever is least favourable. In case of doubt, the test shall be carried out in more than one condition. The HEAT TRANSFER MEDIUM used for the test shall be of a type specified for NORMAL USE.

Addition:

Add the following new subclauses:

4.4.2.101 MOTOR-COMPRESSOR

Housing and winding temperatures of MOTOR-COMPRESSORS that do not conform with IEC 60335-2-34 (including IEC 60335-2-34:2012, IEC 60335-2-34:2012/AMD1:2015 and IEC 60335-2-34:2012/AMD2:2016, Annex AA), shall be measured under the conditions of 19.101, 19.102 and 19.103 of IEC 60335-2-34:2012.

Housing and winding temperatures of MOTOR-COMPRESSORS conforming with IEC 60335-2-34 (including IEC 60335-2-34:2012, IEC 60335-2-34:2012/AMD1:2015 and IEC 60335-2-34:2012/AMD2:2016, Annex AA), are not measured.

4.4.2.102 Fluid leakage in the equipment

Internal leaks of fluids shall be simulated.

4.4.2.103 Solenoid valve and motorized valve

Equipment where the failure of a solenoid or motorized valve could cause a HAZARD shall be tested with the valve held in the worst likely failed state (including fully open, fully closed, anywhere in-between and changing state at the wrong time).

4.4.2.104 Failure of temperature control

The BATH TANK or other liquid vessel of the equipment shall be filled to its maximum level with the HEAT TRANSFER MEDIUM for NORMAL USE as specified by the manufacturer. The following faults shall then be applied, fault a) is applied on its own but if the conditions for c) are true then c) is applied immediately after b).

- a) Uncontrolled heating – For equipment where there is an opening over the BATH TANK and where the boiling of the HEAT TRANSFER MEDIUM could cause a HAZARD, the temperature controllers shall be overridden so that the HEAT TRANSFER MEDIUM is kept boiling until any TEMPERATURE-LIMITING DEVICE for overtemperature protection is triggered, or boiling is terminated by the loss of the liquid.

- b) Uncontrolled cooling – Temperature controllers shall be overridden to produce uncontrolled cooling until the HEAT TRANSFER MEDIUM becomes coagulated, solidified or frozen, or until there is no evidence of further increases in the kinematic viscosity of the HEAT TRANSFER MEDIUM, or operation of the MOTOR-COMPRESSOR is automatically terminated by a protective device.
- c) Return to control – This test shall be applied to equipment incorporating an immersed or flow-through REFRIGERATING SYSTEM EVAPORATOR and/or a CIRCULATING PUMP and where the HEAT TRANSFER MEDIUM has become frozen, solidified or coagulated and the MOTOR-COMPRESSOR is still operational or could be made operational by resetting its protective device without the use of a TOOL. Under these conditions the MOTOR-COMPRESSOR's protective device shall be reset (if required) and the temperature control shall be re-activated with the CONTROLLED TEMPERATURE set to a value where the HEAT TRANSFER MEDIUM would be a liquid at its normal viscosity. The test terminates when all of the HEAT TRANSFER MEDIUM is at the specified CONTROLLED TEMPERATURE and normal viscosity.

4.4.2.105 HUMIDIFIER

HUMIDIFIERS that are not RATED to operate continuously shall be forced to operate continuously.

The container of an electrode-type HUMIDIFIER shall be filled with a saturated solution of sodium chloride in water, at a temperature of $20\text{ °C} \pm 5\text{ °C}$. The HUMIDIFIER shall be supplied at its RATED voltage.

NOTE The solution is saturated when no more salt can be dissolved in the water at a particular temperature.

If flexible tubing or hose is used for the steam or mist outlet, the test shall be performed with the tubing or hose unobstructed, partially blocked, and fully blocked.

If the equipment depends on a differential pressure between the inlet and outlet of the HUMIDIFIER to drive the steam or mist into the equipment, the HUMIDIFIER shall be operated with the equipment running at or cycling between its maximum and minimum CONTROLLED TEMPERATURES, whichever is least favourable.

In case of doubt, tests shall be carried out with more than one combination of conditions.

4.4.2.106 Speed controller

If a HAZARD could arise in case of a single fault of a speed controller, then such faults shall be applied, one at a time.

NOTE As examples, speed controllers are sometimes used to control MOVEMENT FREQUENCY in a SHAKER or COMBINED TEST CHAMBER, and to control pressure and flow rate of a CIRCULATING PUMP. Under a SINGLE FAULT CONDITION of the speed controller, a HAZARD might arise if the pressure developed by the pump exceeds the MAXIMUM ALLOWABLE PRESSURE of an APPLICATION SYSTEM, or if excessive MOVEMENT FREQUENCY of a SHAKER or COMBINED TEST CHAMBER results in loosening, tumbling, ejection, or destruction of the SPECIMEN.

4.4.3 Duration of tests

4.4.3.1 General

Replacement:

Replace the text with the following:

The equipment shall be operated until further change as a result of the applied fault is unlikely. Each test is normally limited to 1 h since a secondary fault arising from a SINGLE FAULT CONDITION will usually manifest itself within that time. If there is an indication that a HAZARD of electric shock, spread of fire or injury to persons can eventually occur, the test shall be continued until it is clear that stable conditions have been maintained for at least 1 h, unless one of these HAZARDS arises before then.

4.4.4 Conformity after application of fault conditions

4.4.4.1 General

Addition:

Add the following text below item c):

Conformity with the requirements for temperature protection of MOTOR-COMPRESSORS is checked as specified in 4.4.2.101.

5 Marking and documentation

This clause of Part 1 is applicable except as follows:

5.1.3 MAINS supply

Addition:

Add the following new symbols to Table 1:

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV

Table 1 – Symbols

Number	Symbol	Reference	Description
101		ISO 7010-W010 (2011-05)	Warning; low temperature/freezing conditions, frostbite HAZARD
102		ISO 7010-W021 (2011-05)	Warning; flammable material/FLAMMABLE LIQUID
103		ISO 7010-W009 (2011-05)	Warning; biological HAZARD
104		ISO 7010-W027 (2011-05)	Warning; optical radiation
105		ISO 7010-W011 (2011-05)	Warning; slippery surface
106		ISO 7010-W024 (2011-05)	Warning; crushing of hands

5.1.5 TERMINALS, connections and operating devices

Addition:

Add the following new subclauses:

5.1.5.101 LIQUID CONNECTIONS for HEAT TRANSFER MEDIUM

LIQUID CONNECTIONS for HEAT TRANSFER MEDIUM shall be marked with graphical symbols or text to identify the outlet and inlet of the HEAT TRANSFER MEDIUM.

NOTE For refrigerating CIRCULATORS, symbols 107 through 109 can be used and, for refrigerating and heating CIRCULATORS, symbols 110 through 112 can be used (see Table AA.1).

Additionally, consideration may be given to mark the following:

- if the outlet pressure of the liquid is greater than 0,03 MPa or 0,02 MPa with a maximum flow rate of more than 10 l/min, the maximum pressure in Pa, in association with symbol 108 or 111;
- for a CIRCULATOR with a liquid suction pressure greater than 0,02 MPa, the maximum pressure in Pa preceded by a minus sign, in association with symbol 109 or 112;
- for an enclosed CIRCULATOR intended for connection to a sealed APPLICATION SYSTEM, and if the LIQUID CONNECTIONS need to withstand pressure exceeding 0,03 MPa, the maximum pressure for each LIQUID CONNECTION, in association with symbols 108 and 109, or 111 and 112.

Symbols 107 to 112 are found in Table AA.1.

Where there is insufficient space near the LIQUID CONNECTIONS, symbol 14 of Table 1 may be used and explanations shall be given in the instructions provided with the equipment.

Conformity is checked by inspection.

5.1.5.102 LIQUID CONNECTION for filling of BATH TANKS with enclosed CIRCULATORS

Where the mis-setting of controls or valves associated with the LIQUID CONNECTION for filling a BATH TANK with an enclosed CIRCULATOR could cause a HAZARD, symbol 14 shall be placed close to the LIQUID CONNECTION and the instructions for use (see 5.4.4) shall clearly explain the necessary settings to ensure safety under different operating conditions.

Conformity is checked by inspection.

5.1.5.103 Other LIQUID CONNECTIONS and exhaust opening

LIQUID CONNECTIONS for filling, water supply, draining, overflowing and exhaust opening shall be marked as follows:

- a) for equipment intended for manual filling of liquid, if the area of the opening for the BATH TANK or other liquid vessel is smaller than 80 cm² or it is not self-evident, a text marking or symbol 116 to indicate the location of the opening for filling;
- b) for equipment intended for direct connection to the water supply, a text marking or symbol 113 for each LIQUID CONNECTION for water source, and optionally including, as applicable, auxiliary text to indicate the RATED pressure, flow rate, and maximum temperature of the water supply;
- c) for equipment incorporating a water-cooled CONDENSING UNIT, or LIQUID CONNECTIONS for circulating water, a text marking or symbol 113 to identify the inlet, and a text marking or symbol 114 to identify the outlet, one or both of which also indicate the direction of liquid flow, and including as applicable, auxiliary text to indicate the RATED pressure, flow rate, and maximum temperature of the water supply;
- d) for LIQUID CONNECTION for condensate, a text marking or symbol 115;
- e) for LIQUID CONNECTION for draining, a text marking or symbol 117;
- f) for LIQUID CONNECTION for overflowing, a text marking or symbol 118;
- g) markings in association with a VENTILATOR include:
 - 1) symbol 119 for the adjustment handle or shaft of the VENTILATOR,
 - 2) symbol 120 for the fresh air inlet accompanied by, where necessary, the following text or its equivalent, "Fresh air inlet. Do not block.";
 - 3) symbol 121 for the exhaust opening.

NOTE Symbols 113 to 121 can be found in Table AA.1.

Where there is insufficient space near the LIQUID CONNECTIONS and/or exhaust openings, symbol 14 of Table 1 may be used and additional explanation shall be included in the instructions.

Conformity is checked by inspection.

5.1.5.104 Equipotential TERMINALS

Each equipotential TERMINAL shall be marked with the symbol for equipotentiality of IEC 60417-5021 (2002-10). The marking shall not be marked on a screw, bolt, removable washer, or any other part that is removable when a connection is being made to conductors or wires.

Conformity is checked by inspection.

Addition:

Add the following new subclauses at the end of 5.1:

5.1.101 Marking for equipment incorporating a REFRIGERANT CONDENSING UNIT

For equipment incorporating a REFRIGERANT CONDENSING UNIT, the following information shall be marked:

- a) the total mass of REFRIGERANT for each separate REFRIGERANT circuit;
- b) for a single component REFRIGERANT, at least one of the following:
 - 1) the chemical name,
 - 2) the chemical formula,
 - 3) the REFRIGERANT number;
- c) for a blended REFRIGERANT, at least one of the following:
 - 1) the chemical name and nominal proportion of each of its components,
 - 2) the chemical formula and nominal proportion of each of its components,
 - 3) the REFRIGERANT number and nominal proportion of each of its components,
 - 4) the REFRIGERANT number of the REFRIGERANT blend;

NOTE 1 REFRIGERANT numbers are quoted in accordance with ISO 817 or other REFRIGERANT classification standard, for example ANSI/ASHRAE 34.

- d) MAXIMUM ALLOWABLE PRESSURE (PS) under NORMAL CONDITION, HIGH-PRESSURE SIDE and LOW-PRESSURE SIDE for each REFRIGERANT stage.

NOTE 2 The collation of the test results that define PS is detailed in 11.7.1.

Conformity is checked by inspection.

5.1.102 Marking for equipment incorporating MECHANICAL MOVEMENT

For SHAKERS and COMBINED TEST CHAMBERS incorporating a function of MECHANICAL MOVEMENT, the maximum safe load of the SPECIMEN holder shall be marked.

Conformity is checked by inspection.

5.2 Warning markings

Addition:

Add the following text after item b):

Warning markings for particular HAZARDS which exist only when performing equipment maintenance shall be marked so that they are visible only when the particular maintenance is being performed. For example, the marking of the type of FLAMMABLE REFRIGERANT and of the flammable insulation blowing gas, shall be visible when gaining access to the MOTOR-COMPRESSORS, and, in the case of equipment with a remote REFRIGERANT CONDENSING UNIT, the pipe connections. The symbol 102 of Table 1 shall be at least 15 mm in height.

5.4.1 General

Replacement:

Replace item d) by the following:

- d) the information specified in 5.4.2 to 5.4.6, 5.4.101 and 5.4.102;

5.4.2 Equipment RATINGS

Replacement:

Replace the first paragraph by the following text:

Where applicable the documentation shall include the following:

Addition:

Add the following items after f):

- aa) the maximum and minimum CONTROLLED TEMPERATURES;
- bb) the ACC RANGE and RATED cooling capacity for REFRIGERATING SYSTEM;
- cc) RATED PRESSURE and flow rate for LIQUID CONNECTIONS between CIRCULATOR and an APPLICATION SYSTEM;
- dd) the maximum additive relative humidity;
- ee) the minimum air pressure;
- ff) the maximum radiation strength;
- gg) RATED PRESSURE, flow rate for connections to liquid and air supplies;
- hh) maximum MOVEMENT FREQUENCY, MOVEMENT AMPLITUDE versus the mass of the load.

5.4.3 Equipment installation

Replacement:

Replace items a) to g) with the following:

- a) assembly, location and mounting requirements. Space requirements, in particular the minimum distance to all the ventilating holes or grid, LIQUID CONNECTIONS and/or exhaust opening. Additional requirements for the rigidity and non-slip characteristics of the floor and/or laboratory bench. If a HAZARD could be caused by hot items falling from the equipment, for example when a door is opened, there shall be a warning that the equipment shall not be mounted on a surface of flammable material. Assembling the equipment away from overhead fire sensors, where opening of the door or lid or, exhausting of the fume is possible for NORMAL USE;
- b) for equipment incorporating lockable swivel casters and/or levellers, the requirements to lock the casters and adjust the levellers;
- c) ventilation requirements: if the operating of the equipment could lead to liberation of hazardous air or gas mixture, installation instructions shall warn of the need for an extraction system, and of additional TEMPERATURE-LIMITING DEVICES relating to safe temperatures for the materials, etc.;
- d) requirements for liquid filling, draining or overflowing (see 10.1 b));
- e) connection to the power source:
 - 1) instructions for protective grounding;
 - 2) for equipment intended for WET LOCATIONS (see 1.4.2) and in which HAZARDOUS LIVE parts may need to be ACCESSIBLE (see 6.1.2), warning symbol and statement that power socket with appropriate IP protection is used and whether external residual current circuit breaker (RCD) with RATED breaking capacity is necessary;
 - 3) warning symbol and statement which are necessary when permanent connection to the supply source is essential;
 - 4) for PERMANENTLY CONNECTED EQUIPMENT:
 - supply wiring requirements;

- requirements for any external switch or circuit-breaker (see 6.11.3.1) and external overcurrent protection devices (see 9.6.2), and a recommendation that the switch or circuit-breaker be near the equipment;
- f) requirements for special external services, for example, air and cooling liquid. Characteristics necessary for safety shall be specified, for example, maximum and minimum temperature, pressure, or flow of air or cooling liquid;
- g) requirements for installation of and/or connection to vacuum pump, air compressor and/or steam source;
- h) instructions relating to sound pressure level (see 12.5.1); the maximum sound power level produced by equipment which emits sound, if measurement is required by 12.5.1;
- i) requirements for DRYING-OUT and/or STANDSTILL (see 5.4.3.101);
- j) requirements for connecting a remote CONDENSING UNIT to the equipment, in particular, requirements for location, space, pipes, tubes, accessories (see 14.101), detailed specifications for REFRIGERANT (see 5.1.101), ventilation, water supply, and detailed procedures for connection and adjustment;
- k) requirements for connecting a CIRCULATOR to the APPLICATION SYSTEM, in particular requirements for location, space, tubes, accessories (see 14.102), insulation, liquid HEAT TRANSFER MEDIUM, ventilation, water supply, and detailed procedures for connection and adjustment;
- l) requirements for installing any functional lamp source, in particular recommended lamps and accessories, measures for protection against rupture of the lamp and its disposal, precautions for protection against HAZARDS of possible electric shock, hot surface, excessive optical and/or UV radiations, requirements for ventilation and water source, and detailed procedures for installation and adjustment;
- m) requirements for connecting HUMIDIFIER or steam source to the equipment, in particular recommended type and specifications of the HUMIDIFIER, equivalent evaporation of the steam source, requirements for tubes, accessories, insulation, ventilation, water supply, and precautions for protection against HAZARDS of possible electric shock, hot surface, mechanical injury in association with the installation, and detailed procedures for installation and adjustment;
- n) requirements for installation and adjustment for the MECHANICAL MOVEMENT.

Conformity is checked by inspection.

Addition:

Add the following new subclause:

5.4.3.101 DRYING-OUT and STANDSTILL

The instructions shall include a warning that the equipment cannot be assumed to meet all the safety requirements of this document during the DRYING-OUT and/or STANDSTILL.

Conformity is checked by inspection.

5.4.4 Equipment operation

Addition:

Add the following items after item j):

- aa) requirements for the liquid HEAT TRANSFER MEDIUM and warning against HAZARDS related to improper use of the liquid;
 - specifications of the liquid applicable to the equipment, in particular the CONTROLLED TEMPERATURE range, flammability, viscosity, FLASH POINT, FIRE POINT,

AUTO IGNITION TEMPERATURE, specific gravity and specific heat capacity and their effect on applications (see 4.3.2.113);

- procedures and precautions for filling, draining and replacing (see 10.1 b));
- chemical HAZARD and instructions for disposal and emergency treatment;
- special requirements for HEAT TRANSFER MEDIA which change states during NORMAL USE, in particular the HEAT TRANSFER MEDIA in a salt BATH;

- bb) instructions for how to calculate the cooling capacity and/or effective heating capacity for SPECIMENS and the APPLICATION SYSTEM;

NOTE 101 Cooling capacity is a measurement of the heat flow that a REFRIGERATING SYSTEM withdraws from the HEAT TRANSFER MEDIUM, as determined according to standard testing procedures, for example, DIN 12876-2.

NOTE 102 Effective heating capacity is a measurement of the heat flow that heating sources radiate to the HEAT TRANSFER MEDIUM.

- cc) requirements for SPECIMEN loading, distributing and fixing within the working space for BATH, INCUBATOR or TEST CHAMBER or over the holder of MECHANICAL MOVEMENT;
- dd) procedures to be followed to shut down the equipment safely and leave it in a safe state;
- ee) warning against access to WALK-IN EQUIPMENT (see also Annex BB) for untrained personnel or children. Requirements for access to WALK-IN EQUIPMENT, in particular the use of personal protective equipment, presence of a second OPERATOR, unlocking mechanism and clearance of the door, and indicating device when the OPERATOR is inside the equipment;
- ff) requirements for the ventilating device, access port (hatch) and LIQUID CONNECTIONS; warning against HAZARDS from high and low temperatures (see 10.1), liberated hazardous gas, liquid or solid (see 13.1);
- gg) requirements for regular inspection and its intervals with regard to SPECIMEN fixing and potential HAZARDS during the shaking process;
- hh) instructions for proper operation of and warning against HAZARDS from lamps and lamp systems, HUMIDIFIER or steam source and MECHANICAL MOVEMENT;
- ii) instructions for use of personal protective equipment, protective measures or requirement for training.

Conformity is checked by inspection.

Addition:

Add the following new subclause:

5.4.4.101 Cleaning and decontamination

The instructions shall include conditions and intervals for cleaning and, where necessary, decontamination. The recognized generic names of recommended materials for cleaning and decontamination shall be given as well as an indication of any materials which could be likely to be used but which are incompatible with parts of the equipment or with material contained in it.

The instructions shall also state that the RESPONSIBLE BODY shall ensure that:

- a) appropriate decontamination is carried out if a hazardous substance is spilt onto or into the equipment;
- b) no decontamination or cleaning agents are used which could cause a HAZARD as a result of a reaction with parts of the equipment or with material contained in it;
- c) the manufacturer or his agent is consulted if there is any doubt about the compatibility of decontamination or cleaning agents with parts of the equipment or with material contained in it.

If a manufacturer claims that an item can be decontaminated by steam sterilization, it shall be capable of withstanding steam sterilization under at least one of the time-temperature conditions given in Table 101.

Manufacturers should be aware of the internationally recognized "Laboratory Biosafety Manual", published by the World Health Organization in Geneva, which gives information on decontaminants, their use, dilutions, properties and potential applications. There are also national guidelines which cover these areas.

Cleaning and decontamination may be necessary as a safeguard when equipment intended for biological application and any accessories are maintained, repaired, or transferred. Manufacturers are required to provide a format for the RESPONSIBLE BODY to certify that such treatment has been carried out.

Table 101 – Time-temperature conditions

Absolute pressure kPa	Corresponding steam temperature		Minimum hold time min
	Nominal °C	Range °C	
325	136,0	134 to 138	3
250	127,5	126 to 129	10
215	122,5	121 to 124	15
175	116,5	115 to 118	30

NOTE "Minimum hold time" means the time during which the containment is at steam temperature.

Conformity is checked by inspection.

5.4.5 Equipment maintenance and service

Replacement:

Replace the text with the following:

Where continued safe operation is dependent on regular scheduled maintenance, inspection and/or testing of the equipment, the instructions to the RESPONSIBLE BODY shall detail the required maintenance, inspection and/or testing procedures, and provide information to assist the RESPONSIBLE BODY in determining a suitable maintenance schedule.

In particular the following details shall be included if applicable:

- Detailed specifications for the REFRIGERANT (see 5.1.101), HEAT TRANSFER MEDIUM, flexible tubing, hose, fittings, insulation materials, lamps, door gaskets which are specific to the equipment.
- Intervals, detailed procedures for checking the function of safety-related mechanisms of MECHANICAL MOVEMENT, specific consumable parts and accessories.
- Intervals, detailed procedures for inspecting the function of the TEMPERATURE-LIMITING DEVICE, LIQUID LEVEL CUT OUT, PRESSURE-LIMITING DEVICE and similar protective devices.
- Intervals and detailed procedures for cleaning of the piezo-electric transducer used in an ultrasonic HUMIDIFIER, RESISTANCE-HEATING DEVICE, water heat exchanger, and filters in the heat exchanging system.
- Statement that maintenance operations ACCESSIBLE by means of a TOOL shall be carried out only by trained personnel approved by the manufacturer.

- Where applicable, instructions shall specify procedures for the RESPONSIBLE BODY to check the effective operation of devices or systems for overtemperature protection, liquid level protection, high or low pressure protection, the unlocking or interlocking mechanism of a door or lid for escaping from within the WALK-IN EQUIPMENT (see Annex BB) which are necessary for safety, and shall state how often the checks need to be made.

If applicable, the manufacturer's documentation shall instruct against replacing detachable MAINS supply cords by inadequately RATED cords.

For equipment using replaceable batteries, the specific battery type shall be stated.

The instructions shall specify any parts which are required to be examined or supplied only by the manufacturer or his agent to ensure that safety is not compromised. Listing the manufacturer's part number is considered sufficient when the manufacturer does not wish to allow alternatives to be used.

The RATING and characteristics of replaceable fuses shall be stated.

Where special procedures are required to prepare equipment for periods of inactivity, storage or for decommissioning, these procedures shall be detailed in the instructions.

If the equipment is to be kept idle and/or stored under freezing ambient conditions, instructions for power disruption, liquid draining and DRYING-OUT shall be given.

Precaution statements and warnings against HAZARDS related to procedures for maintenance and inspection shall be given.

Instructions on the following subjects shall be provided for service personnel, as necessary to permit safe servicing and continued safety of the equipment after servicing if the equipment is suitable to be serviced:

- a) RISKS, specific to the equipment, that can affect the service personnel;
- b) protective measures for these RISKS;
- c) verification of the safe state of the equipment after repair.

Instructions for service personnel need not be supplied to the RESPONSIBLE BODY, but should be made available to service personnel.

Conformity is checked by inspection.

Addition:

Add the following new subclauses:

5.4.101 Additional instructions for refrigerating equipment that use FLAMMABLE REFRIGERANT

For refrigerating equipment that uses FLAMMABLE REFRIGERANT, the instructions shall include sufficient information to ensure the safe handling, servicing and disposal of the equipment.

The instructions shall include the substance of the following warnings as necessary:

- WARNING: Ensure all ventilation openings are not obstructed;
- WARNING: Do not use mechanical devices or other means to accelerate the defrosting process, other than those recommended by the manufacturer;
- WARNING: Do not damage the refrigerant circuit;

- **WARNING:** Do not use electrical appliances within the equipment, other than those recommended by the manufacturer.

NOTE For the US, additional marking and informational requirements exist for refrigerating equipment which employs FLAMMABLE REFRIGERANTS. See Annex DD for detailed information.

For equipment which uses flammable gas for insulation blowing, the instructions shall include information regarding disposal of the equipment.

The instructions for equipment incorporating a remote REFRIGERANT CONDENSING UNIT that uses a FLAMMABLE REFRIGERANT shall include the substance of the following warning:

- **WARNING:** In order to reduce fire hazards, the installation of this equipment shall only be carried out by qualified personnel approved by the manufacturer.

The marking of the type of FLAMMABLE REFRIGERANT and of the flammable gas for insulation blowing shall be visible when gaining access to the MOTOR-COMPRESSORS, and, in the case of equipment with a remote REFRIGERANT CONDENSING UNIT, the pipe connections.

Symbol 102 of Table 1 shall be placed on the nameplate of the equipment near the declaration of the REFRIGERANT type and charge information. It shall be clearly visible after installation of the equipment.

Conformity is checked by inspection.

5.4.102 Additional instructions for equipment intended for use with a FLAMMABLE LIQUID HEAT TRANSFER MEDIUM

For BATHS, CIRCULATORS and shaking BATHS intended for use with a FLAMMABLE LIQUID HEAT TRANSFER MEDIUM, the instructions shall include sufficient information to ensure the safe handling, servicing and disposal of the equipment.

The instructions shall include the substance of the following warnings as necessary:

- **WARNING:** Ensure all ventilation openings are not obstructed;
- **WARNING:** No smoking! No flame! Do not use electrical parts which can produce spark when operating around the equipment and the application system;
- **WARNING:** Drain and recover the liquid when the equipment idles, if the liquid heat transfer medium is used with open bath tank and if it is highly volatile at ambient temperature.

A label carrying symbol 102 shall be provided with the equipment which can be used with a FLAMMABLE LIQUID HEAT TRANSFER MEDIUM along with instructions for the RESPONSIBLE BODY to affix the label visibly on the equipment if it is to be used with a FLAMMABLE LIQUID HEAT TRANSFER MEDIUM.

The instructions shall be provided with detailed information for procedures to reduce the RISK with regard to the use of a FLAMMABLE LIQUID HEAT TRANSFER MEDIUM, including how the adjustable TEMPERATURE-LIMITING DEVICE is adequately set so that the surface temperature in contact with the liquid is below the limit of 9.5 a).

Conformity is checked by inspection.

6 Protection against electric shock

This clause of Part 1 is applicable except as follows:

6.1.1 Requirements

Addition:

Add the following after the conformity statement:

If the installation instructions specify a STANDSTILL or DRYING-OUT (see 5.4.3.101), this is carried out before making the measurements set out in 6.3, 6.7.2.2 and 6.8. STANDSTILL or DRYING-OUT is followed by a rest period of 2 h, with the equipment de-energized, before the measurements are taken.

Measurements are made with the equipment at ambient temperature. If there is doubt whether the permissible limits could be exceeded at the least favourable combined operating conditions, the relevant measurements are repeated at these conditions and the higher values are used.

6.3.1 Levels in NORMAL CONDITION

Addition:

Add the following to item b) 1):

Levels for PERMANENTLY CONNECTED EQUIPMENT are 1,5 times these values.

6.3.2 Levels in SINGLE FAULT CONDITION

Addition:

Add the following to item b) 1):

Levels for PERMANENTLY CONNECTED EQUIPMENT are 1,5 times these values.

6.7.2.2 Solid insulation

Addition:

Add the following new subclause:

6.7.2.2.101 DRYING-OUT

If the performance requirements of the equipment cannot be achieved without the use of hygroscopic heater insulation, it is permissible for equipment to require a period of operation to dry out the insulation before meeting the requirements of 6.7.2.2, 6.3.1 and 6.8.2 provided that the OPERATOR is made aware of this (see 5.4.3.101).

Conformity is checked by performing the DRYING-OUT specified in the OPERATOR manual (see 5.4.3.101) before conducting the tests of 6.3.1 and 6.8.2.

6.8.1 General

Addition:

Add the following paragraph after the second paragraph:

If a DRYING-OUT is specified (see 6.7.2.2.101), this is carried out in accordance with the OPERATOR manual (see 5.4.3.101) before the tests of 6.8.3. DRYING-OUT is followed by a rest period of 2 h with the equipment de-energized. The tests are then performed and completed within 1 h at the end of the rest period.

6.8.2 Humidity preconditioning

Addition:

Add the following at the end of the last paragraph:

Equipment for which a DRYING-OUT is specified (see 5.4.3.101) shall not be subjected to humidity preconditioning.

6.9.1 General

Addition:

Add the following paragraph after the note:

Bare HAZARDOUS LIVE parts and insulated wiring and connections shall be so routed and arranged that the CLEARANCES and CREEPAGE DISTANCES are not reduced below acceptable values by:

- 1) liquids, vapours or impurities condensed, accumulated or leaking inside the equipment;
- 2) contact with hot or cold parts;
- 3) mechanical stress or abrasion by sharp edges.

6.10.1 MAINS supply cords

Replacement:

Replace the third and fourth paragraphs as follows:

If a cord is likely to come into contact with hot or cold external parts of the equipment, it shall be made of suitably temperature-resistant material or, alternatively, additional protection shall be provided to prevent the cord from coming into contact with the heated or cold surface.

If the cord is detachable, both the cord and the appliance inlet shall have adequate temperature RATINGS. The cord and the appliance inlet shall have a temperature RATING above the maximum temperatures measured under NORMAL CONDITION on any part of the appliance inlet itself.

The appliance coupler shall have a mechanism which prevents the cord of a lower temperature RATING from being inserted into the appliance inlet featuring a higher temperature RATING.

NOTE – An appliance coupler in compliance with IEC 60320 (all parts), such as that with style C15 and C16, or C21 and C22 for hot conditions, or C15A and C16A for super hot conditions is an example of a required mechanism.

7 Protection against mechanical HAZARDS

This clause of Part 1 is applicable except as follows:

7.3.5.1 Gap limitations between moving parts – Access normally allowed

Addition:

Add the following paragraphs after the first paragraph:

If the width of the gap can decrease from a value larger than the minimum gap specified in Table 13 for that body part to a value smaller than the minimum gap in NORMAL CONDITION and

SINGLE FAULT CONDITION, for example the door and/or locking device of TEST CHAMBERS or INCUBATORS, including WALK-IN EQUIPMENT (see Annex BB), the door or locking device shall be provided with a handle or shaft so that hand, wrist, fist and fingers are kept away from the moving gap during the operation of closing and/or locking the door. If twin doors are used, they may be so constructed that closing and/or locking of one door is possible only after the other door is closed, where the HAZARD of crushing is minimized.

Additional warning marking is necessary in proximity to the moving gap and where the locking device is located by using symbol 106 of Table 1.

Addition:

Add the following new subclause:

7.3.101 Warning markings for MECHANICAL MOVEMENT

The MECHANICAL MOVEMENT area in a SHAKER or COMBINED TEST CHAMBER shall be marked with symbol 14 of Table 1 or the applicable symbol 122 to 127 of Table AA.1.

The SPECIMEN holder of the MECHANICAL MOVEMENT shall be marked with symbol 14 of Table 1.

Conformity is checked by inspection.

7.4 Stability

Addition:

Add the following new subclauses:

7.4.101 Movement during operation

The equipment shall not change position during NORMAL USE.

Conformity is checked by inspection and test.

The equipment shall be operated according to the manufacturer's specifications, at the setting and load condition representing the worst case normal operating condition. Operating time is 10 min, or one operation cycle, whichever is shorter.

Movement shall be limited either by design, or by fastening to the mounting surface, or a combination of both, so that no part of the equipment moves outside a clearance envelope extending 5 mm, or less if stated by the manufacturer, in any direction from the outermost parts of the equipment in its original position.

During the tests the equipment shall remain in position. Any flexible tubing or other mechanical connection between the equipment and the APPLICATION SYSTEM shall withstand stress which could cause HAZARD.

For equipment intended for long-term continuous operation, the maximum excursion and test period is to be determined through the RISK assessment of Clause 17.

7.4.102 Removable SPECIMEN holder for MECHANICAL MOVEMENT

If a HAZARD, such as abnormal noise or mechanical injury from the imbalance or uncoupling of the SPECIMEN holder for MECHANICAL MOVEMENT during NORMAL USE could result during its removal or reengagement, the removable SPECIMEN holder shall be marked with an appropriate warning symbol in close proximity to the handles of the holder and an explanation shall be included in the documentation.

Conformity is checked by inspection.

7.5 Provisions for lifting and carrying

7.5.1 General

Addition:

Add the following text after the first paragraph:

Where the physical construction is such that parts which are not designed to be used as handles, grips, lifting devices or supporting parts could be mistaken as such, they shall:

- a) have a strength identical to or higher than that required for normal lifting devices or supporting parts, or
- b) have a warning marking (see 5.2) located adjacent to the relevant part(s), indicating that they shall not be used as handles, grips, lifting devices or supporting parts. Symbol 14 of Table 1 and additional explanations in the documentation are considered to meet the requirements.

Replacement:

Replace the conformity statement as follows:

Conformity is checked by inspection and as specified in 7.5.2 and 7.5.3.

8 Resistance to mechanical stresses

This clause of Part 1 is applicable except as follows:

8.1 General

Replacement:

Replace the text of item 3) by the following:

- 3) except for FIXED EQUIPMENT, for equipment with a mass over 100 kg, or for equipment whose size and weight make unintentional movement unlikely and which is not moved in NORMAL USE.

8.2.1 Static test

Replacement:

Replace the second paragraph by the following:

An ENCLOSURE which is non-metallic or has glass as part of its construction is operated until a steady-state condition is reached at the least favourable of the following conditions:

- a) *at maximum or minimum ambient temperature; or*
- b) *at extended maximum or minimum ambient temperature; or*
- c) *over the maximum or minimum CONTROLLED TEMPERATURE; or*
- d) *cycled between the maximum and minimum CONTROLLED TEMPERATURE range; or*
- e) *with all the lamps on and at maximum power input for radiation.*

The equipment is disconnected from the supply source before the test is performed.

8.2.2 Impact test

Replacement:

Replace the first paragraph after the Note by the following:

An ENCLOSURE which is non-metallic or has glass as part of its construction is operated until a steady-state condition is reached at the least favourable of the following conditions:

- a) at maximum or minimum ambient temperature; or*
- b) at extended maximum or minimum ambient temperature; or*
- c) over the maximum or minimum CONTROLLED TEMPERATURE; or*
- d) cycled between the maximum and minimum CONTROLLED TEMPERATURE range; or*
- e) with all the lamps on and at maximum power input for radiation.*

The equipment is disconnected from the supply source and then tested within 10 min.

9 Protection against the spread of fire

This clause of Part 1 is applicable except as follows:

9.5 Requirements for equipment containing or using FLAMMABLE LIQUIDS

Addition:

Add the following text after the first paragraph:

This subclause 9.5 applies to FLAMMABLE LIQUIDS other than FLAMMABLE REFRIGERANTS. The requirements for FLAMMABLE REFRIGERANTS are covered in 5.4.101 and 11.7.101.

Replacement:

Replace item a) and Note 1 by the following:

a) The equipment shall be so constructed that it complies with items 1), 2) and 3) as follows:

- 1) In NORMAL CONDITION and SINGLE FAULT CONDITION, the surface temperature of the FLAMMABLE LIQUID shall not exceed the FLASH POINT of the liquid being exposed to the air.
- 2) In NORMAL CONDITION and SINGLE FAULT CONDITION, the surface temperature of any RESISTANCE-HEATING DEVICE at the surface of the FLAMMABLE LIQUID and in contact with air shall not exceed $(t - 25) ^\circ\text{C}$, where t is the FIRE POINT of the liquid.
- 3) For equipment where an OPERATOR setting could expose a FLAMMABLE LIQUID to a condition where the temperatures in a) 1) or 2) could be exceeded in the case of a SINGLE FAULT CONDITION during REASONABLY FORESEEABLE MISUSE, additional measures shall be provided to protect the OPERATOR from this HAZARD.
 - For example, a LIQUID LEVEL CUT OUT that disables the RESISTANCE-HEATING DEVICE before the temperature requirements of a) 1) or 2) are exceeded is considered to comply with this requirement.
 - Consideration should be given to any scenario that can expose any permitted FLAMMABLE LIQUID to a temperature that could exceed $t_a - 100 ^\circ\text{C}$, where t_a is the AUTO IGNITION TEMPERATURE.
 - The use of a FLAMMABLE LIQUID not approved by the manufacturer for use in the equipment is not considered as an OPERATOR setting and is therefore beyond the evaluation of Clause 16.

NOTE 101 Guidance on what is considered REASONABLY FORESEEABLE MISUSE is provided in 16.1.

It is not sufficient to limit the surface temperature of the FLAMMABLE LIQUID and parts in contact with the surface solely by the temperature control system. Overtemperature protection meeting the requirements of 10.101 achieved by an independent, adjustable TEMPERATURE-LIMITING DEVICE shall be used.

NOTE 102 The surface temperature of a RESISTANCE-HEATING DEVICE used to heat a liquid can be considerably higher than the temperature of the liquid.

NOTE 103 Additional instructions for equipment intended for use with a FLAMMABLE LIQUID HEAT TRANSFER MEDIUM are detailed in 5.4.102.

Addition:

Add the following note after item c):

NOTE 104 Where FLAMMABLE LIQUID is present in the equipment, symbol 102 can be used as a warning marking.

Replacement:

Replace the first paragraph of the conformity statement by the following:

Conformity is checked by inspection, including nameplate, documentation and function of the equipment and, if necessary, by the tests and measurements of temperature as specified in 10.4 and 10.101.

10 Equipment temperature limits and resistance to heat

This clause of Part 1 is applicable except as follows:

10.1 Surface temperature limits for protection against burns

Replacement:

Replace the title by the following:

10.1 Surface temperature limits for protection against burns and frostbite

Replace the third paragraph by the following:

If easily touched heated surfaces are necessary for functional reasons, whether because they are intended to deliver heat or they are hot because of proximity to heating parts, they are permitted to exceed the values of Table 19 in NORMAL CONDITION and to exceed 105 °C in SINGLE FAULT CONDITION, provided that they are recognizable as such by appearance or function or are marked with symbol 13 of Table 1 (see 5.2). Equipment heated by its environment to temperature values exceeding the values in Table 19 in NORMAL CONDITION and 105 °C in SINGLE FAULT CONDITION need not be marked with symbol 13.

NOTE The limit for the maximum surface temperature of the housing of the discharge pipe in proximity to the MOTOR-COMPRESSOR conforming to IEC 60335-2-34 (including IEC 60335-2-34:2012, IEC 60335-2-34:2012/AMD1:2015 and IEC 60335-2-34:2012/AMD2:2016, Annex AA) is 150 °C when tested at 43 °C ambient.

If the minimum temperature of the easily touched cold surfaces exceeds the value of –30 °C, the cold surface shall be marked with symbol 101 of Table 1 to warn the OPERATOR of the HAZARD of frostbite (see 5.2). Equipment cooled by its environment to temperature values lower than –30 °C need not be marked with symbol 101.

Additionally, where the liquid temperature could be higher than +60 °C or lower than –30 °C, or where the temperature of air or gas mixture could be higher than +70 °C or lower than

–40 °C, consideration should be given to mark the following to warn against possible burn and/or frostbite HAZARDS:

- a) for movable immersion CIRCULATOR during movement for NORMAL USE, the surface of the equipment in close proximity to the wetted parts may be marked with symbol 13 and/or symbol 101.
- b) LIQUID CONNECTIONS for circulating, draining or overflowing of the HEAT TRANSFER MEDIUM may be marked with symbol 13 and/or symbol 101, and/or with the maximum and/or minimum CONTROLLED TEMPERATURES of the equipment in association with symbols 108, 111, 117 or 118.
- c) The exhaust opening may be marked with symbol 13 and/or symbol 101 and/or the maximum and/or minimum CONTROLLED TEMPERATURES of the equipment in association with symbol 121.
- d) If an enclosed CIRCULATOR is intended for a hydraulically sealed APPLICATION SYSTEM, the LIQUID CONNECTION for filling the BATH TANK or the exhaust of a PRESSURE-RELIEF DEVICE may be marked with symbol 13 and/or symbol 101 and/or the maximum and/or minimum CONTROLLED TEMPERATURES of the equipment in association with symbol 116.

Addition:

Add the following paragraph after the fourth paragraph:

For TEST CHAMBERS, INCUBATORS, and similar equipment with heating functions for high temperatures, there shall be an indication of the "ON" condition on each side of the equipment which has a door in it or has any other opening intended for loading of the SPECIMEN.

Replacement:

Replace the conformity statement with the following:

Conformity is checked by inspection and by measurement as specified in 10.4, and by inspection of barriers to check that protection against accidentally touching surfaces exceeding temperatures above the values of Table 19 is appropriate, and that they cannot be removed without the aid of a TOOL.

10.2 Temperatures of windings

Addition:

Add the following text and table after Table 20:

Conformity for MOTOR-COMPRESSORS is checked by measurement as specified in 10.4, in NORMAL CONDITION and in the applicable SINGLE FAULT CONDITIONS of 4.4.2.10, 4.4.2.101 and also in any other SINGLE FAULT CONDITIONS that could cause a HAZARD as a result of excessive temperature or pressure. The temperature limits for MOTOR-COMPRESSORS are defined in Table 102. The pressures are recorded for use in accordance with 11.7.2.

Table 102 – Maximum temperatures for MOTOR-COMPRESSORS

Part of the MOTOR-COMPRESSOR	Temperature (°C)
Windings with	
– synthetic insulation	140
– cellulosic insulation or the like	130
Housing	150

10.4 Conduct of temperature tests

10.4.1 General

Replacement:

Replace the text with the following:

Maximum temperature is determined by measuring the temperature rise under reference test conditions defined by 4.3.1 of this document. Linear extrapolation is not permitted. Unless a particular SINGLE FAULT CONDITION specifies otherwise, the NORMAL USE of the equipment as defined in 4.3.2 of this document and the manufacturer's instructions concerning ventilation, cooling liquid, limits for intermittent use, etc., are followed. Any cooling liquid shall be at the highest RATED temperature. Operating pressures shall be monitored and recorded during all the temperature tests for use in the evaluation of the PS.

Alternatively, temperature measurements are made at the least favourable ambient temperature within the RATED ambient temperature range of the equipment if this represents a less favourable condition. Measures are taken to eliminate errors caused by the method of achieving the test ambient temperature (e.g. suitable baffling or ENCLOSURE if the test is conducted in an environmental testing TEST CHAMBER and the forced air movements would cool the exterior of the equipment).

When measuring temperatures and pressures for REFRIGERATING SYSTEMS, the tests shall be started from a SOAKED TEMPERATURE CONDITION when all pressures have been fully equalized. Tests at the extremes of the input voltage ($\pm 10\%$) shall start under these voltage conditions and achieve a stable state but need not start from a SOAKED TEMPERATURE CONDITION. At the termination of the test, the monitoring shall continue after the equipment is switched off until the pressures from each REFRIGERANT stage have equalized or clearly demonstrate that maximum values have been reached.

During the test, protective devices other than self-resetting thermal motor-protectors for MOTOR-COMPRESSORS shall not operate. When steady conditions have been established, thermal motor-protectors for MOTOR-COMPRESSORS shall not operate.

Unless thermocouples are embedded in the windings of the MOTOR-COMPRESSOR, winding temperatures shall be taken using the change of resistance method in accordance with Annex E of IEC 60950-1:2005, and should be recorded at initial conditions and at steady-state. All other temperature and pressure measurements shall be taken continuously and the maximum temperatures and pressures recorded.

For MOTOR-COMPRESSORS conforming with IEC 60335-2-34 (including IEC 60335-2-34:2012, IEC 60335-2-34:2012/AMD1:2015 and IEC 60335-2-34:2012/AMD2:2016, Annex AA), the temperatures of the following parts are not measured:

- MOTOR-COMPRESSOR housing;
- MOTOR-COMPRESSOR windings and other accessories, such as parts for protection, start-up, and any other parts that are tested with MOTOR-COMPRESSORS in accordance with

IEC 60335-2-34 (including IEC 60335-2-34:2012, IEC 60335-2-34:2012/AMD1:2015 and IEC 60335-2-34:2012/AMD2:2016, Annex AA).

For MOTOR-COMPRESSORS not conforming with IEC 60335-2-34 (including IEC 60335-2-34:2012, IEC 60335-2-34:2012/AMD1:2015 and IEC 60335-2-34:2012/AMD2:2016, Annex AA), the temperatures of the following parts shall not exceed the limits as specified in Table 102:

- *MOTOR-COMPRESSOR housing;*
- *MOTOR-COMPRESSOR windings.*

Addition:

Add the following new subclauses:

10.101 Overtemperature protection

When a single fault in the equipment could lead to a HAZARD from overheating of the equipment or material being processed, a non-self-resetting TEMPERATURE-LIMITING DEVICE or system meeting the requirements of 14.3 shall de-energize the RESISTANCE-HEATING DEVICE and any other parts which could cause a HAZARD.

If an insufficient quantity of liquid HEAT TRANSFER MEDIUM could cause a HAZARD, a self-resetting or non-self-resetting LIQUID LEVEL CUT OUT shall de-energize the RESISTANCE-HEATING DEVICE and any other parts which could cause a HAZARD. When the temperature of a surface in direct contact with the FLAMMABLE LIQUID HEAT TRANSFER MEDIUM exceeds $t_a - 100\text{ °C}$, where t_a = AUTO IGNITION TEMPERATURE, the LIQUID LEVEL CUT OUT shall operate before this surface can be exposed to air.

If a HAZARD could result from an incorrect immersion depth, movable immersion CIRCULATORS, when combined with either an open BATH TANK or a refrigerating BATH resulting in a BATH or CIRCULATOR, shall be marked with the maximum and minimum depth of immersion. These markings may be horizontal lines if additional explanation is included in the documentation.

For equipment designed to contain FLAMMABLE LIQUIDS, either for treatment or for heat-transfer, TEMPERATURE-LIMITING DEVICES or systems shall ensure, when set as directed in the manufacturer's instructions, that the temperature of the liquid shall not exceed the value as specified in 9.5 a) in NORMAL USE or SINGLE FAULT CONDITION.

The equipment as a whole, or the relevant parts, shall be de-energized by one of the following methods:

- a) For single-phase equipment, the proposed circuit and physical construction shall be examined to identify possible single faults. The TEMPERATURE-LIMITING DEVICE shall be placed in the pole of the supply that provides the better protection from single faults that could defeat the overtemperature protection in the event of a subsequent failure of the temperature control system. A device which isolates both phase and neutral conductors at the same time can provide double fault protection (depending on application) and should be considered if the residual RISK is unacceptable.

Conformity is checked by inspection of the circuit diagram, the data sheet for the TEMPERATURE-LIMITING DEVICE, and the method in which it is installed in the equipment, and, if necessary, by the tests specified in 14.3.

- b) For polyphase equipment, either by one single device or a system disconnecting all phases.

Consideration shall be given to the following:

- In equipment designed for the cooling and/or heating of materials, HAZARDS can arise from the overheating of materials being processed or overheating of the liquid HEAT TRANSFER

MEDIUM as well as from the overheating of parts of the equipment itself. For this reason a higher level of safety may need to be provided in case of a SINGLE FAULT CONDITION in the equipment.

- In some cases, a fall in the CONTROLLED TEMPERATURE of a heated medium (for example liquid in a BATH or air in an oven or heating cabinet) could cause a HAZARD. If this could occur as a result of the operation of a TEMPERATURE-LIMITING DEVICE, an additional independent system may be used to prevent the CONTROLLED TEMPERATURE from falling to a hazardous level.

NOTE NORMAL USE (which is use in accordance with the manufacturer's instructions) includes the correct setting of any adjustable TEMPERATURE-LIMITING DEVICE. If the OPERATOR is instructed to change the set point of the TEMPERATURE-LIMITING DEVICE (including providing the TOOL if required) then the incorrect setting of the TEMPERATURE-LIMITING DEVICE can be considered REASONABLY FORESEEABLE MISUSE. Refer to 16.1 for additional guidance.

TEMPERATURE-LIMITING DEVICES necessary for safety shall be separate from any temperature controller. This applies not only to the temperature sensing means but also to all disconnecting devices in the circuits to be de-energized. Whether operated by temperature, pressure, liquid level, airflow or other means, they shall meet the requirements of 14.3.

Adjustable TEMPERATURE-LIMITING DEVICES and system shall be adjustable only with the aid of a TOOL or similar means that prevents unintended adjustment.

Conformity is checked by inspection and during the fault tests specified in 4.4.2.10, 4.4.2.11 and as applicable, the tests in 4.4.2.101 to 4.4.2.106.

10.102 Restarting after interruption of cooling and/or heating

According to applications, a HAZARD could arise either by re-starting or by not re-starting after interruption of the cooling and/or heating as result of the termination of the circulating or agitating in a BATH or CIRCULATOR and in an oven or TEST CHAMBER. Equipment shall be incorporated with the appropriate means to re-start or not re-start, and instructions shall specify whether the equipment will re-start or not re-start, both in the case of MAINS interruption and in the case of a SINGLE FAULT CONDITION.

NOTE In some cases, it can be appropriate for an audible or visible signal to warn that an interruption has occurred.

Conformity is checked by inspection and test.

11 Protection against HAZARDS from fluids and solid foreign objects

This clause of Part 1 is applicable except as follows:

11.1 General

Addition:

Add the following paragraph and Note 101 after the conformity statement:

Equipment intended to be connected to the water supply shall be constructed to prevent backsiphonage of non-potable water into the water supply.

NOTE 101 IEC 61770 gives requirements for preventing backsiphonage of non-potable water into the water supply and tests.

Conformity is checked by inspection.

11.3 Spillage

Addition:

Add the following text after the conformity statement:

The construction of a draining valve, nozzle and any other similar device shall be designed to prevent them from being opened or pulled out unintentionally.

Conformity is checked by inspection.

11.4 Overflow

Replacement:

Replace the title and text of 11.4 with the following:

11.4 Overflow and low level

Liquid overflowing from any container in the equipment which can be overfilled or overflowed, whether by the OPERATOR or for functional reasons as part of equipment operation, shall not cause a HAZARD during NORMAL USE or in SINGLE FAULT CONDITION, for example, as a result of the wetting of insulation or of internal uninsulated parts that are HAZARDOUS LIVE.

Equipment likely to be moved while a vessel is full of liquid shall be protected against liquid surging out of the vessel.

Equipment containing liquid, whether as the HEAT TRANSFER MEDIUM or as a result of treatment, experiencing expansion and contraction, evaporation, spray, rain or dripping when being heated, cooled, atomized, irrigated or condensed shall be provided with means to protect against any HAZARD associated with the overflow or low level during NORMAL USE or in SINGLE FAULT CONDITION.

Conformity is checked by inspection and by carrying out each of the following treatments and tests, if applicable. Immediately after the treatment, the CLEARANCE and solid insulation shall pass the voltage tests of 6.8 (without humidity preconditioning) applicable to the type of insulation (see 6.7), and ACCESSIBLE parts shall not exceed the limits of 6.3.1 for NORMAL USE and 6.3.2 under SINGLE FAULT CONDITION.

For BATHS, CIRCULATORS and similar equipment incorporating a liquid vessel, operate the equipment as follows:

Fill the BATH TANK or any other liquid vessel of the equipment to its maximum level with water unless otherwise specified, following the instructions of the manufacturer.

a) Spillage from overflow

The filling is continued for an additional amount equal to 20 % of the vessel capacity, but not less than 0,25 l, or for 1 min after the first evidence of overflow. Where no spillage occurs due to the function of the LIQUID CONNECTION for overflow that prevents such spillage, the filling is continued for a further amount equal to 30 % of the vessel capacity, or for 5 min following the overflow through the LIQUID CONNECTION.

The LIQUID CONNECTION for overflow, if so equipped, shall be connected and fitted as instructed in the manual. If not specified by the manufacturer, use a filling rate of 10 l/min.

Take the value resulting from the least favourable situation. There shall be no wetting of conductive live parts.

For a remotely controlled automatic refill system, a RISK assessment shall be carried out according to Clause 17.

b) *Splash from low level*

Drain the BATH TANK or any other liquid vessel of the equipment to its minimum level or just prior to the evidence of the triggering of the low LIQUID LEVEL CUT OUT, if so equipped, while keeping the equipment running and the functional assembly relying on appropriate liquid level operating, for example, by ensuring that the CIRCULATING PUMP and HUMIDIFIER are working.

There shall be no wetting of conductive live parts.

c) *Spillage from expansion and contraction*

Use the HEAT TRANSFER MEDIUM with the widest CONTROLLED TEMPERATURE range and highest coefficient of expansion applicable for the equipment as instructed by the manufacturer.

Set the CONTROLLED TEMPERATURE of the equipment at ambient and keep the CIRCULATING PUMP running until the CONTROLLED TEMPERATURE is stabilized, and:

- 1) set the CONTROLLED TEMPERATURE of the equipment to its minimum, then to its maximum applicable for the same liquid, and finally to ambient. Change the setting only if the CONTROLLED TEMPERATURE is stabilized at its setting or there is no evidence of further significant changing. Refill the BATH TANK if necessary with the same liquid to its maximum level for NORMAL USE prior to subsequent tests;*
- 2) set the CONTROLLED TEMPERATURE of the equipment to its maximum, then to its minimum, and finally to ambient. Change the setting only if the CONTROLLED TEMPERATURE is stabilized at its setting or there is no evidence of further significant changing. Refill the BATH TANK if necessary with the same liquid to its maximum level for NORMAL USE prior to subsequent tests;*
- 3) program the setting for the CONTROLLED TEMPERATURES of the equipment to its maximum, minimum and time for the change that maximum difference of the CONTROLLED TEMPERATURE changing is possible. Run the program with two repetitions or until no evidence of a more unfavourable situation is expected.*

d) *Surging from movement*

Remove the plug from the power supply, and operate the equipment as follows:

- 1) For equipment with castors, or provided with accessory trolleys specified by the manufacturer:*
 - The equipment is moved in the forward direction on a smooth and solid surface at a speed of $0,5 \text{ m/s} \pm 0,1 \text{ m/s}$ for 2 m, and then with one of the castors against a solid vertical plane obstacle. The obstacle shall have a rectangular cross section with a height of $10 \text{ mm} \pm 0,5 \text{ mm}$ and a width of at least 80 mm with a radius of $2 \text{ mm} \pm 0,1 \text{ mm}$ at the top edges. Unless the direction of movement is mechanically restricted or explicitly specified by the manufacturer, the longest side of the equipment should be aligned with the direction of travel.*
 - Equipment intended to be moved when the fluid-containing vessel is emptied shall be filled to 50 % of the maximum level.*
 - Operate the equipment with the obstacle against different castors, and repeat each test three times.*

Take the value resulting from the least favourable situation. There shall be no wetting of conductive live parts, or if a HAZARD could result, no wetting of the OPERATOR's grips or handles.

A BATH TANK or any other liquid vessel incapable of sealed operation is left open. Equipment with fully enclosed fluid containing vessels is exempted from this test.

2) For equipment with lifting devices:

- equipment up to 18 kg, including liquid, is subjected to a cycling 10° tilt-test across the short side of the equipment, or*
- equipment over 18 kg, including liquid, is subjected to a cycling 5° tilt-test across the long side of the equipment.*

In either case, the equipment is subjected to 3 tilt-test cycles, where one cycle consists of the positions flat, tilted left, flat, tilted right, cycled within 10 s.

There shall be no wetting of conductive live parts, and if a HAZARD could result, no spillage outside the equipment or wetting of the OPERATOR's grips or handles.

A BATH TANK or any other liquid vessel incapable of sealed operation is left open. Equipment with fully enclosed fluid containing vessels is exempted from this test.

e) Spillage from condensate and simulated spraying, irrigating or raining

For equipment incorporating a drip pan, operate the equipment as follows:

Block the outlet of the drip pan. Fill the pan with water carefully to the brim without splashing. The drip pan is then subjected to a continuous overflow, the rate of which is adjusted to approximately 17 cm³/s, or to its maximum RATING specified by the manufacturer. Apply an airflow of 1 m³/s if the overflow is influenced by the airflow of the cooling or CIRCULATING FAN(S). The test is continued for a period of 30 min, or until water drains from the equipment.

Equipment incorporating a defrosting device is subjected to a complete cycle of defrosting under the least favourable conditions.

Equipment incorporating a spraying, irrigating or raining device is subjected to a complete cycle of spraying, irrigating or raining under the most unfavourable conditions.

Addition:

Add the following new subclauses:

11.4.101 Salt mist, thawing, condensate and spray

Where a HAZARD could result by direct exposure to the spray, the saturated compressed-air for salt-solution atomizing of the salt-spray-corrosion TEST CHAMBER shall be designed to be interlocked by the mechanism of the cover, so that it stops automatically or so that it will not start with the cover opened.

It is permissible for the interlock detailed above to be overridden where necessary for operation or maintenance and when spray is desired with the cover opened, only where activation of the spray is controlled by a device that needs to be continuously held in the active state by the OPERATOR and the following warning symbol and statement is placed on the equipment:

Hazardous chemicals, use protective respirator, face mask, coveralls or gloves!

Conformity is checked by inspection and evaluation of the interlock according to Clause 15 if relied upon to mitigate the RISK.

The refrigerating subassembly and piping, where necessary for safety, shall be properly insulated and protected against occurrence of condensate or accumulation of frost for NORMAL USE. Salt mist, thawing, condensing and spraying water shall be collected and discharged, ensuring that no leakage, spillage or overflow occurs.

Conformity is checked by inspection. In case of doubt, the CLEARANCES and solid insulation shall pass the voltage tests of 6.8 (without humidity preconditioning) applicable to the type of insulation (see 6.7) and ACCESSIBLE parts shall not exceed the limits of 6.3.1.

11.4.102 HAZARDS from liquids in relation to the SPECIMEN and APPLICATION SYSTEM

Fixing devices, tube racks or insulated vessels, and flexible tubing and clamps, if necessary for safety, shall be provided with the equipment to fix the SPECIMENS or for connection to the APPLICATION SYSTEM to protect them from coming into contact with the HEAT TRANSFER MEDIUM.

Where a HAZARD could be caused by excessive torque or pressure applied to a high-viscosity liquid HEAT TRANSFER MEDIUM or to a pressure-sensitive APPLICATION SYSTEM, for example through rupture of a jacketed glass reactor, a CIRCULATOR with a discharge pressure exceeding 0,08 MPa shall be incorporated with pressure-indicating and adjusting devices. A safety device can be integrated to interrupt the CIRCULATING PUMP and initiate an alarm signal if the torque or pressure rises above a pre-set value.

According to the applications, a HAZARD could arise either by re-starting or by not re-starting after interruption of the circulation of the liquid. Equipment shall be incorporated with the appropriate means to re-start or not re-start, and instructions shall specify whether equipment will re-start or not re-start, both in the case of MAINS or mechanical interruption and in the case of a SINGLE FAULT CONDITION.

Conformity is checked by inspection and in case of doubt by measurement of pressure.

11.4.103 HAZARDS from liquids in relation to the SHAKER

Safety devices or means shall be provided with the SHAKER to protect against HAZARDS from splash and/or spillage of the liquids, accumulation of released volatile or hazardous substances, or condensation of the volatile substances. The safety device shall be independent of the controllers for MECHANICAL MOVEMENT and/or the temperature, humidity.

Conformity is checked by inspection.

11.4.104 Construction and warning markings related to manual filling or draining

Equipment incorporating a BATH TANK or other liquid container intended for manual filling or incorporating a reservoir for collecting condensate that requires manual draining, if the liquid level is not visible in construction or location, shall be equipped with a clearly visible liquid level indicator. Alternatively, if the liquid level indicator cannot be made available, a warning marking shall be applied and clearly visible in close proximity to the LIQUID CONNECTION for filling or draining. Additional explanations including instructions for operation and maintenance requirements for the warning marking shall be included in the documentation.

Conformity is checked by inspection.

11.4.105 Movable immersion CIRCULATOR

If HAZARDS could arise from liquid penetration or spillage when the movable immersion CIRCULATOR is removed from the BATH TANK and placed horizontally or upside down or during movement for NORMAL USE, it shall be marked with symbol 12 or symbol 14 of Table 1 to warn of electric or liquid HAZARD.

Conformity is checked by inspection.

11.4.106 Removable SPECIMEN holder for MECHANICAL MOVEMENT

If a HAZARD, such as spillage or overflow of the liquid, could result during the removal or re-insertion, the removable SPECIMEN holder for MECHANICAL MOVEMENT shall be marked with an appropriate warning symbol and text in close proximity to the handles of the holder, and an explanation shall be included in the documentation.

Conformity is checked by inspection or by operation in accordance with instructions.

11.7.1 Maximum pressure

Addition:

Add the following after the conformity statement:

The maximum pressure to which a part of the REFRIGERATING SYSTEM can be subjected under NORMAL CONDITION or SINGLE FAULT CONDITION shall not exceed the RATED MAXIMUM ALLOWABLE PRESSURE for the part. The RATED MAXIMUM ALLOWABLE PRESSURE of a component is determined either by its RATING if certified to the component requirements of 14.101 or by its design if the parts can pass the tests of 11.7.2.

The MAXIMUM ALLOWABLE PRESSURE (PS) of REFRIGERATING SYSTEMS shall be determined by test or by applying the saturated REFRIGERANT pressures at the minimum specified temperatures given in Table 103. When saturated REFRIGERANT pressures are used to define the PS, the manufacturer is exempted from the requirement to record the pressures during tests for NORMAL USE and under SINGLE FAULT CONDITIONS. If the start-to-discharge pressure of a PRESSURE RELIEF DEVICE or the set pressure of a ruptured member used in the REFRIGERATING SYSTEM is less than the SATURATED-VAPOUR PRESSURE in Table 103, it can be used to limit the PS for that system. The value of the PS when determined by test shall be considered to be the highest of the following:

- the maximum pressure developed during the temperature test as defined in 10.4;
- the maximum pressure developed during the abnormal test to simulate the failure of the controlled environment in accordance with 4.3.2.114, if applicable;
- the maximum pressure developed during the test in SINGLE FAULT CONDITION for cooling as specified in 4.4.2.10;
- the maximum pressure developed during the temperature test for transportation and storage as defined in 11.7.102.

NOTE 101 For a single REFRIGERATING SYSTEM, the pressure can be separated into two sections, the HIGH-PRESSURE SIDE and LOW-PRESSURE SIDE of each MOTOR-COMPRESSOR; the PS value can be different for each HIGH-PRESSURE SIDE and LOW-PRESSURE SIDE.

NOTE 102 It is possible that equipment meeting the requirements of 11.7 will not be accepted as conforming to national requirements relating to high pressures. There are notes applied to the relevant requirements which detail the modification of these requirements in order to be accepted as evidence of conformity with national regulations in the USA, in Canada, and in some other countries.

Table 103 – Minimum temperature for the determination of SATURATED-VAPOUR PRESSURE of the REFRIGERANT

Ambient conditions	≤ 43 °C	≤ 55 °C
HIGH-PRESSURE SIDE with air-cooled CONDENSER	63 °C	67 °C
HIGH-PRESSURE SIDE with water-cooled CONDENSER	Maximum leaving water temperature + 8 °C	
HIGH-PRESSURE SIDE with evaporative CONDENSER in a CASCADE SYSTEM	43 °C	55 °C
LOW-PRESSURE SIDE with heat exchanger exposed to the outdoor ambient temperature	43 °C	55 °C
LOW-PRESSURE SIDE with heat exchanger exposed to the indoor ambient temperature	38 °C	38 °C
NOTE 1 For the HIGH-PRESSURE SIDE, the specified temperatures are considered the maximum which will occur during operation. These temperatures are higher than those during the off cycle of the MOTOR-COMPRESSOR. For the LOW-PRESSURE SIDE and/or intermediate pressure side, it is sufficient to base the calculation of pressure on the expected temperature during the off cycle of the MOTOR-COMPRESSOR. These temperatures are minimum temperatures and thus determine that the system will not be designed for a MAXIMUM ALLOWABLE PRESSURE lower than the REFRIGERANT SATURATED-VAPOUR PRESSURE corresponding to these minimum temperatures. NOTE 2 The use of specified temperatures does not always result in REFRIGERANT SATURATED-VAPOUR PRESSURE within the system, for example a limited-charge REFRIGERATING SYSTEM or a system working at or above critical temperature, CO₂ in particular. NOTE 3 For zeotropic blends, the MAXIMUM ALLOWABLE PRESSURE (PS) is the pressure at the bubble point.		

Conformity is checked by inspection of the RATINGS of the parts and, if necessary, by measuring the pressures.

11.7.2 Leakage and rupture at high pressure

Addition:

Add the following new subclauses:

11.7.2.101 Leakage and rupture of REFRIGERATING SYSTEMS

11.7.2.101.1 General

REFRIGERANT-containing parts of a REFRIGERATING SYSTEM shall not cause a HAZARD through rupture or leakage. The specific requirements for REFRIGERATING SYSTEMS using FLAMMABLE REFRIGERANT or FLAMMABLE REFRIGERANT blends are addressed in 11.7.101.

For components subject to the pressure at the HIGH-PRESSURE SIDE or LOW-PRESSURE SIDE of the REFRIGERATING SYSTEM, the structural strength of the fluid-containing parts shall comply with three times the PS as defined in 11.7.1 for the HIGH-PRESSURE SIDE or LOW-PRESSURE SIDE.

Conformity is checked by inspection of the RATINGS of the components exposed to this pressure and, if a HAZARD could arise, by the pressure test in 11.7.2.101.2 and 11.7.2.101.3. Components that are certified to the component requirements in 14.101 and are used within their RATINGS (component pressure RATING $\geq$ PS) are deemed to comply with this requirement without test.

NOTE 1 For evidence of conformity with national regulations in the USA, in Canada, and in some other countries, the structural strength of components is identical but the design RATING of the component is different based on the safety margin required in the national regulations. For example, in the USA, the design RATING for a component complying with the ASME boiler code is 1/5 of the structural strength of the component.

NOTE 2 In conjunction with NOTE 1, the minimum structural strength RATING of REFRIGERANT-containing components in the USA and Canada is 5 times the PS measured during normal pressure tests and 3 times the PS measured during abnormal pressure tests, where PS is derived from tests in 10.4 for the HIGH-PRESSURE SIDE or LOW-PRESSURE SIDE and the test in 4.4.2.10 for the HIGH-PRESSURE SIDE only. Note the fact of these certification differences during selection of certified components from North America based on the testing conducted in this document.

11.7.2.101.2 Pressure test

The pressure of the component or assembly (equipment under test (EUT)) is raised gradually, by air or non-hazardous gas or via a hydrostatic pressure test, to the specified test value and is held at that value for 1 min. If the continuously CONTROLLED TEMPERATURE for the EUT is less than or equal to 125 °C for copper or aluminium, or 200 °C for steel, the test temperature of the EUT during this test shall be at least 20 °C. If the continuously CONTROLLED TEMPERATURE for the EUT exceeds 125 °C for copper or aluminium, or 200 °C for steel, the test temperature of the EUT during this test shall be at least 150 °C for copper or aluminium and 260 °C for steel. For other materials or higher CONTROLLED TEMPERATURES, the effects of temperature on the material fatigue characteristics shall be evaluated.

The EUT is considered to comply with the requirements of 11.7.2.101 if it can withstand the pressure test without rupture. If the EUT does not comply, then an alternative method to demonstrate compliance is to subject the EUT to the test in 11.7.2.101.3.

11.7.2.101.3 Fatigue test

If the continuously CONTROLLED TEMPERATURE of the EUT exceeds 125 °C for copper or aluminium, or 200 °C for steel, the fatigue test temperature of the parts or assemblies that are at these CONTROLLED TEMPERATURES, shall be at least 10 K above the continuously CONTROLLED TEMPERATURE. The static test pressure shall be increased by the ratio of the allowable stress of the material at ambient temperature to that at the highest continuously CONTROLLED TEMPERATURE. For other materials, the effects of the CONTROLLED TEMPERATURE on the fatigue characteristics shall be evaluated to determine the test conditions.

Three test samples shall be filled with fluid, and shall be connected to a pressure-driving source. The pressure shall be raised and lowered between the upper and lower cyclic values at a rate specified by the manufacturer for a total number of 250 000 cycles. The entire specified pressure excursion shall occur during each cycle.

The following test pressures shall be applied:

For safety purposes, it is suggested that a non-compressible fluid be used.

- For components at the LOW-PRESSURE SIDE, the PS for the LOW-PRESSURE SIDE shall be applied for the first cycle. For components at the HIGH-PRESSURE SIDE, the PS for the HIGH-PRESSURE SIDE shall be applied for the first cycle.

The pressure for the test cycles shall be as follows:

- The upper pressure value shall not be less than 0,7 times the PS and the lower pressure value shall not be greater than 0,7 times the PS. The upper pressure shall be 0,9 times the PS, for water-cooled condensers.
- For the final test cycle, the test pressure shall be increased to 1,4 times the PS ($2 \times 0,7 \times PS$). The pressure shall be 1,8 times the PS ($2 \times 0,9 \times PS$), for water-cooled CONDENSERS.

The component shall not rupture, burst or leak during this test.

A strength pressure test at 2 times the PS is to be performed on three samples other than the samples used for the fatigue test.

The component shall not rupture, burst or leak during this test.

11.7.3 Leakage from low-pressure parts

Addition:

Add the following text after the conformity statement:

For REFRIGERATING SYSTEMS the requirements of 11.7.2 address the low-pressure leakage evaluation.

Addition:

Add the following new subclauses:

11.7.101 Additional requirements for REFRIGERATING SYSTEMS that use FLAMMABLE REFRIGERANT

11.7.101.1 General

This document addresses the requirements for REFRIGERATING SYSTEMS which use FLAMMABLE REFRIGERANT when the amount of REFRIGERANT is limited to a maximum of 150 g in each separate REFRIGERANT circuit. For equipment that uses a REFRIGERANT charge of FLAMMABLE REFRIGERANT that exceeds this amount, additional requirements shall apply.

NOTE ISO 5149-1 or EN 378 (all parts) are standards that address the requirements for REFRIGERATING SYSTEMS that utilize more than 150 g of FLAMMABLE REFRIGERANT and can be used to identify what the additional requirements can be.

11.7.101.2 Protected REFRIGERATING SYSTEM

Equipment with a protected REFRIGERATING SYSTEM is that:

- without any part of the REFRIGERATING SYSTEM inside an OPERATOR access compartment;

- where any part of the REFRIGERATING SYSTEM which is located inside an OPERATOR access compartment is constructed so that the REFRIGERANT is contained within an ENCLOSURE with at least two layers of metallic materials separating the REFRIGERANT from the OPERATOR access compartment, each layer having a thickness of at least 0,1 mm. The ENCLOSURE has no joints other than the bonded seams of the EVAPORATOR where the bonded seam has a width of at least 6 mm;
- where any part of the REFRIGERATING SYSTEM which is located inside an OPERATOR access compartment has the REFRIGERANT contained in an ENCLOSURE which itself is contained within a separate protective ENCLOSURE. If leakage from the containing ENCLOSURE occurs, the leaked REFRIGERANT is contained within the protective ENCLOSURE and the REFRIGERATING SYSTEM will not function as in NORMAL USE. The protective ENCLOSURE shall also withstand the test of 11.7.2.101. No critical point in the protective ENCLOSURE shall be located within the OPERATOR access compartment.

Separate compartments with a common air circuit are considered to be a single compartment.

Equipment with a protected REFRIGERATING SYSTEM and which uses FLAMMABLE REFRIGERANT shall be so constructed as to avoid any fire or explosion HAZARD in the event of leakage of the REFRIGERANT from the REFRIGERATING SYSTEM.

Separate components such as thermostats which contain less than 0,5 g of FLAMMABLE REFRIGERANT are not considered to cause a fire or explosion HAZARD in the event of a leakage from the component itself.

For equipment with a protected REFRIGERATING SYSTEM, no additional requirements apply to electrical components located inside OPERATOR access compartments.

Equipment with a protected REFRIGERATING SYSTEM which, when tested, is found not to comply with the requirements specified for a protected REFRIGERATING SYSTEM, may be considered as having an unprotected REFRIGERATING SYSTEM if it is tested in accordance with 11.7.101.5 and found to comply with the requirement for an unprotected REFRIGERATING SYSTEM.

Compliance is checked by inspection and by the tests of 11.7.101.3 and 11.7.101.4.

11.7.101.3 Leakage test for FLAMMABLE REFRIGERANT

Critical points are only considered to be the interconnecting joints between parts of the REFRIGERANT circuit, including the gasket of a semi-hermetic MOTOR-COMPRESSOR. Welded telescopic joints of the MOTOR-COMPRESSOR, the welding of the pipes through the compressor housing and the welding of the fusite are not considered critical points.

To find the most critical point of the REFRIGERATING SYSTEM, it can be necessary to perform more than one test.

The method for simulating a leakage is to inject the REFRIGERANT vapour through a capillary tube at the critical point. The capillary tube shall have a bore of 0,7 mm $\pm$ 0,05 mm and a length between 2 m and 3 m.

Care should be taken that the installation of the capillary tube does not unduly influence the results of the test and that foreign material does not enter the capillary tube during insulation or assembly for the test. The capillary tube may need to be positioned before the equipment is insulated.

During this test the equipment is tested with doors and lids closed, and is switched off or operated under NORMAL CONDITION at RATED voltage, whichever gives the more unfavourable result.

During a test in which the equipment is operated, gas injection is started at the same time as the equipment is first switched on.

The quantity of REFRIGERANT of the type indicated by the manufacturer to be injected is equal to 80 % of the nominal charge of the REFRIGERANT $\pm 1,5$ g or the maximum that can be injected in 1 h, whichever is the smaller.

The quantity injected is taken from the vapour side of a gas bottle which shall contain enough liquid REFRIGERANT to ensure that, at the end of the test, there is still liquid REFRIGERANT left in the bottle.

If a REFRIGERANT blend can fractionate, the test is performed using the fraction that has the smallest value of the LOWER EXPLOSIVE LIMIT.

The gas bottle is kept at a temperature of:

- a) 32 °C $\pm$ 2 °C for leakage simulation on the LOW-PRESSURE SIDE;*
- b) 70 °C $\pm$ 2 °C for leakage simulation on the HIGH-PRESSURE SIDE.*

The quantity of gas injected should preferably be measured by weighing the bottle.

The concentration of leaked REFRIGERANT is measured at least every 30 s from the beginning of the test and for at least 1 h after injection of the gas has stopped, inside and outside OPERATOR ACCESSIBLE areas, as close as possible to the electrical components which, during NORMAL USE or abnormal operation, produce sparks or arcs.

The concentration is not measured close to:

- non-self-resetting protective devices necessary for compliance with single fault testing under 4.4 even if they produce arcs or sparks during operation;*
- intentionally weak parts that become permanently open-circuited during the single fault testing under 4.4 even if they produce arcs or sparks during operation;*
- an electrical device that has been tested and found to comply with at least the requirements in Annex EE.*

The instrument used for monitoring gas concentrations (such as those which use infrared sensing techniques) should have a fast response, typically 2 s to 3 s and not unduly influence the result of the test.

If gas chromatography is to be used, the gas sampling in the confined areas should occur at a rate not exceeding 2 ml every 30 s.

Other instruments are not precluded from being used provided that they do not unduly influence the results.

The measured value shall not exceed 75 % of the LOWER EXPLOSIVE LIMIT of the REFRIGERANT as specified in Table 104, and shall not exceed 50 % of the LOWER EXPLOSIVE LIMIT of the REFRIGERANT as specified in Table 104 for a period exceeding 5 min.

Substitution of an inert gas for leak test purposes is permitted if it can be demonstrated that the molecular mass of an inert gas matches that of the FLAMMABLE REFRIGERANT in question.

11.7.101.4 Scratch test for protected REFRIGERATING SYSTEMS

All ACCESSIBLE surfaces of protected REFRIGERATING SYSTEMS, including ACCESSIBLE surfaces in intimate contact with the protected REFRIGERATING SYSTEMS, are scratched using the TOOL, the tip of which is shown in Figure 103.

The TOOL is applied using the following parameters:

- force at right angles to the surface to be tested $35\text{ N} \pm 3\text{ N}$;
- force parallel to the surface to be tested not exceeding 250 N .


The TOOL is drawn across the surface to be tested at a rate of approximately 1 mm/s .

The surface to be tested is scratched at three different positions in a direction at right angles to the axis of the channel and at three different positions on the channel in a direction parallel to it. In the latter case, the length of the scratch shall be approximately 50 mm .

The scratches shall not cross each other.

The appropriate parts of the REFRIGERATING SYSTEM shall withstand the test of 11.7.2.101 with the test pressure reduced by 50% .

Dimensions in millimetres



Key

- A Hard-soldered carbide tip K10
- B Direction of movement

Figure 103 – Details of scratching TOOL tip

11.7.101.5 Unprotected REFRIGERATING SYSTEMS

Equipment with an unprotected REFRIGERATING SYSTEM is that where at least one part of the REFRIGERATING SYSTEM is placed inside an OPERATOR ACCESSIBLE compartment or that which does not comply with 11.7.101.2.

For equipment with an unprotected REFRIGERATING SYSTEM and which uses a FLAMMABLE REFRIGERANT, any electrical component located inside the OPERATOR ACCESSIBLE compartment, which during NORMAL CONDITION or SINGLE FAULT CONDITION produces arcs or sparks, and

luminaries, shall be tested and found at a minimum to comply with the requirements of Annex EE for group IIA gases or for the REFRIGERANT used.

This requirement does not apply to:

- non-self-resetting protective devices necessary for compliance with 4.4; nor to
- intentionally weak parts that become permanently open-circuited during the tests of 4.4, even if they produce arcs or sparks during operation.

REFRIGERANT leakage into OPERATOR ACCESSIBLE compartments shall not result in an EXPLOSIVE GAS ATMOSPHERE outside the OPERATOR ACCESSIBLE compartments in areas where electrical components that produce arcs and sparks during NORMAL USE or abnormal operation, or luminaries, are mounted, when doors or lids remain closed or when opening or closing doors or lids, unless these components have been tested and found at a minimum to comply with Annex EE for group IIA gases or for the REFRIGERANT used.

This requirement does not apply to:

- non-self-resetting protective devices necessary for compliance with 4.4; nor to
- intentionally weak parts that become permanently open-circuited during the tests of 4.4, even if they produce arcs or sparks during operation.

Separate components such as thermostats which contain less than 0,5 g of flammable gas are not considered to cause a fire or explosion HAZARD in the event of a leakage from the component itself.

Other types of protection for electrical devices for potentially EXPLOSIVE GAS ATMOSPHERES covered by IEC 60079 (all parts) are also acceptable.

Changing of a lamp is not considered a potential explosion HAZARD, because the door or lid is open during this operation.

Compliance is checked by inspection, by the appropriate tests of IEC 60079-15:2010 and by the following test.

The tests contained in Annex EE may be carried out using the stoichiometric concentration of the REFRIGERANT used. However, a device which has been independently tested and found to comply with Annex EE using the gas specified for group IIA need not be tested.

Irrespective of the requirements given in IEC 60079-15:2010, Clause 5, surface temperature limits are specified in 11.7.101.7.

The test is performed in a draught-free location with the equipment switched off or operated under conditions of NORMAL USE at RATED voltage, whichever gives the more unfavourable result.

During a test in which the equipment is operated, gas injection is started at the same time as the equipment is first switched on.

The test is performed twice and is repeated a third time if one of the first tests gives more than 40 % of the LOWER EXPLOSIVE LIMIT.

Through an appropriate orifice, 80 % of the nominal REFRIGERANT charge $\pm 1,5$ g, in the vapour state, is injected into an OPERATOR ACCESSIBLE compartment in a time not exceeding 10 min. The orifice is then closed. The injection shall be as close as possible to the centre of the back wall of the compartment at a distance from the top of the compartment approximately equal to one-third of the height of the compartment. Thirty minutes after the injection is completed, the

door or lid is opened at a uniform rate in a time between 2 s and 4 s, to an angle of 90° or to the maximum possible, whichever is less.

For equipment having more than one door or lid, the most unfavourable sequence or combination of opening the lids or doors is used.

For equipment fitted with fan motors, the test is performed with the most unfavourable combination of motor operation.

The concentration of leaked REFRIGERANT is measured every 30 s from the beginning of the test, at positions as close as possible to the electrical components. However, it is not measured at the locations of:

- non-self-resetting protective devices necessary for compliance with 4.4; nor at*
- intentionally weak parts that become permanently open-circuited during the tests of 4.4, even if they produce arcs or sparks during operation.*

The concentration values are recorded until they tend to go down.

The measured value shall not exceed 75 % of the LOWER EXPLOSIVE LIMIT of the REFRIGERANT as specified in Table 104, and shall not exceed 50 % of the LOWER EXPLOSIVE LIMIT of the REFRIGERANT as specified in Table 104 for a period exceeding 5 min.

The above test is repeated, except that the door or lid is subjected to an open/close sequence at a uniform rate in a time of between 2 s and 4 s, the door or lid being opened to an angle of 90° or to the maximum possible, whichever is less, and closed during the sequence.

11.7.101.6 Stagnation of leaked FLAMMABLE REFRIGERANT

Equipment which uses FLAMMABLE REFRIGERANT shall be constructed so that leaked REFRIGERANT will not stagnate and thus cause a fire or explosion HAZARD in areas outside the OPERATOR ACCESSIBLE compartment where components producing arcs or sparks or luminaires are mounted.

This requirement does not apply to areas where:

- non-self-resetting protective devices necessary for compliance with 4.4; or
- intentionally weak parts that become permanently open-circuited during the test of 4.4

are mounted, even if they produce arcs and sparks during operation.

Separate components such as thermostats that contain less than 0,5 g of flammable gas are not considered to cause a fire or explosion HAZARD in the event of a leakage of the component itself.

Compliance is checked by the following test, unless luminaires and components that produce arcs and sparks during NORMAL USE and which are mounted in the areas under consideration, have been tested and found to comply at a minimum with the requirements in Annex EE for group IIA gases or for the REFRIGERANT used.

Irrespective of the requirements given in IEC 60079-15:2010, Clause 5, the surface temperature limits are specified in 11.7.101.7.

Other types of protection for electrical devices for potentially EXPLOSIVE GAS ATMOSPHERES covered by IEC 60079 (all parts) are also acceptable.

The test is performed in a draught-free location with the appliance switched off or operated under NORMAL USE at RATED voltage, whichever gives the more unfavourable result when an ignition source is present.

During a test in which the equipment is operated, gas injection is started at the same time as the equipment is first switched on.

A quantity equal to 50 % of the REFRIGERANT charge $\pm 1,5$ g is injected into the considered area.

Injection is to be at a constant rate over a period of 1 h and is to be at the point of closest approach of:

- *pipe-work joints in external parts of the refrigerating circuit,*
- *the gaskets of semi-hermetic MOTOR-COMPRESSORS,*

to the electrical component under consideration. Any direct injection shall be avoided.

Welded telescopic joints of the MOTOR-COMPRESSOR, the welding of the pipes through the compressor housing and the welding of the fusite are not considered to be pipework joints.

The concentration of leaked REFRIGERANT as close as possible to the electrical component is measured continuously from the beginning of the test until it starts to decrease.

The measured value shall not exceed 75 % of the LOWER EXPLOSIVE LIMIT of the REFRIGERANT as specified in Table 104, and shall not exceed 50 % of the LOWER EXPLOSIVE LIMIT of the REFRIGERANT as specified in Table 104 for a period exceeding 5 min.

11.7.101.7 Surface temperature limits

Temperatures on surfaces that can be exposed to leakage of FLAMMABLE REFRIGERANT shall not exceed the AUTO IGNITION TEMPERATURE of the REFRIGERANT as specified in Table 104, reduced by 100 K.

Compliance is checked by measuring the appropriate surface temperatures during the tests specified in 4.4 and Clause 10.

Temperatures of

- *non-self-resetting protective devices that operate during the tests specified in 4.4; or*
- *intentionally weak parts that become permanently open-circuited during the tests specified in 4.4*

are not measured during those tests specified in 4.4 that cause these devices to operate.

Table 104 – REFRIGERANT flammability parameters

REFRIGERANT number	REFRIGERANT name	REFRIGERANT formula	REFRIGERANT AUTO IGNITION TEMPERATURE ^{a,c} °C	REFRIGERANT LOWER EXPLOSIVE LIMIT ^{b,c,d,e} % V/V
R50	Methane	CH ₄	645	4,9
R170	Ethane	CH ₃ CH ₃	515	3,1
R290	Propane	CH ₃ CH ₂ CH ₃	470	1,7
R600	n-Butane	CH ₃ CH ₂ CH ₂ CH ₃	365	1,5
R600a	Isobutane	CH(CH ₃) ₃	460	1,8
R1150	Ethene	CH ₂ =CH ₂	425	3,1
R1270	Propylene	CH ₂ =CHCH ₃	455	2,3
^a Values for other FLAMMABLE REFRIGERANTS shall be obtained from IEC 60079-20-1. ^b Values for other FLAMMABLE REFRIGERANTS shall be obtained from IEC 60079-20-1 and ISO 5149-1. ^c IEC 60079-20-1 is the reference standard. ISO 5149-1 may be used if the required data is not contained in IEC 60079-20-1. ^d Concentration of REFRIGERANT in dry air. ^e In some standards, the term "flammability limit" is used for "LOWER EXPLOSIVE LIMIT".				

11.7.102 Temperature test for storage and transport

11.7.102.1 General

Pressures developed from SOAKED TEMPERATURE CONDITIONS resulting from the temperatures the REFRIGERATING SYSTEM is exposed to during storage and/or transport shall not cause a HAZARD.

These pressures are used as one input for determining the PS (11.7.1) and are derived by the test below or from the REFRIGERANT SATURATED-VAPOUR PRESSURES at a storage and/or transport ambient temperature of 55 °C for NORMAL CONDITION or 70 °C for storage and/or transport under tropical conditions.

For pressures in parts protected by a PRESSURE-RELIEF DEVICE, the test pressure shall not exceed 0,9 times the setting of that device during storage and/or transport.

For refrigerating equipment that uses FLAMMABLE REFRIGERANT, the storage and/or transport ambient temperature shall be 70 °C.

Conformity is checked by inspection of the RATINGS of the components exposed to this pressure and, if a HAZARD could arise, by the tests of 11.7.2.

If there is any doubt as to the SATURATED-VAPOUR PRESSURE of the REFRIGERANT in use, then the test pressure shall be derived by one of the following test methods: 11.7.102.2 or 11.7.102.3, or the calculation of 11.7.102.4.

11.7.102.2 Test of charge-to-volume ratio

The steps for the test of charge-to-volume ratio are as follows:

- calculate the total volume of the REFRIGERATING SYSTEM in question;*
- calculate the charge-to-volume ratio for the design charge;*

- c) *take a charging cylinder of known volume and charge it to give the same volume-to-mass ratio as the system to be simulated;*
- d) *place the cylinder with a pressure gauge or transducer in a controlled ambient environment defined by the storage and/or transport ambient temperature and allow the cylinder to soak;*
- e) *record the maximum pressure and use this value as the test pressure for the REFRIGERATING SYSTEM.*

11.7.102.3 Test by pressure under the SOAKED TEMPERATURE CONDITION

The steps for test by pressure under the SOAKED TEMPERATURE CONDITION are as follows:

- a) *measure the pressure of the REFRIGERATING SYSTEM under the SOAKED TEMPERATURE CONDITION;*
- b) *use an evacuated cylinder and heat it up to the SOAKED TEMPERATURE CONDITION;*
- c) *charge the cylinder with the same REFRIGERANT used in the REFRIGERATING SYSTEM under the SOAKED TEMPERATURE CONDITION until it has the same pressure as the REFRIGERATING SYSTEM in the SOAKED TEMPERATURE CONDITION;*
- d) *place the cylinder with a pressure gauge or transducer in a controlled ambient environment defined by the storage and/or transport ambient temperature and allow the cylinder to soak;*
- e) *record the maximum pressure and use this value as the test pressure for the REFRIGERATING SYSTEM.*

11.7.102.4 Calculation by using the ideal gas law

FLAMMABLE REFRIGERANTS are assumed to be ideal gases. Calculate the pressure at transport and storage conditions by using the ideal gas law, based on the pressure and temperature in the SOAKED TEMPERATURE CONDITION.

11.7.103 Internal fluid leaks

Where, in a SINGLE FAULT CONDITION, fluid can leak within the equipment, this shall not cause a HAZARD.

Fluid-containing parts meeting the construction requirements of IEC 60079-15:2010 can be assumed not to leak. Other fluid-containing parts and seals shall be assumed to leak.

In particular, leaked FLAMMABLE LIQUID shall not come into contact with any ignition sources. Equipment containing no spark-generating parts (see Annex EE) and where no surface temperature exceeds $t_a - 100$ K (see 9.5 a) and 11.7.101.7), where t_a is the AUTO IGNITION TEMPERATURE of the liquid, is considered to meet this requirement.

Conformity is checked by inspection, by performing the tests of 4.4.2.102 and 10.4.

12 Protection against radiation, including laser sources, and against sonic and ultrasonic pressure

This clause of Part 1 is applicable except as follows:

12.1 General

Replacement:

Replace the text with the following:

The equipment shall provide protection against the effects of internally generated optical, ultraviolet, ionizing and microwave radiation as well as laser sources, and sonic and ultrasonic pressure.

Conformity tests are carried out if the equipment is likely to cause such HAZARDS.

12.2.1.3 Equipment not intended to emit radiation

Addition:

Add the following paragraph and Note 101 after the conformity statement:

The equipment intended for application to radioactive substances, for example chemicals in a jacketed reactor, or a plant, seed or insect treated with radioactive chemicals, shall be isolated to provide protection against transmission of ionizing radiation, and the operation of the equipment shall be strictly supervised to follow the rules and regulations for radiation laboratories to reduce the amount of ionizing radiation to an acceptable level (see also 5.4.4.101). The RESPONSIBLE BODY or the OPERATOR shall apply the symbol 17 of Table 1 with the signature of the OPERATOR. The symbol shall at the minimum be in close proximity to where the SPECIMEN is kept and easily visible for NORMAL USE.

NOTE 101 Examples of such equipment include the BATH, CIRCULATOR and climatic TEST CHAMBER for biological applications, etc.

Conformity is checked by inspection.

12.3 Optical radiation

Addition:

Add the following text after the first paragraph:

Where the exposure to hazardous radiation is inevitable for functional reasons, the equipment shall incorporate protective measures to limit exposure to a safe level. Equipment incorporating a lamp and lamp systems that can produce hazardous effects shall be marked with symbol 104 to warn of optical radiation, with symbol 13 to warn of a burn HAZARD, or with symbol 14 to warning of other HAZARDS, as applicable.

13 Protection against liberated gases and substances, explosion and implosion

This clause of Part 1 is applicable except as follows:

13.1 Poisonous and injurious gases and substances

Addition:

Add a new sentence at the end of the first paragraph:

For example, the high temperature decomposition products of the oil HEAT TRANSFER MEDIUM.

13.2.1 Components

Replacement:

Replace the title and text in 13.2.1 with the following:

13.2.1 Components of the equipment and materials being treated

If components liable to explode are not provided with a PRESSURE-RELIEF DEVICE, or if the equipment is intended to treat materials in such a way that explosion or implosion can occur, protection for the OPERATOR shall be incorporated with the equipment (see 7.7) or otherwise personal protective measures shall be included in the OPERATOR instructions. PRESSURE-RELIEF DEVICES shall be located so that a discharge will not cause HAZARD to the OPERATOR. The construction shall be such that the PRESSURE-RELIEF DEVICE cannot be obstructed.

Addition:

Add the following new subclauses:

13.2.101 Implosion of low air pressure equipment

A low air pressure TEST CHAMBER or vacuum oven shall be incorporated with protection for the OPERATOR and the surroundings against the effects of implosion.

Conformity is checked by inspection of the equipment and of the design information and, in case of doubt, by provoking an implosion.

13.2.102 Explosion and implosion of lamps

The lamps or lamp systems shall be incorporated and constructed to provide protection against explosion and implosion, whether for normal operation or for maintenance, under mechanical and thermal stresses resulting from shaking, vibrating, thermal shocking over the CONTROLLED TEMPERATURE range, or unexpected contact with a cold liquid.

Lamps liable to explode or implode when vibrated, shaken, heated, cooled or thermal shocked over the CONTROLLED TEMPERATURE range and, where a HAZARD could arise when ruptured, shall be protected with an explosion-proof transparent shield which is ACCESSIBLE only with the aid of a TOOL. If glass is used, it shall not be in contact with the surface of the lamps and it shall be subjected to the tests of 8.2, and meet the pass criteria of 8.1 of this document.

Conformity is checked by inspection.

Addition:

Add the following new subclauses:

13.101 Biohazardous substances

Equipment that can be potentially infectious, whether from the SPECIMEN itself or as a result of treatment with biohazardous agents or formulations, shall be prominently marked with symbol 103 of Table 1. At a minimum, the symbol shall be in close proximity to where the SPECIMEN or biohazardous substance is kept and easily visible during NORMAL USE.

Symbol 103 shall be placed near any biohazardous area ACCESSIBLE during OPERATOR maintenance and visible only during this maintenance.

Where applicable, symbol 103 shall also be attached to disposal bags or containers for biologically hazardous materials removed from the equipment, and to any LIQUID CONNECTIONS or exhaust openings where the liberation of biohazardous substances can occur during NORMAL USE.

Equipment that can be hazardous due to the use of hazardous substances shall be marked with an appropriate international symbol, or (if none is available) symbol 14 of Table 1.

See also 5.4.3 c) for details of instructions relating to ventilation requirements.

NOTE Local, national or regional regulations concerning the collection or discharge of biohazardous material can apply.

Conformity is checked by inspection.

13.102 Warning requirements related to chemical HAZARD

Equipment intended for chemical applications, such as BATHS, CIRCULATORS, SHAKERS, climatic TEST CHAMBERS and salt spray corrosion TEST CHAMBERS, and which could present chemical HAZARDS to the OPERATOR and the environment, shall be marked with a symbol or text suitable to the chemical HAZARD. The symbol shall be in close proximity to where the SPECIMEN is kept and easily visible during NORMAL USE. Where applicable, the symbol or text shall also be attached to glassware such as flasks for shaking or immersion applications, APPLICATION SYSTEMS such as jacketed reactors containing hazardous chemicals, or LIQUID CONNECTIONS and exhaust openings where liberating of chemical contaminants can occur during NORMAL USE.

See also 5.4.3 c) for details of instructions relating to ventilation requirements.

NOTE Examples of chemical HAZARDS presented by these types of equipment are salt mist, salt solutions, SPECIMENS treated with salt spray, pest insects, microorganisms or plants treated with pesticides, radioactive substances and chemical mixtures.

Symbol 102 of Table 1 is used for warnings pertaining to flammable materials. Symbols for other chemical HAZARDS may be selected from ISO 7010, as follows:

- a) for explosive materials, W002:2011-05
- b) for radioactive materials, W003:2011-05
- c) for toxic materials, W016:2011-05
- d) for corrosive materials, W023:2011-05
- e) for oxidizing substances, W028:2011-05
- f) for other chemical HAZARDS, other appropriate symbols from ISO 7010.

If there is no appropriate symbol for the particular chemical HAZARD, symbol 14 of Table 1 shall be used and additional explanations of the chemical HAZARD shall be included in the documentation.

Conformity is checked by inspection.

14 Components and subassemblies

This clause of Part 1 is applicable except as follows:

14.3 Overtemperature protection devices

Replacement:

Replace the text by the following:

TEMPERATURE-LIMITING DEVICES and systems for overtemperature protection designed to operate in SINGLE FAULT CONDITION shall meet all of the following requirements:

- a) be constructed and tested to ensure reliable function. Devices of the capillary type shall be so designed that the protection is kept complete in the event of leakage from the capillary tube;

- b) be RATED to interrupt the maximum voltage and current of the circuit in which they are employed;
- c) do not operate in NORMAL USE.

LIQUID LEVEL CUT OUTS used to protect against overtemperature shall meet the same requirements as TEMPERATURE-LIMITING DEVICES and systems.

Conformity is checked by studying the operating principle of the device or system or by fracturing the capillary tube and by performing adequate reliability tests with the equipment operated in SINGLE FAULT CONDITION. Ensure that the capillary tube is not obstructed when it is being fractured.

The number of operations is as follows:

- 1) *non-resetting devices are caused to operate once;*
- 2) *non-self-resetting devices and systems, except thermal fuses, are reset after each operation and thus caused to operate 10 times;*
- 3) *self-resetting devices are caused to operate 200 times.*

NOTE Forced cooling and resting periods can be introduced to prevent damage to the equipment.

During the test, resetting devices shall operate each time the SINGLE FAULT CONDITION is applied and non-resetting devices shall operate once to provide the expected protection. After the test, the resetting devices shall show no sign of damage which could prevent their operation in a further SINGLE FAULT CONDITION.

Addition:

Add the following new subclauses:

14.101 Components and subassemblies for REFRIGERATING SYSTEMS

Components and piping that are part of the REFRIGERATING SYSTEM shall comply with the related standards or requirements as indicated in Annex CC or be evaluated according to the pressure RATING requirements of this document (see 11.7.2).

Conformity is checked by inspection or as specified in 11.7.2, as applicable.

14.102 Flexible tubing and hose subjected to liquid pressure other than that of the REFRIGERANT

Flexible tubing and hose subjected to the RATED PRESSURE of the equipment shall be of sufficient mechanical strength.

The construction and materials of the flexible tubing and hose, including fittings and thermal insulation for subassemblies if any, shall withstand mechanical, chemical and thermal stresses encountered for NORMAL USE.

Conformity is checked by the following tests and, in case of doubt, by tests repeated at RATED PRESSURE and temperature:

The high pressure flexible tubing and hose for liquid circulating shall be subjected to a static pressure test of four times the RATED PRESSURE at ambient temperature and under the maximum CONTROLLED TEMPERATURE range of the intended application, whereby the test pressure shall be reached between 15 s and 30 s after starting at zero pressure.

NOTE The PRESSURE-RELIEF DEVICE and/or alternative sensing devices can be rendered inoperative in this test.

The flexible tubing and hose used for water supply, if any, shall be subjected to a static pressure test of two times the maximum inlet pressure for 5 min at ambient temperature.

During the test there shall be no leakage or rupture.

15 Protection by interlocks

This clause of Part 1 is applicable except as follows:

15.1 General

Replacement:

Replace the text with the following:

Interlocks used to protect OPERATORS from HAZARDS shall prevent an OPERATOR from being exposed to the HAZARD before the HAZARD is removed and shall meet the requirements of 15.2, 15.3 and 15.101 to 15.104 as applicable.

Conformity is checked by inspection and by performing all the relevant tests of this document.

Addition:

Add the following new subclauses:

15.101 Mechanism of door and/or lock for WALK-IN EQUIPMENT

It shall be possible to escape from the WALK-IN EQUIPMENT at all times.

The door for WALK-IN EQUIPMENT shall be so designed and constructed that its opening is possible both from the outside and from within the equipment, with the priority assigned to the unlocking and opening from within the equipment.

NOTE 1 A separate door or exit independent of the main entrance which is locked and opened from outside the equipment, when ACCESSIBLE only from within the equipment and when open to the outside, is considered to meet this requirement.

NOTE 2 Additional requirements for WALK-IN EQUIPMENT can apply in accordance with Annex BB.

When the door is closed and/or locked from within the equipment, there shall be an illuminated indication in proximity to the controller outside the equipment, which reads: "equipment in operation, OPERATOR inside the room!" The indication shall be interlocked to one or more of the following settings ACCESSIBLE from outside:

- 1) the maximum CONTROLLED TEMPERATURE not exceeding: +40 °C
- 2) the minimum CONTROLLED TEMPERATURE not exceeding: –30 °C
- 3) start the VENTILATOR or any other similar devices;
- 4) disable the initiation of vacuum pump or any evacuating system;
- 5) limit the number of lamps or the light emitting intensity in accordance with 12.3 and/or warn the OPERATOR of the HAZARD and the necessity for protective eyewear if hazardous optical radiation exists.

Conformity is checked by inspection of the documentation and in accordance with 15.2 and 15.3.

15.102 Interlock between the CIRCULATING PUMP, agitator and heating, cooling, MECHANICAL MOVEMENT and/or operation of the APPLICATION SYSTEM

The RESISTANCE-HEATING DEVICE and/or MOTOR-COMPRESSOR of the BATH and CIRCULATOR shall be interlocked with the CIRCULATING PUMP, agitator and, where applicable, the APPLICATION SYSTEM, if HAZARDS could arise due to one or more of the following:

- the CONTROLLED TEMPERATURE of the equipment deviates from its setting to some extent, resulting in overheating or deep cooling of the SPECIMEN or APPLICATION SYSTEM;
- localized overheating or deep cooling of the liquid HEAT TRANSFER MEDIUM occurs as a result of the termination of the CIRCULATING PUMP or agitator;
- obstruction or leakage of the external liquid circulating occurs between the equipment and the APPLICATION SYSTEM.

Depending on the related HAZARD, the RESISTANCE-HEATING DEVICE or the MOTOR-COMPRESSOR, or both, shall be de-energized if the CIRCULATING PUMP and/or agitator is interrupted and if the CONTROLLED TEMPERATURE deviates from its setting to some extent, and the operation of the APPLICATION SYSTEM shall be controlled to prevent the developing of the HAZARD.

NOTE Whether the RESISTANCE-HEATING DEVICE or the MOTOR-COMPRESSOR alone, or both, are de-energized depends on the related HAZARD. It is advantageous to provide the equipment with means such that either or both of these could be interlocked and available to the OPERATOR with additional instructions for the configuration of the function.

Conformity is checked by inspection and by operating the interlocks as specified in the documentation and in accordance with 15.2 and 15.3.

15.103 Interlock between CIRCULATING FAN, door or lid and heating, cooling and/or radiation, humidifying and MECHANICAL MOVEMENT

The RESISTANCE-HEATING DEVICE and/or MOTOR-COMPRESSOR and, where applicable, the radiation, humidifying, MECHANICAL MOVEMENT, shall be interlocked with the CIRCULATING FAN if HAZARDS could arise due to one or more of the following:

- the CONTROLLED TEMPERATURE of the equipment deviates from its setting to some extent, resulting in overheating or deep cooling of the SPECIMEN;
- where the RESISTANCE-HEATING DEVICE and/or EVAPORATOR are located, localized overheating and/or deep cooling occur(s) resulting from the termination of the CIRCULATING FAN;
- with the door or lid open, continuous heating and/or cooling, and humidifying can occur if the settings deviate from the ambient temperature and humidity;
- with the door or lid open, the OPERATOR or the surroundings can be exposed to excessive optical radiation or any other hazardous radiation;
- with the door or lid open, the OPERATOR can be exposed to mechanical HAZARD if MECHANICAL MOVEMENT continues.

Depending on the related HAZARD, the RESISTANCE-HEATING DEVICE or the MOTOR-COMPRESSOR, or both, shall be de-energized if the CIRCULATING FAN is interrupted and if the CONTROLLED TEMPERATURE deviates from its setting to some extent. The CIRCULATING FAN shall be switched off while or some time after the door or lid is opened, while the HUMIDIFIER, lamp or lamp systems (see 12.3) and MECHANICAL MOVEMENT shall be terminated or reduced to a safe level with the door or lid opened.

NOTE Whether the RESISTANCE-HEATING DEVICE or the MOTOR-COMPRESSOR alone or both are de-energized depends on the related HAZARD. It is advantageous to provide the equipment with means that either or both of them could be interlocked and available to the OPERATOR with additional instructions for the configuration of the function.

Conformity is checked by inspection and by operating the interlocks as specified in the documentation and, in accordance with 15.2 and 15.3.

15.104 Interlock between salt spray and cover of salt spray corrosion TEST CHAMBER

The mechanism of the cover for the salt spray corrosion TEST CHAMBER shall meet the requirements specified in 11.4.101 of this document. The activation of the saturated compressed-air for salt solution atomizing shall be interlocked by the mechanism of the cover.

Conformity is checked by inspection and by operating the interlocks as specified in the documentation and in accordance with 15.2 and 15.3.

16 HAZARDS resulting from application

This clause of Part 1 is applicable except as follows.

16.1 REASONABLY FORESEEABLE MISUSE

Replacement:

Replace the text as follows:

The equipment shall comply with the requirements of this document during NORMAL USE, including mistakes, lapses, slips or use of an equipment or system in a way not intended by the manufacturer, but which can result from readily predictable human behaviour. Such acts to consider would include well-meant optimization or readily available shortcuts.

No HAZARD shall arise in NORMAL USE or SINGLE FAULT CONDITION, through readily available adjustments, knobs, or other software-based or hardware-based controls are set in a way not intended, or not described in the instructions.

Reckless use, unqualified use or use outside the specifications set by the manufacturer is not considered as part of this document. Similarly, intended acts or intended omissions of an act by the OPERATOR of the equipment as a result of conduct that is beyond any reasonable means of RISK control by the manufacturer are similarly excluded from the scope of this document.

Other possible cases of REASONABLY FORESEEABLE MISUSE that are not addressed by specific requirements in this document shall be addressed by the RISK assessment (see Clause 17).

Addition:

Add the following new subclause:

16.101 Slip HAZARD

For WALK-IN EQUIPMENT (see Annex BB), where the ground or floor can be slippery when wet or icy, the equipment shall be designed and constructed in such a way as to minimize the RISK of slipping. Where a slip HAZARD remains, appropriate means including personal protective measures which enable the OPERATOR to maintain their stability and safety shall be provided (for example handholds that are fixed relative to the OPERATOR) and the equipment shall be permanently marked with symbol 105 of Table 1, warning of slippery surface and against the HAZARD of falling. The symbol shall be placed on the door or on the inside wall of the equipment, where it is clearly visible for the OPERATOR during NORMAL USE.

Conformity is checked by inspection.

17 Risk assessment

This clause of Part 1 is applicable.

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV

Annexes

The annexes of Part 1 are applicable except as follows:

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV

Annex K (normative)

Insulation requirements not covered by 6.7

K.1.3 Solid insulation for MAINS CIRCUITS

K.1.3.1 General

Addition:

Add the following paragraph after Note 1:

If the performance of the equipment requires the use of a hygroscopic insulated RESISTANCE-HEATING DEVICE, it is permissible for equipment to require a period of operation to dry out the insulation before meeting the requirements of 6.3.1 and 6.8.3, provided that the OPERATOR is made aware of this (see 5.4.3.101).

Addition:

Add the following paragraph after the conformity statement:

If a DRYING-OUT is specified, conformity is checked by performing the DRYING-OUT specified in the OPERATOR manual (see 5.4.3.101) before conducting the tests of a) and b) above.

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV

Annex L (informative)

Index of defined terms

Addition:

Add the following terms:

Term	Definition
ACC RANGE	3.5.104
ACTIVE COOLING CONTROL RANGE	3.5.104
APPLICATION SYSTEM	3.2.125
AUTO IGNITION TEMPERATURE	3.5.107
BATH	3.1.101
BATH TANK	3.2.113
CASCADE SYSTEM	3.2.103
CIRCULATING FAN	3.2.111
CIRCULATING PUMP	3.2.110
CIRCULATOR	3.1.102
COMBINED TEST CHAMBER	3.1.104
CONDENSER	3.2.105
CONDENSING UNIT	3.2.106
CONTROLLED TEMPERATURE	3.5.114
DRYING-OUT	3.1.108
EVAPORATOR	3.2.107
EXPLOSIVE GAS ATMOSPHERE	3.5.109
FIRE POINT	3.5.106
FLAMMABLE LIQUID	3.2.120
FLAMMABLE REFRIGERANT	3.2.123
FLASH POINT	3.5.105
HEAT TRANSFER MEDIUM	3.2.121
HIGH-PRESSURE SIDE	3.2.108
HUMIDIFIER	3.2.112
INCUBATOR	3.1.105
LIQUID CONNECTION	3.2.114
LIQUID LEVEL CUT OUT	3.2.117
LOW-PRESSURE SIDE	3.2.109
LOWER EXPLOSIVE LIMIT	3.2.108
MAXIMUM ALLOWABLE PRESSURE	3.5.102
MECHANICAL MOVEMENT	3.5.111
MOTOR-COMPRESSOR	3.2.104
MOVEMENT AMPLITUDE	3.5.113
MOVEMENT FREQUENCY	3.5.112
PRESSURE-LIMITING DEVICE	3.2.118

PRESSURE-RELIEF DEVICE	3.2.119
PS	3.5.102
RATED PRESSURE	3.5.103
REFRIGERANT	3.2.122
REFRIGERATING SYSTEM	3.2.102
RESISTANCE-HEATING DEVICE	3.2.101
SATURATED-VAPOUR PRESSURE (of REFRIGERANT)	3.5.101
SHAKER	3.1.106
SOAKED TEMPERATURE CONDITION	3.5.110
SPECIMEN	3.2.124
STANDSTILL	3.1.109
TEST CHAMBER	3.1.103
TEMPERATURE-LIMITING DEVICE	3.2.116
VENTILATOR	3.2.115
WALK-IN EQUIPMENT	3.1.107

Addition:

Add the following new annexes:



IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV




Annex AA (informative)

Useful symbols

The symbols in Table AA.1 are useful for identification and documentation related to the safe operation of the equipment. These symbols may be used as specified in 5.1.5.101, 5.1.5.103, 5.4.101, 5.4.102, 7.3.5.1, 7.3.101, 10.1, 12.3, 13.101, 13.102 and 16.101.

Table AA.1 – Useful symbols

Number	Symbol	Reference	Description
107		a	Use with a refrigerating BATH and CIRCULATOR with a liquid CIRCULATING PUMP and LIQUID CONNECTIONS for external circulating.
108		a	LIQUID CONNECTION for a CIRCULATING PUMP outlet of the liquid HEAT TRANSFER MEDIUM (coolant only) in refrigerating CIRCULATORS. The minimum CONTROLLED TEMPERATURE of the liquid can be accompanied with the symbol if it is lower than $-30\text{ }^{\circ}\text{C}$. The maximum exit pressure can also be marked if it is higher than 0,03 MPa or 0,02 MPa with a flow rate of more than 10 l/min.
109		a	LIQUID CONNECTION for return of the liquid HEAT TRANSFER MEDIUM (coolant only) in refrigerating CIRCULATORS. For an enclosed CIRCULATOR or CIRCULATOR equipped with suction CIRCULATING PUMP, and when the suction pressure is greater than 0,02 MPa, the minimum suction pressure can be marked in association with the symbol.
110		b	Use with refrigerating and heating BATH and CIRCULATOR with a liquid CIRCULATING PUMP and LIQUID CONNECTIONS for external circulating.
111		b	LIQUID CONNECTION for a CIRCULATING PUMP outlet of the liquid HEAT TRANSFER MEDIUM (both heating and cooling) in refrigerating and heating CIRCULATORS. The maximum and/or minimum CONTROLLED TEMPERATURE(s) of the liquid can be accompanied with the symbol if they are higher than $+60\text{ }^{\circ}\text{C}$ and/or lower than $-30\text{ }^{\circ}\text{C}$. The maximum exit pressure can also be marked if it is higher than 0,03 MPa or 0,02 MPa with a flow rate of more than 10 l/min.
112		b	LIQUID CONNECTION for return of the liquid HEAT TRANSFER MEDIUM (both heating and cooling) in refrigerating and heating CIRCULATORS. For an enclosed CIRCULATOR or CIRCULATOR equipped with a suction pump and when the suction pressure is greater than 0,02 MPa, the minimum suction pressure can be marked in association with the symbol.
113		ISO 7000-0794 (2004-01)	Input or entrance, for example, LIQUID CONNECTIONS for a water-cooled CONDENSER, water supply, salt solution, and connections for a steam source, compressed air, etc. The MAXIMUM ALLOWABLE PRESSURE (PS) in pascal, and the maximum and/or minimum temperatures in centigrade, can be accompanied with the symbol where applicable.

Number	Symbol	Reference	Description
114		ISO 7000-0795 (2004-01)	Output or exit, for example, LIQUID CONNECTION for water-cooled CONDENSER and connection for vacuum source, etc.
115		IEC 60417-5595 (2002-10)	Condensate collector
116		ISO 7000-0028 (2004-01)	Filling device
117		ISO 7000-0029 (2004-01)	Draining device
118		ISO 7000-0030 (2004-01)	Overflow device
119		^c	VENTILATOR
120		ISO 7000-1604 (2004-01)	Intake air
121		ISO 7000-1605 (2004-01)	Exhaust gas
122			Orbital movement, maximum MOVEMENT FREQUENCY and MOVEMENT AMPLITUDE can be accompanied with the symbol where applicable.
123			Reciprocating movement, maximum MOVEMENT FREQUENCY and MOVEMENT AMPLITUDE can be accompanied with the symbol where applicable.
124			Hand and wrist movement, maximum MOVEMENT FREQUENCY and MOVEMENT AMPLITUDE can be accompanied with the symbol where applicable.
125			Vortex movement, maximum MOVEMENT FREQUENCY can be accompanied with the symbol where applicable.
126			Rocking movement, maximum MOVEMENT FREQUENCY and MOVEMENT AMPLITUDE may be accompanied with the symbol where applicable.

Number	Symbol	Reference	Description
127			Rotating movement, maximum MOVEMENT FREQUENCY and MOVEMENT AMPLITUDE can be accompanied with the symbol where applicable.
^a These symbols are created based on ISO 7000-0880 (1989) for circulating equipment with coolant pump. The big circle in connection with the coolant pump (ISO 7000-0355 (2004-01)) is cut into two parts, with one representing the outlet and the other the return of the liquid. An arrow is added to make it clear for identification of the liquid outlet or return. ^b These symbols are created based on symbols 107, 108 and 109, by removing the symbol for cooling (ISO 7000-0027 (2004-01)). ^c This symbol is created by combining the symbol for intake air (ISO 7000-1604 (2004-01)) and that for exhaust gas (ISO 7000-1605 (2004-01)). To prevent any confusion, the combination is turned at an angle of 90°.			

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 PLV

Annex BB (informative)

Protection of people who are inside WALK-IN EQUIPMENT

BB.1 General

In order to minimize the HAZARD for people who get locked in WALK-IN EQUIPMENT with extreme temperatures, or with a controlled atmosphere, exhaust gas mixtures, fume or mist, suspension of particles or aerosols, as well as excessive optical radiation, measures as described in Clauses BB.2 and BB.3 should be taken. Care should be taken to ensure that no personnel is locked in WALK-IN EQUIPMENT at the end of the working day. Annex BB is limited to WALK-IN EQUIPMENT operating at CONTROLLED TEMPERATURES below zero or over 35 °C.

BB.2 Emergency switch or signal

According to the operating conditions, the following devices should be provided with the WALK-IN EQUIPMENT:

- 1) alarm switch operated by illuminated push buttons near the floor or by chains hanging near the floor, installed in a suitable place in the equipment, the operation of which initiates an audible signal and a visual signal, in a place where the permanent presence of a person is guaranteed. It should not be possible to stop this signal except by means of a specific operation;
- 2) signal devices connected to an electric circuit with a voltage of at least 12 V. Batteries for this purpose should have an operating time of at least 10 h and be connected to a MAINS supplied automatic charging device. If a transformer is used, it should be supplied with current from a different circuit to the one used for other equipment inside the WALK-IN EQUIPMENT. Furthermore, the device should be of such design that it does not cease to function due to corrosion, frost or the formation of ice on contact surfaces;
- 3) light switch inside the WALK-IN EQUIPMENT in parallel with light switches located outside this equipment so that the lighting turned on by means of the inside switch cannot be turned off by means of the outside switch;
- 4) plug switch or other systems giving the same result for the CIRCULATING FANS located inside the WALK-IN EQUIPMENT in series with the switches located on the outside so that the fans turned off by means of the inside switch cannot be turned on by means of the outside switch;
- 5) light switches having permanently illuminated buttons;
- 6) in the event of failure of the lighting, independent lighting or other approved means of indicating the routes towards the door which is intended to open from the inside (and/or alarm switch);
- 7) permanent emergency lighting system.

BB.3 WALK-IN EQUIPMENT with a controlled atmosphere

In WALK-IN EQUIPMENT with a controlled atmosphere (equipment with an atmosphere in which the concentration of oxygen, carbon dioxide and nitrogen are different from those in normal air), the following additional requirements apply:

- 1) warning that a self-contained breathing apparatus shall be worn when entering this WALK-IN EQUIPMENT;

- 2) warning that if WALK-IN EQUIPMENT with a controlled atmosphere is entered, another person shall remain outside the room and in visual contact with those inside through an access door (hatch). The person outside shall also have a self-contained breathing apparatus at their disposal in case they should have to enter the equipment in order to rescue the person inside in an emergency;
- 3) doors, hatches and other appliances giving access to the WALK-IN EQUIPMENT shall be provided with a written warning notice against low oxygen level in the equipment.

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV

Annex CC (informative)

Safety requirements for components and piping

CC.1 Overview

The applicable component requirements for sealed system components and the associated piping are defined differently for geographical regions depending on the classification of the pressure vessels in question.

For Europe, the sealed system components can be considered pressure vessels in accordance with the Pressure Equipment Directive (PED) 2014/68/EU depending on the classification in Tables CC.1 and CC.2. If the components or piping are classified as a category II or higher pressure vessel according to the PED then the requirements of Table CC.3 apply including the use of a Notified Body according to the PED. Table CC.4 sets out the minimum wall thickness for copper and steel tubing.

For USA and Canada, the component requirements of Clause CC.2 apply.

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV

Table CC.1 – Parameters of pressure vessels according to EN 14276-1

Fluid	Nature	PS (bar) ^a	V (L)	PS × V (bar × L)	Category/Article
if	and	and	and	and	then
Group 1	Gas	≤ 0,5	—	—	Not subjected to PED ^b
		> 0,5 and ≤ 200	≤ 1	—	Art. 4.3 ^c
			> 1	≤ 25	Art. 4.3 ^c
				> 25 and ≤ 50	I
				> 50 and ≤ 200	II
		> 200 and ≤ 1 000	≤ 1	—	III
		≤ 1 000	> 1	> 200 and ≤ 1 000	III
				> 1 000	IV
		> 1 000	—	—	IV
	Liquid ^d	≤ 0,5	—	—	Not subjected to PED ^b
		> 0,5 and ≤ 500	≤ 1	—	Art. 4.3 ^c
			> 1	≤ 200	Art. 4.3 ^c
		> 0,5 and ≤ 10		> 200	I
		> 10 and ≤ 500			II
		> 500	< 1	—	II
		> 500	> 1	—	III
Group 2	Gas	≤ 0,5	—	—	Not subjected to PED ^b
		> 0,5 and ≤ 1 000	≤ 1	—	Art. 4.3 ^c
			> 1	≤ 50	Art. 4.3 ^c
				> 50 and ≤ 200	I
				> 200 and ≤ 1 000	II
		> 1 000 and ≤ 3 000	≤ 1	—	III
			> 1	> 1 000 and ≤ 3 000	III
		> 0,5 and ≤ 4		> 1 000	III
		> 4		> 3 000	IV
		> 3 000	—	—	IV
	Liquid ^d	≤ 0,5	—	—	Not subjected to PED ^b
		> 0,5 and ≤ 10	—	—	Art. 4.3 ^c
		> 10 and ≤ 1 000	≤ 10	—	Art. 4.3 ^c
		> 10 and ≤ 1 000	> 10	≤ 10 000	Art. 4.3 ^c
		> 10 and ≤ 500	—	> 10 000	I
		> 1 000	< 10	—	I
		> 500	> 10	> 10 000	II

^a 1 bar = 0,1 Mpa.

^b PED = Pressure Equipment Directive.

^c Art. 4.3 = reference to Article 4.3 of the Pressure Equipment Directive.

^d Liquids are considered to be fluids having a vapour pressure of not more than 0,5 bar above the normal atmospheric pressure (1 013 mbar).

Table CC.2 – Parameters of piping according to EN 14276-2

Fluid	Nature	PS (bar) ^a	DN	PS × DN (bar) ^a	Category/Article
if	and	and	and	and	then
Group 1	Gas	≤ 0,5	—	—	Not subjected to PED ^b
		> 0,5	≤ 25	—	Art. 4.3 ^c
			> 25 and ≤ 100	≤ 1 000	I
			> 100 and ≤ 350	> 1 000 and ≤ 3 500	II
			> 350	> 3 500	III
	Liquid ^d	≤ 0,5	—	—	Not subjected to PED ^b
		> 0,5	≤ 25	—	Art. 4.3 ^c
			—	≤ 2 000	Art. 4.3 ^c
		> 0,5 and ≤ 10	—	> 2 000	I
		> 10 and ≤ 500	> 25		II
		> 500		—	III
Group 2	Gas	≤ 0,5	—	—	Not subjected to PED ^b
		> 0,5	≤ 32	—	Art. 4.3 ^c
			—	≤ 1 000	Art. 4.3 ^c
			> 32 and ≤ 100	> 1 000 and ≤ 3 500	I
			> 100 and ≤ 250	> 3 500 and ≤ 5 000	II
			> 250	> 5 000	III
	Liquid ^d	≤ 0,5	—	—	Not subjected to PED ^b
		> 0,5 and ≤ 10	—	—	Art. 4.3 ^c
		—	—	≤ 5 000	Art. 4.3 ^c
		—	≤ 200	—	Art. 4.3 ^c
		> 10 and ≤ 500	> 200	> 5 000	I
		> 500		—	II

^a 1 bar = 0,1 Mpa.

^b PED = Pressure Equipment Directive.

^c Art. 4.3 = reference to Article 4.3 of the Pressure Equipment Directive.

^d Liquids are considered to be fluids having a vapour pressure of not more than 0,5 bar above the normal atmospheric pressure (1 013 mbar).

Table CC.3 – Components and piping requirements

Components	Related standards and requirements
Heat exchangers: – pipe coil without air (tube in tube) – multi-tubular (shell and tubes)	EN 14276-1 or EN 13445 if applicable combined with 11.7.2 of this document
Plate heat exchangers	EN 14276-1 or EN 13445 if applicable combined with 11.7.2 of this document
Headers and coils with air as secondary fluid	EN 14276-2 combined with a production leak tightness test based on guidance from EN 1779
Receiver/accumulator/economizer	EN 14276-1 or EN 13445 if applicable combined with 11.7.2 of this document
Oil separator	EN 14276-1 or EN 13445 if applicable combined with 11.7.2 of this document
Drier	EN 14276-1 or EN 13445 if applicable combined with 11.7.2 of this document
Filter	EN 14276-1 or EN 13445 if applicable combined with 11.7.2 of this document
Muffler	EN 14276-1 or EN 13445 if applicable combined with 11.7.2 of this document
Hermetic positive displacement compressor	IEC 60335-2-34 or EN 12693
Semi-hermetic positive displacement compressor	IEC 60335-2-34 or EN 12693
Open positive displacement compressor	EN 12693
Non-positive displacement compressor	EN 14276-1 or EN 13445 if applicable combined with IEC 60204-1
Pump General requirements Additional requirements for pumps in REFRIGERATING SYSTEMS and heat pumps with R717	EN 809 combined with IEC 60204-1, and combined with a production leak tightness test based on guidance from EN 1779 and the marking requirements from 5.1.101 of this document
Piping	EN 14276-2 or EN 13480
Piping joints Permanent joints Detachable joints	EN 14276-2 combined with a production leak tightness test based on guidance from EN 1779 and an evaluation of the suitability of the joint for the pipe, piping material, pressure, temperature and fluid
Flexible piping	EN 1736
Valves	EN 12284
Safety valve	EN 13136 and ISO 4126-1 combined with a production leak tightness test based on guidance from EN 1779
Safety switching devices for limiting the pressure	EN 12263 combined with a production leak tightness test based on guidance from EN 1779
Isolating valves	EN 12284
Hand operated valves	EN 12284
Valves with seal cap	EN 12284
Bursting disc	ISO 4126-2 and EN 13136 combined with a production leak tightness test based on guidance from EN 1779:1999
Fusible plug	EN 13136 combined with a production leak tightness test based on guidance from EN 1779:1999 and marked with the melting temperature and working pressure of the fusible material.
Liquid level indicators	EN 12178 combined with a production leak tightness test based on guidance from EN 1779
Gauges	EN 837-1, EN 837-2 and EN 837-3 combined with a production leak tightness test based on guidance from EN 1779
Brazing and soldering materials	Soldering alloys shall not be used for REFRIGERANTS for uses where strength is a factor. Brazing alloys shall only be used when their compatibility with REFRIGERANTS and lubricants has been proven by test or experience
Welding materials	EN 14276-2

CC.2 Component and subassembly requirements for switches and controls used in REFRIGERATING SYSTEMS for North America

The minimum rating for the number of operations for switches and controls used in a REFRIGERATING SYSTEM shall be as follows:

- | | |
|---|---------|
| a) quick freeze switches | 300 |
| b) manual and semi-automatic defrost switches | 300 |
| c) door switches | 50 000 |
| d) on/off switches | 300 |
| e) thermostats which control MOTOR-COMPRESSORS | 100 000 |
| f) temperature limiters which control defrosting heaters | 100 000 |
| g) MOTOR-COMPRESSOR starting relays | 100 000 |
| h) self-resetting thermal motor-protector for MOTOR-COMPRESSORS | 2 000 |
| NOTE 2 000 or the number of operations during the 15-day locked rotor test, whichever is the greater. | |
| i) non-self resetting thermal motor-protector for MOTOR-COMPRESSORS | 50 |
| j) other automatic thermal motor-protectors except for fan motors | 2 000 |
| k) other manual reset thermal motor-protectors | 30 |
| l) interlock devices | 100 000 |

NOTE 2 000 or the number of operations during the 15-day locked rotor test, whichever is the greater.

Table CC.4 – Minimum wall thickness for copper and steel tubing

Outside diameter		Copper				Steel	
		Protected within refrigerator		Unprotected			
inches	(mm)	inches	(mm)	inches	(mm)	inches	(mm)
1/4	(6,35)	0,024 5	(0,623)	0,026 5	(0,673)	0,025	(0,635)
5/16	(7,94)	0,024 5	(0,623)	0,026 5	(0,673)	0,025	(0,635)
3/8	(9,53)	0,024 5	(0,623)	0,026 5	(0,673)	0,025	(0,635)
1/2	(12,70)	0,024 5	(0,623)	0,028 5	(0,724)	0,025	(0,635)
5/8	(15,88)	0,031 5	(0,799)	0,031 5	(0,799)	0,032	(0,813)
3/4	(19,05)	0,031 5	(0,799)	0,038 5	(0,978)	0,032	(0,813)
7/8	(22,23)	0,041 0	(1,041)	0,041 0	(1,041)	0,046	(1,168)
1	(25,40)	0,046 0	(1,168)	0,046 0	(1,168)	—	—
1-1/8	(28,58)	0,046 0	(1,168)	0,046 0	(1,168)	0,046	(1,168)
1-1/4	(31,75)	0,050 5	(1,283)	0,050 5	(1,283)	0,046	(1,168)
1-3/8	(34,93)	0,050 5	(1,283)	0,050 5	(1,283)	—	—
1-1/2	(38,10)	0,055 5	(1,410)	0,055 5	(1,410)	0,062	(1,575)
1-5/8	(41,28)	0,055 5	(1,410)	0,055 5	(1,410)	—	—
2-1/8	(53,98)	0,064 0	(1,626)	0,064 0	(1,626)	—	—
2-5/8	(66,68)	0,074 0	(1,880)	0,074 0	(1,880)	—	—

The nominal wall thickness of the tubing will have to be greater than the thickness indicated to maintain the minimum wall thickness.

Annex DD (informative)

Equipment containing FLAMMABLE REFRIGERANTS – Information and marking requirements

DD.1 Marking, installation and operating instructions (SB6)

NOTE For the US, additional marking and informational requirements exist for refrigerating equipment which utilize FLAMMABLE REFRIGERANTS. The source document reference, UL 471, Annex SB6 (SB6), is included in brackets at the end of each subclause.

DD.1.1 Marking

When a FLAMMABLE REFRIGERANT is used, the markings as outlined in DD.1.2 to DD.1.5, or equivalent shall

- a) be in letters no less than 6,4 mm (1/4 inch) high;
- b) be permanently marked on the refrigerating equipment in the indicated locations (SB6.1.1 revised, November 17, 2014).

DD.1.2 OPERATOR markings

"DANGER – Risk Of Fire Or Explosion. FLAMMABLE REFRIGERANT Used. Do Not Use Mechanical Devices To Defrost Refrigerating Equipment. Do Not Puncture REFRIGERANT Tubing".

This marking shall be provided on or near any EVAPORATORS that can be contacted by the OPERATOR (SB6.1.2 revised, June 28, 2013).

DD.1.3 Service markings

For self-contained refrigerating equipment, the following markings shall be located near the machine compartment. For a remote CONDENSING UNIT, the following markings shall be located near the inter-connecting REFRIGERANT tubing connections and the nameplate:

- a) "DANGER – Risk Of Fire Or Explosion. FLAMMABLE REFRIGERANT Used. To Be Repaired Only By Trained Service Personnel. Do Not Puncture REFRIGERANT Tubing".
- b) "CAUTION – Risk Of Fire Or Explosion. FLAMMABLE REFRIGERANT Used. Consult Repair Manual/Owner's Guide Before Attempting To Install or Service This Equipment. All Safety Precautions Must be Followed".

(SB6.1.3 revised, November 30, 2012)

DD.1.4 Disposal

"CAUTION – Risk Of Fire Or Explosion. Dispose Of Properly In Accordance With Federal Or Local Regulations. FLAMMABLE REFRIGERANT Used".

This marking shall be provided on the exterior of the refrigerating equipment.

DD.1.5 Exposed tubing

"CAUTION – Risk Of Fire Or Explosion Due To Puncture Of REFRIGERANT Tubing; Follow Handling Instructions Carefully. FLAMMABLE REFRIGERANT Used"

This marking shall be provided near all exposed REFRIGERANT tubing.

DD.1.6 Accessing the REFRIGERANT circuit

Refrigeration tubing or other devices through which the REFRIGERANT is intended to be serviced shall be painted, coloured, or labelled red, Pantone® Matching System (PMS) No. 185. This colour shall be present at all places where service puncturing or otherwise creating an opening in the REFRIGERANT circuit might be expected. In the case of a process tube on a MOTOR-COMPRESSOR, the colour mark shall extend at least 2,5 cm (1 inch) from the MOTOR-COMPRESSOR (SB6.1.6 revised, November 17, 2014).

DD.1.7 Symbol for warning of flammable materials

The marking in item DD.1.3 a) shall also contain Symbol 102 of Table 1 for warning of flammable materials.

The colour and format of the symbol shall be exactly the same as shown. The perpendicular height of the triangle shall be at least 15 mm (9/16 in) (SB6.1.7 revised, June 28, 2013).

DD.1.8 Equipment containing a remote CONDENSING UNIT

For equipment containing a remote CONDENSING UNIT, the following marking shall be located near the tubing intended for the connection of the field supplied REFRIGERANT tubing: "CAUTION – This equipment is intended for use with FLAMMABLE REFRIGERANT. Install in accordance with the FLAMMABLE REFRIGERANT requirements specified in the ASHRAE 15".

DD.1.9 Refrigerating equipment intended for laboratory use

Refrigerating equipment intended for laboratory use that contains an A3 REFRIGERANT shall be marked:

"This unit is intended for use in commercial, industrial, or institutional occupancies as defined in the Safety Standard for Refrigeration Systems, ASHRAE 15".

(SB6.1.9 added, November 30, 2012)

DD.2 Installation and operating instructions

DD.2.1 Handling and moving

Installation and operating instructions shall be provided with cautionary statements concerning the handling, moving, and use of the refrigerating equipment to avoid either damaging the REFRIGERANT tubing or increasing the RISK of a leak.

DD.2.2 Packaging markings

The shipping carton of a refrigerating equipment that employs a FLAMMABLE REFRIGERANT shall be marked:

"CAUTION – RISK of Fire or Explosion due to FLAMMABLE REFRIGERANT Used. Follow Handling Instructions Carefully in Compliance with U.S. Government Regulations"

The warning marking of Symbol 102 of Table 1 shall also appear on the shipping carton (SB6.2.2 revised, November 17, 2014).

DD.2.3 Replacement components and servicing

The installation and operating instructions shall indicate that component parts shall be replaced with like components and that servicing shall be done by manufacturer-authorised

personnel, so as to minimize the RISK of possible ignition due to incorrect parts or improper service.

DD.2.4 Installation instructions for equipment containing a remote CONDENSING UNIT

In addition to the above, the installation instructions for equipment containing a remote CONDENSING UNIT shall contain the following:

- a) Information for spaces where pipes containing FLAMMABLE REFRIGERANT are allowed, including statements that (1) the pipework shall be protected from physical damage, and (2) compliance with the installation requirements of ASHRAE 15 shall be observed.
- b) The minimum necessary room volume per REFRIGERATING SYSTEM charge allowed. See Table SB6.1. This may be in the form of a table indicating minimum room volume per REFRIGERANT charge amount, but shall not reference a formula.
- c) Information for handling, installation, cleaning, servicing and disposal of REFRIGERANT.
- d) A warning that the equipment shall not be installed in a room with continuously operating open flame or ignition sources.

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 only

Annex EE (normative)

Non-sparking "n" electrical device

The numbering of the following clauses and subclauses corresponds to the clause and subclause numbers of IEC 60079-15:2010. The following clauses and subclauses of IEC 60079-15:2010 are applicable except as modified hereafter.

11 Supplementary requirements for non-sparking luminaires

This clause of IEC 60079-15:2010 is applicable, with the exception of the following subclauses: 11.2.4.1, 11.2.4.5, 11.2.5, 11.2.6, 11.2.7, 11.3.4, 11.3.5, 11.3.6 and 11.4.

19 Supplementary requirements for sealed devices producing arcs, sparks or hot surfaces

This clause of IEC 60079-15:2010 is applicable, except for 19.1 and 19.6, which are replaced as follows:

19.1 Non-metallic materials

Replacement:

Seals are tested in accordance with 22.5. However, if the device is tested in the equipment, then 22.5.1 and 22.5.2 are not applicable. However, after the tests of 4.4, an inspection shall reveal no damage of the encapsulation, such as cracks in the resin or exposure of encapsulated parts that could impair the type of protection.

19.6 Type tests

Replacement:

The type tests described in 22.5 shall be performed where relevant.

20 Supplementary requirements for restricted-breathing enclosures protecting equipment producing arcs, sparks or hot surfaces

This clause of IEC 60079-15:2010 is applicable.

Bibliography

The Bibliography of Part 1 is applicable except as follows:

Addition:

Additional references:

IEC 60050-426:2008, *International Electrotechnical Vocabulary (IEV) – Part 426: Equipment for explosive atmospheres*

IEC 60068-1, *Environmental testing – Part 1: General and guidance*

IEC 60068-2-1, *Environmental testing – Part 2-1: Tests – Test A: Cold*

IEC 60068-2-2, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60068-2-5, *Environmental testing – Part 2-5: Tests – Test S: Simulated solar radiation at ground level and guidance for solar radiation testing and weathering*

IEC 60068-2-10, *Environmental testing – Part 2-10: Tests – Test J and guidance: Mould growth*

IEC 60068-2-11, *Environmental testing – Part 2-11: Tests. Test Ka: Salt mist*

IEC 60068-2-13, *Environmental testing – Part 2-13: Tests. Test M: Low air pressure*

IEC 60068-2-14, *Environmental testing – Part 2-14: Tests – Test N: Change of temperature*

IEC 60068-2-30, *Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60068-2-38, *Environmental testing – Part 2-38: Tests – Test Z/AD: Composite temperature/humidity cyclic test*

IEC 60068-2-39, *Environmental testing – Part 2-39: Tests – Tests and guidance: Combined temperature or temperature and humidity with low air pressure tests*

IEC 60068-2-40, *Environmental testing – Part 2-40: Tests. Test Z/AM: Combined cold/low air pressure tests*

IEC 60068-2-41, *Environmental testing – Part 2-41: Tests. Test Z/BM: Combined dry heat/low air pressure tests*

IEC 60068-2-53, *Environmental testing – Part 2-53: Tests and guidance – Combined climatic (temperature/humidity) and dynamic (vibration/shock) tests*

IEC 60068-2-66, *Environmental testing – Part 2: Test methods – Test Cx: Damp heat, steady state (unsaturated pressurized vapour)*

IEC 60068-2-67, *Environmental testing – Part 2-67: Tests – Test Cy: Damp heat, steady state, accelerated test primarily intended for components*

IEC 60068-2-78, *Environmental testing – Part 2-78: Tests – Test Cab: Damp heat, steady state*

IEC 60068-3-5, *Environmental testing – Part 3-5: Supporting documentation and guidance – Confirmation of the performance of temperature chambers*

IEC 60079 (all parts), *Explosive atmospheres*

IEC 60204-1, *Safety of machinery – Electrical equipment of machines – Part 1: General requirements*

IEC 60335-2-24:2010, *Household and similar electrical appliances – Safety – Part 2-24: Particular requirements for refrigerating appliances, ice-cream appliances and ice makers*
IEC 60335-2-24:2010/AMD2:2017

IEC 60335-2-40:2018, *Household and similar electrical appliances – Safety – Part 2-40: Particular requirements for electrical heat pumps, air-conditioners and dehumidifiers*

IEC 60335-2-41, *Household and similar electrical appliances – Safety – Part 2-41: Particular requirements for pumps*

IEC 60335-2-73, *Household and similar electrical appliances – Safety – Part 2-73: Particular requirements for fixed immersion heaters*

IEC 60335-2-74, *Household and similar electrical appliances – Safety – Part 2-74: Particular requirements for portable immersion heaters*

IEC 60335-2-89, *Household and similar electrical appliances – Safety – Part 2-89: Particular requirements for commercial refrigerating appliances with an incorporated or remote refrigerant unit or compressor*

IEC 60335-2-98, *Household and similar electrical appliances – Safety – Part 2-98: Particular requirements for humidifiers*

IEC 61010-2-010, *Safety requirements for electrical equipment for measurement, control and laboratory use – Part 2-010: Particular requirements for laboratory equipment for the heating of materials*

IEC 61770, *Electric appliances connected to the water mains – Avoidance of backsiphonage and failure of hose-sets*

ISO 817:2014, *Refrigerants – Designation and safety classification*

ISO 4126-1, *Safety devices for protection against excessive pressure – Part 1: Safety valves*

ISO 5149-1:2014, *Refrigerating systems and heat pumps – Safety and environmental requirements – Part 1: Definitions, classification and selection criteria*

ISO 9227, *Corrosion tests in artificial atmospheres – Salt spray tests*

ISO 7000, *Graphical symbols for use on equipment – Registered symbols* (available from: <http://www.graphical-symbols.info/equipment>)

ANSI/ASHRAE 15, *Safety standard for refrigeration systems*

ANSI/ASHRAE 34, *Designation and classification of refrigerants*

EN 378-1:2008, *Refrigerating systems and heat pumps – Safety and environmental requirements – Part 1: Basic requirements, definitions, classification and selection criteria*
EN 378-1:2008/AMD2:2012

EN 378-2, *Refrigerating systems and heat pumps – Safety and environmental requirements – Part 2: Design, construction, testing, marking and documentation*

EN 378-3, *Refrigerating systems and heat pumps. Safety and environmental requirements – Part 3: Installation site and personal protection*

EN 378-4, *Refrigerating systems and heat pumps. Safety and environmental requirements – Part 4: Operation, maintenance, repair and recovery*

EN 809, *Pumps and pump units for liquids – Common safety requirements*

EN 837-1, *Pressure gauges – Part 1 Bourdon tube pressure gauges – Dimensions, metrology, requirements and testing*

EN 837-2, *Pressure gauges – Part 2: Selection and installation recommendations for pressure gauges*

EN 837-3, *Pressure gauges – Part 3: Diaphragm and capsule pressure gauges – Dimensions, metrology, requirements and testing*

EN 1736, *Refrigerating systems and heat pumps – Flexible pipe elements, vibration isolators, expansion joints and non-metallic tubes – Requirements, design and installation*

EN 1779, *Non-destructive testing. Leak testing. Criteria for method and technique selection*

EN 12178, *Refrigeration systems and heat pumps – Liquid level indicating devices – Requirements, testing and marking*

EN 12263, *Refrigerating systems and heat pumps – Safety – Switching devices for limiting the pressure – Requirements and tests*

EN 12284, *Refrigeration systems and heat pumps – Valves – Requirements, testing and marking*

EN 12693, *Refrigerating systems and heat pumps. Safety and environmental requirements. Positive displacement refrigerant compressors*

DIN 12876-1, *Electrical laboratory devices – Laboratory circulators and baths – Part 1: Terms and classification*

DIN 12876-2, *Electrical laboratory devices – Laboratory circulators and baths – Part 2: Determination of ratings of heating and refrigerated circulators*

DIN 12876-3, *Electrical laboratory devices – Laboratory circulators and baths – Part 3: Determination of ratings of laboratory baths*

EN 13445 (all parts) *Unfired pressure vessels*

EN 13480 (all parts), *Metallic industrial piping*

EN 14276-1, *Pressure equipment for refrigerating systems and heat pumps – Part 1 Vessels – General requirements*

EN 14276-2, *Pressure equipment for refrigerating systems and heat pumps – Part 2 Piping – General requirements*

MIL-STD-810 G, *Environmental Engineering Considerations and Laboratory Tests*

UL 471 – Standard for Commercial Refrigerators and Freezers; 10th Edition, Annex SB6

ASME, Boiler and Pressure Vessel Code 2017

ICH, *Harmonised Tripartite Guideline, published by the International Conference on Harmonization of Technical Regulations for Registration of Pharmaceuticals for Human Use*

NCR-101, *Plant Growth Chamber Handbook, a publication of NCR-101 on Controlled Environment Technology and Use*

World Health Organization, *Laboratory Biosafety Manual*

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV

SOMMAIRE

AVANT-PROPOS	90
INTRODUCTION.....	93
1 Domaine d'application et objet.....	96
2 Références normatives	97
3 Termes et définitions	97
4 Essais	103
5 Marquage et documentation	110
6 Protection contre les chocs électriques.....	121
7 Protection contre les DANGERS mécaniques	122
8 Résistance aux contraintes mécaniques	124
9 Protection contre la propagation du feu	125
10 Limites de température de l'appareil et résistance à la chaleur	126
11 Protection contre les DANGERS des fluides et des corps solides étrangers.....	131
12 Protection contre les radiations, y compris les sources laser, et contre la pression acoustique et ultrasonique.....	147
13 Protection contre les émissions de gaz et substances, les explosions et les implosions	148
14 Composants et sous-ensembles	151
15 Protection par systèmes de verrouillage	152
16 DANGERS résultant de l'application	154
17 Appréciation du RISQUE.....	155
Annexes	156
Annexe K (normative) Exigences d'isolation non couvertes par 6.7	157
Annexe L (informative) Index des termes définis	158
Annexe AA (informative) Symboles utiles.....	160
Annexe BB (informative) Protection des individus se trouvant à l'intérieur d'un APPAREIL MOBILE	163
Annexe CC (informative) Exigences de sécurité pour les composants et les tuyauteries.....	165
Annexe DD (informative) Appareils contenant des FLUIDES FRIGORIGENES INFLAMMABLES – Exigences relatives aux informations et au marquage	170
Annexe EE (normative) Dispositif électrique sans étincelle "n"	173
Bibliographie.....	174
Figure 101 – Schéma d'un SYSTEME FRIGORIFIQUE comportant un CONDENSEUR	94
Figure 102 – Organigramme représentant le processus de sélection.....	95
Figure 103 – Détails de la pointe de l'OUTIL à rayer	142
Tableau 1 – Symboles	111
Tableau 101 – Conditions de température-temps	118
Tableau 102 – Températures maximales pour les MOTOCOMPRESSEURS.....	128
Tableau 103 – Température minimale pour la détermination de la PRESSION DE VAPEUR SATURÉE du FLUIDE FRIGORIGENE	137

Tableau 104 – Paramètres d'inflammabilité du FLUIDE FRIGORIGENE.....	146
Tableau AA.1 – Symboles utiles.....	160
Tableau CC.1 – Paramètres des récipients sous pression conformément à l'EN 14276-1....	166
Tableau CC.2 – Paramètres des tuyauteries conformément à l'EN 14276-2	167
Tableau CC.3 – Exigences relatives aux composants et aux tuyauteries.....	168
Tableau CC.4 – Épaisseur minimale de paroi pour les tubes en cuivre et en acier	169

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

RÈGLES DE SÉCURITÉ POUR APPAREILS ÉLECTRIQUES DE MESURAGE, DE RÉGULATION ET DE LABORATOIRE –

Partie 2-012: Exigences particulières pour les appareils d'essais climatiques et d'environnement, et autres appareils de conditionnement de température

AVANT-PROPOS

- 1) La Commission Électrotechnique Internationale (IEC) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de l'IEC). L'IEC a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. À cet effet, l'IEC – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de l'IEC"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec l'IEC, participent également aux travaux. L'IEC collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de l'IEC concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de l'IEC intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de l'IEC se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de l'IEC. Tous les efforts raisonnables sont entrepris afin que l'IEC s'assure de l'exactitude du contenu technique de ses publications; l'IEC ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de l'IEC s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de l'IEC dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de l'IEC et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) L'IEC elle-même ne fournit aucune attestation de conformité. Des organismes de certification indépendants fournissent des services d'évaluation de conformité et, dans certains secteurs, accèdent aux marques de conformité de l'IEC. L'IEC n'est responsable d'aucun des services effectués par les organismes de certification indépendants.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à l'IEC, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de l'IEC, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de l'IEC ou de toute autre Publication de l'IEC, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments de la présente Publication de l'IEC peuvent faire l'objet de droits de brevet. L'IEC ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de brevets et de ne pas avoir signalé leur existence.

La Norme internationale IEC 61010-2-012 a été établie par le comité d'études 66 de l'IEC: Sécurité des appareils de mesure, de commande et de laboratoire.

Elle a le statut d'une publication groupée de sécurité conformément au Guide IEC 104.

Cette deuxième édition annule et remplace la première édition parue en 2016. Cette édition constitue une révision technique.

Cette édition inclut les modifications techniques majeures suivantes par rapport à la l'édition précédente:

- a) alignement sur les modifications introduites par l'Amendement 1 de l'IEC 61010-1:2010;
- b) modifications relatives à l'utilisation de petites capitales uniquement pour les termes définis;
- c) clarifications concernant les essais de refroidissement au 4.4.2.10;
- d) exigences relatives à la protection contre les surtempératures au 10.101, comprenant la suppression de la seconde partie de b) et c);
- e) modifications relatives à l'emploi exact des termes "température", "température de fonctionnement", "température de service", "température d'application", "température ambiante" aux 3.5.104, 3.5.105, 4.3.1, 4.3.2, 5.4.2, 8.2.1, 8.2.2, 11.7.2.101.2, 11.7.2.101.3, 13.2.102, 14.102, 15.101, 15.102, 15.103, à l'Introduction et à d'autres nombreux endroits. Pour des besoins de clarification, la définition du 3.5.114, TEMPERATURE REGULEE est ajoutée.

Le texte de cette Norme internationale est issu des documents suivants:

FDIS	Rapport de vote
66/687/FDIS	66/688/RVD

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à l'approbation de cette Norme internationale.

Ce document a été rédigée selon les Directives ISO/IEC, Partie 2.

Une liste de toutes les parties de la série IEC 61010, publiées sous le titre général, *Règles de sécurité pour appareils électriques de mesurage, de régulation et de laboratoire*, peut être consultée sur le site web de l'IEC.

L'IEC 61010-2-012 doit être utilisée conjointement avec la dernière édition de l'IEC 61010-1. Elle a été établie sur la base de la troisième édition (2010) et de son Amendement 1 (2016), ci-après dénommée la Partie 1.

La présente Partie 2-012 complète ou modifie les articles correspondants de l'IEC 61010-1 de façon à la transformer en norme IEC: *Exigences particulières pour les appareils d'essais climatiques et d'environnement, et autres appareils de conditionnement de température*.

Lorsqu'un paragraphe particulier de la Partie 1 n'est pas mentionné dans la présente Partie 2-012, ce paragraphe est applicable pour autant qu'il soit raisonnable. Lorsque la présente Partie 2-012 spécifie "addition", "modification", "remplacement" ou "suppression", il convient d'adapter en conséquence l'exigence, la modalité d'essai ou la note correspondante de la Partie 1.

Dans la présente norme:

- 1) les caractères d'imprimerie suivants sont utilisés:
 - exigences et définitions: caractères romains;
 - NOTES: petits caractères romains;
 - *conformité et essais: caractères italiques;*
 - termes définis à l'Article 3 et utilisés dans toute cette norme: PETITES CAPITALES ROMAINES.
- 2) les paragraphes, figures, tableaux et notes qui viennent en supplément de ceux de la Partie 1 sont numérotés à partir de 101. Les annexes supplémentaires sont identifiées par des lettres à partir de AA.

Le comité a décidé que le contenu de ce document ne sera pas modifié avant la date de stabilité indiquée sur le site web de l'IEC sous "<http://webstore.iec.ch>" dans les données relatives au document recherché. À cette date, le document sera

- reconduit,
- supprimé,
- remplacé par une édition révisée, ou
- amendé.

IMPORTANT – Le logo "*colour inside*" qui se trouve sur la page de couverture de cette publication indique qu'elle contient des couleurs qui sont considérées comme utiles à une bonne compréhension de son contenu. Les utilisateurs devraient, par conséquent, imprimer cette publication en utilisant une imprimante couleur.

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019

INTRODUCTION

La présente Partie 2-012, la Partie 2-010 et la Partie 2-011 pris ensemble, couvrent les DANGERS spécifiques associés à l'échauffement et au refroidissement des matières par des appareils, et sont organisés comme suit:

IEC 61010-2-010	Couvre spécifiquement les DANGERS associés aux appareils comportant des systèmes d'échauffement.
IEC 61010-2-011	Couvre spécifiquement les DANGERS associés aux appareils comportant des SYSTEMES FRIGORIFIQUES.
IEC 61010-2-012	Couvre spécifiquement les DANGERS associés aux appareils comportant à la fois des systèmes de chauffage et des SYSTEMES FRIGORIFIQUES qui interagissent entre eux de sorte que les systèmes FRIGORIFIQUES et de chauffage combinés génèrent des DANGERS supplémentaires ou plus graves pour les deux systèmes que s'ils sont traités séparément. Elle couvre également les DANGERS associés au traitement des matières par d'autres facteurs tels que l'exposition aux rayonnements, une humidité excessive, la présence de CO ₂ , un MOUVEMENT MECANIQUE, etc.

Recommandations pour l'application de la ou des partie(s) 2 appropriée(s)

Lorsque l'appareil comprend uniquement un système d'échauffement des matières, et aucun SYSTEME FRIGORIFIQUE, ou lorsque d'autres facteurs d'environnement s'appliquent, la Partie 2-010 s'applique sans que la Partie 2-011 ou la Partie 2-012 ne s'avère nécessaire. De façon analogue, lorsque l'appareil comprend uniquement un SYSTEME FRIGORIFIQUE, et aucun système d'échauffement des matières, ou lorsque d'autres facteurs d'environnement s'appliquent, la Partie 2-011 s'applique sans que la Partie 2-010 ou la Partie 2-012 ne s'avère nécessaire. Toutefois, lorsque l'appareil comporte à la fois un système d'échauffement des matières et un SYSTEME FRIGORIFIQUE ou lorsque les matériaux traités dans l'application prévue génèrent une chaleur importante dans le SYSTEME FRIGORIFIQUE, il convient de déterminer si l'interaction entre les deux systèmes engendre des DANGERS supplémentaires ou plus graves que si les systèmes étaient évalués séparément (TEMPERATURE REGULEE, voir organigramme pour le processus de sélection). Lorsque l'interaction des fonctions de chauffage et de refroidissement n'engendre aucun DANGER supplémentaire ou plus grave, les deux Parties 2-010 et 2-011 s'appliquent pour leurs fonctions respectives. Inversement, si des DANGERS supplémentaires ou plus graves proviennent de la combinaison des fonctions de chauffage et de refroidissement, ou lorsque l'appareil inclut des facteurs de traitement des matières supplémentaires, la Partie 2-012 s'applique alors, contrairement aux Parties 2-010 et 2-011.


Quels DANGERS sont applicables dans le cas d'un SYSTEME FRIGORIFIQUE?

Les DANGERS typiques dans le cas d'un SYSTEME FRIGORIFIQUE (voir Figure 101) comprenant un MOTOCOMPRESSEUR, un CONDENSEUR, un dispositif de dilatation et un EVAPORATEUR incluent entre autres:

- La température maximale COTE BASSE PRESSION (température de retour) en direction du MOTOCOMPRESSEUR. Un MOTOCOMPRESSEUR comporte un moteur refroidi par FLUIDE FRIGORIGENE, et il convient d'établir que les températures maximales du COTE BASSE PRESSION dans les conditions les plus défavorables ne dépassent pas les CARACTERISTIQUES ASSIGNEES d'isolation du moteur.
- La pression maximale COTE BASSE PRESSION au niveau de l'admission du MOTOCOMPRESSEUR. L'enveloppe du MOTOCOMPRESSEUR est exposée à cette pression et il convient d'adapter les CARACTERISTIQUES ASSIGNEES de conception du MOTOCOMPRESSEUR aux pressions les plus défavorables tout en fournissant la marge de sécurité correcte pour un récipient sous pression.
- La température maximale COTE HAUTE PRESSION en direction du CONDENSEUR. Les températures COTE HAUTE PRESSION dans les conditions les plus défavorables peuvent présenter un DANGER lié à la température en cas d'exposition de l'OPERATEUR ou de détérioration de l'isolation électrique.

- La pression maximale COTE HAUTE PRESSION au niveau de la sortie du MOTOCOMPRESSEUR. Les composants FRIGORIGENES en aval du MOTOCOMPRESSEUR jusqu'au niveau du dispositif de dilatation sont exposés à cette pression et il convient d'adapter leurs CARACTERISTIQUES ASSIGNEES de conception aux pressions les plus défavorables tout en fournissant la marge de sécurité appropriée pour un récipient sous pression.
- Les TEMPERATURES REGULEES maximales, à savoir les CONDITIONS DE TEMPERATURE DE TREMPAGE auxquelles la chaleur est extraite, peuvent affecter la température maximale COTE BASSE PRESSION en direction du MOTOCOMPRESSEUR, ainsi que présenter un DANGER lié à la température en cas d'exposition de l'OPERATEUR ou de détérioration de l'isolation électrique. Que cette TEMPERATURE REGULEE soit issue d'une fonction de chauffage intégrée du dispositif ou de la chaleur dissipée de la matière refroidie, il convient d'évaluer l'effet dans les conditions les plus défavorables.
- Il convient d'établir l'appel de courant de l'appareil lorsque les conditions de fonctionnement les plus défavorables du SYSTEME FRIGORIFIQUE sont prises en compte, y compris les cycles de dégivrage éventuels qui peuvent s'appliquer.


Il convient de déterminer les conditions les plus défavorables pour les appareils qui comprennent à la fois les conditions d'UTILISATION NORMALE les plus défavorables, et les résultats d'essai les plus défavorables dans des CONDITIONS DE PREMIER DEFECT.



IEC

Figure 101 – Schéma d'un SYSTEME FRIGORIFIQUE comportant un CONDENSEUR

Le processus de sélection est représenté dans l'organigramme suivant (voir Figure 102).



IEC

NOTE Lire "température régulée" (controlled temperature) en lieu et place de "température d'application".

Figure 102 – Organigramme représentant le processus de sélection

RÈGLES DE SÉCURITÉ POUR APPAREILS ÉLECTRIQUES DE MESURAGE, DE RÉGULATION ET DE LABORATOIRE –

Partie 2-012: Exigences particulières pour les appareils d'essais climatiques et d'environnement, et autres appareils de conditionnement de température

1 Domaine d'application et objet

Cet article de la Partie 1 est applicable à l'exception de ce qui suit:

1.1.1 Appareils inclus dans le domaine d'application

Remplacement:

Remplacer le deuxième alinéa par le suivant:

La présente partie de l'IEC 61010 spécifie les exigences de sécurité pour les appareils électriques et leurs accessoires relevant des catégories a) à c) quelle que soit l'utilisation à laquelle ils sont destinés, lorsque ces appareils comprennent une ou plusieurs des caractéristiques suivantes:

- Un SYSTEME FRIGORIFIQUE affecté ou influencé par une fonction de chauffage intégrée de sorte que le SYSTEME FRIGORIFIQUE et de chauffage combiné engendre des DANGERS supplémentaires et/ou plus graves que ceux pour les deux systèmes s'ils sont traités séparément.
- Les matières traitées dans l'application prévue génèrent une chaleur importante dans le SYSTEME FRIGORIFIQUE, de sorte que le SYSTEME FRIGORIFIQUE dans l'application engendre des DANGERS supplémentaires et/ou plus graves que ceux pour le SYSTEME FRIGORIFIQUE dans le cas où il est utilisé seul à la température ambiante ASSIGNEE maximale.
- Une fonction d'exposition aux rayonnements pour les matières traitées qui présentent des DANGERS supplémentaires.
- Une fonction dédiée à l'exposition des matières traitées à une humidité excessive, au dioxyde de carbone, au brouillard salin ou à d'autres substances qui peuvent engendrer des DANGERS supplémentaires.
- Une fonction de MOUVEMENT MECANIQUE qui présente des DANGERS supplémentaires.
- Un dispositif qui permet le déplacement de l'OPERATEUR vers la zone de manœuvre afin de charger ou décharger les matières traitées.

Addition:

Ajouter le texte suivant après le dernier alinéa:

NOTE 101 Les exemples de ce type d'appareils incluent les ENCEINTES pour essais d'environnement et les ENCEINTES D'ESSAI dédiées à la croissance des plantes, les THERMOSTATS de réfrigération comportant une fonction de chauffage et les refroidisseurs à recirculation pour l'extraction de la chaleur.

Il est possible qu'une ou toutes les parties de l'appareil relèvent du domaine d'application d'une ou plusieurs autres Parties 2 de l'IEC 61010, ainsi que du domaine d'application de la présente norme. Dans ce cas, les exigences de ces autres Parties 2 s'appliquent également. Ce document s'applique lorsqu'un ou plusieurs des dangers supplémentaires décrits dans les alinéas en pointillés ci-dessus sont introduits. Cependant, lorsque l'appareil comprend uniquement un système frigorifique ou uniquement une fonction de chauffage ou une combinaison des deux sans introduire de dangers supplémentaires décrits dans les alinéas

pointillés ci-dessus, alors l'IEC 61010-2-011 ou l'IEC 61010-2-010 ou les deux, selon le cas, s'appliquent en lieu et place de la présente Partie 2-012.

Voir d'autres informations dans l'organigramme (Figure 102) pour le processus de sélection et les recommandations dans l'Introduction.

NOTE 102 Le paragraphe 3.1.107 et l'Annexe BB fournissent la définition et les exigences concernant la protection des personnes qui se trouvent à l'intérieur d'APPAREILS MOBILES.

1.1.2 Appareils exclus du domaine d'application

Addition:

Ajouter les points suivants après le point j):

- aa) appareils pour le chauffage, le refroidissement et la ventilation des laboratoires;
- bb) appareils de stérilisation.

1.2 Objet

1.2.1 Aspects inclus dans le domaine d'application

Addition:

Ajouter les points suivants après le point g):

- aa) DANGERS biologiques (voir 13.101);
- bb) substances chimiques dangereuses (voir 13.102).

2 Références normatives

Cet article de la Partie 1 est applicable à l'exception de ce qui suit:

Addition:

IEC 60079-15:2010, *Atmosphères explosives – Partie 15: Protection du matériel par mode de protection "n"*

IEC 60079-20-1, *Atmosphères explosives – Partie 20-1: Caractéristiques des substances pour le classement des gaz et des vapeurs – Méthodes et données d'essai*

IEC 60335-2-34:2012, *Appareils électrodomestiques et analogues – Sécurité – Partie 2-34: Exigences particulières pour les motocompresseurs*

IEC 60335-2-34:2012/AMD1:2015

IEC 60335-2-34:2012/AMD2:2016

IEC 60950-1:2005, *Matériels de traitement de l'information – Sécurité – Partie 1: Exigences générales*

ISO 7010, *Symboles graphiques – Couleurs de sécurité et signaux de sécurité – Signaux de sécurité enregistrés (disponible à l'adresse <http://www.iso.org/obp>)*

3 Termes et définitions

Cet article de la Partie 1 est applicable à l'exception de ce qui suit:

3.1 Appareils et états des appareils

Addition:

Ajouter les nouveaux termes et définitions suivants:

3.1.101

BAIN-MARIE

dispositif complet destiné à appliquer des TEMPERATURES REGULEES à des EPROUVETTES par immersion dans un MOYEN DE TRANSFERT DE CHALEUR liquide thermostaté

3.1.102

THERMOSTAT

appareil destiné à appliquer des TEMPERATURES REGULEES à un SYSTEME D'APPLICATION par circulation externe d'un MOYEN DE TRANSFERT DE CHALEUR liquide thermostaté

3.1.103

ENCEINTE D'ESSAI

ENVELOPPE ou espace dans une partie de laquelle ou duquel des conditions spécifiées peuvent être obtenues, notamment, la température, l'humidité, l'exposition aux rayonnements, une basse pression atmosphérique, la formation de moisissure et le brouillard salin

3.1.104

ENCEINTE D'ESSAI COMBINEE

ENCEINTE D'ESSAI spéciale combinée avec la fonction de MOUVEMENT MECANIQUE, par exemple, pour des essais de vibrations, de chocs, de résistance au choc et des essais dynamiques analogues

3.1.105

INCUBATEUR

ENCEINTE D'ESSAI spéciale, principalement dédiée à l'incubation des micro-organismes et de la culture cellulaire

3.1.106

AGITATEUR

appareil destiné à la dispersion ou à la dissolution d'une substance dans une autre par MOUVEMENT MECANIQUE sans l'utilisation de pales ou d'agitateurs qui peuvent détruire la structure de la substance, notamment, le BAIN-MARIE et l'INCUBATEUR à agitation

3.1.107

APPAREIL MOBILE

ENCEINTE D'ESSAI ou INCUBATEUR dont la porte permet à l'OPERATEUR de pénétrer et rester à l'intérieur de l'appareil, même avec la porte fermée

3.1.108

SECHAGE

laps de temps devant s'écouler ou procédure à effectuer avant le fonctionnement, afin que l'appareil soit à nouveau en CONDITION NORMALE s'il a été transporté ou stocké dans des conditions humides, ou déplacé d'un environnement froid à un environnement bien plus chaud susceptible de présenter de la condensation, ce qui peut provoquer la non-conformité de l'appareil à toutes les exigences de sécurité du présent document

3.1.109

ARRET

laps de temps devant s'écouler ou procédure à effectuer avant le fonctionnement, afin que l'appareil soit à nouveau en CONDITION NORMALE s'il a été transporté, déplacé, agité, incliné ou retourné, ce qui peut alors provoquer la non-conformité de l'appareil à toutes les exigences de sécurité du présent document

3.2 Parties et accessoires

Addition:

Ajouter les nouveaux termes et définitions suivants:

3.2.101

ELEMENT DE CHAUFFAGE PAR RESISTANCE

partie d'un appareil de chauffage par résistance, comprenant une ou plusieurs résistances chauffantes, essentiellement constituées de conducteurs métalliques ou d'une substance électriquement conductrice, convenablement isolée et protégée

[SOURCE: IEC 60050-426:2008, 426-08-08, modifié – "unité de chauffage par résistance" a été remplacé par "appareil de chauffage par résistance".]

3.2.102

SYSTEME FRIGORIFIQUE

ensemble de parties contenant du FLUIDE FRIGORIGENE, reliées les unes aux autres et constituant un circuit frigorifique fermé dans lequel un FLUIDE FRIGORIGENE circule en vue d'extraire et de rejeter de la chaleur

[SOURCE: ISO 5149-1:2014, 3.1.9, modifié – Le terme "(pompe à chaleur)" a été enlevé du terme et "(c'est-à-dire refroidir et chauffer)" de la définition et la note a été effacée.]

3.2.103

SYSTEME EN CASCADE

SYSTEME DE REFRIGERATION qui comporte au moins deux circuits de réfrigération indépendants où le CONDENSEUR d'un système rejette la chaleur directement dans l'EVAPORATEUR d'un autre CONDENSEUR

[SOURCE: EN 378-1:2008, 3.1.12, modifié – "SYSTEME DE REFRIGERATION qui comporte" a été ajouté.]

3.2.104

MOTOCOMPRESSEUR

sous-ensemble de réfrigération composé des mécanismes du compresseur et du moteur, enfermés ensemble dans la même enveloppe étanche, sans arbre extérieur, le moteur fonctionnant dans une atmosphère de FLUIDE FRIGORIGENE, avec ou sans huile

Note 1 à l'article: L'enveloppe peut être fermée de façon permanente par soudage ou par brasage (MOTOCOMPRESSEUR hermétique), ou elle peut être fermée par des joints d'étanchéité (MOTOCOMPRESSEUR hermétique accessible). Une boîte de raccordement, une boîte de raccordement intégrée et d'autres composants électriques ou un dispositif de commande électronique peuvent être inclus.

[SOURCE: IEC 60335-2-34:2012, 3.101, modifié – "appareil" a été remplacé par "sous-ensemble de réfrigération".]

3.2.105

CONDENSEUR

échangeur de chaleur dans lequel le FLUIDE FRIGORIGENE à l'état de vapeur se liquéfie en cédant de la chaleur

[SOURCE: ISO 5149:2014, 3.4.4]

3.2.106

GROUPE DE CONDENSATION

combinaison spécifique de sous-ensembles frigorifiques pour un FLUIDE FRIGORIGENE donné, comprenant un ou plusieurs motocompresseurs, des CONDENSEURS, des réservoirs de fluide (si nécessaire) et les accessoires habituellement fournis

3.2.107

EVAPORATEUR

échangeur de chaleur dans lequel le FLUIDE FRIGORIGENE passe à l'état de vapeur en absorbant de la chaleur

[SOURCE: En anglais, IEC 60335-2-40:2018, 3.110]

3.2.108

COTE HAUTE PRESSION

partie du SYSTEME FRIGORIFIQUE fonctionnant approximativement à la pression de condensation

[SOURCE: ISO 5149-1:2014, 3.1.7]

3.2.109

COTE BASSE PRESSION

partie du SYSTEME FRIGORIFIQUE fonctionnant approximativement à la pression de l'EVAPORATEUR

[SOURCE: ISO 5149-1:2014, 3.1.8]

3.2.110

POMPE DE CIRCULATION

pompe à pression et/ou aspirante qui transporte le MOYEN DE TRANSFERT DE CHALEUR liquide dans un BAIN-MARIE ou un THERMOSTAT

3.2.111

VENTILATEUR DE CIRCULATION

ventilateur hélicoïde ou turbine centrifuge conçu(e) pour diffuser l'air dans une ENCEINTE D'ESSAI ou un INCUBATEUR avec ou sans conduit d'air

3.2.112

HUMIDIFICATEUR

dispositif électrique qui génère de l'eau atomisée ou de la vapeur et qui la diffuse dans une pièce, une serre ou toute autre ENVELOPPE

3.2.113

CUVE POUR BAIN-MARIE

récipient ouvert ou sous enveloppe qui contient le MOYEN DE TRANSFERT DE CHALEUR dans un BAIN-MARIE ou un THERMOSTAT

3.2.114

CONNEXION DE LIQUIDE

raccord de tuyauterie par lequel le liquide est expulsé d'un récipient ou d'un échangeur de chaleur, ou libéré dans ce même récipient ou échangeur de chaleur

3.2.115

VENTILATEUR

dispositif qui permet de substituer l'air extérieur à l'air intérieur d'une ENCEINTE D'ESSAI ou d'un INCUBATEUR

3.2.116

DISPOSITIF DE LIMITATION DE LA TEMPERATURE

dispositif actionné par la température conçu pour éviter les températures dangereuses

[SOURCE: EN 378-1:2008, 3.6.5]

3.2.117**DISPOSITIF D'ARRET DE NIVEAU DE LIQUIDE**

dispositif déclenchant sur le niveau de liquide pour empêcher tous niveaux de liquide dangereux

[SOURCE: EN 378-1: 2008, 3.6.12]

3.2.118**LIMITEUR DE PRESSION**

dispositif commandé par la pression (par exemple, commutateur haute pression) qui est conçu pour arrêter le fonctionnement de l'élément commandant la pression et qui peut également déclencher une alarme

3.2.119**DISPOSITIF DE SURPRESSION**

soupape ou disque conçu pour libérer automatiquement toute pression excessive

[SOURCE: ISO 5149-1:2014, 3.6.7, modifié – "soupape de sûreté ou dispositif muni d'un disque de rupture" a été remplacé par "soupape ou disque" dans la définition.]

3.2.120**LIQUIDE INFLAMMABLE**

liquide capable de produire un gaz ou une vapeur inflammable, lorsqu'il est mélangé à l'air selon certaines proportions, et qui génère une ATMOSPHERE EXPLOSIVE GAZEUSE dans des conditions de fonctionnement prévisibles

3.2.121**MOYEN DE TRANSFERT DE CHALEUR**

moyen utilisé pour transférer de la chaleur au matériau traité

3.2.122**FLUIDE FRIGORIGENE**

fluide utilisé pour la transmission de la chaleur qui, dans un SYSTEME FRIGORIFIQUE, absorbe de la chaleur à basse température et à basse pression du fluide et rejette de la chaleur à une température et à une pression du fluide plus élevées. Ce processus s'accomplit généralement avec changements d'état du fluide

[SOURCE: En anglais, ISO 817:2014, 3.1.35]

3.2.123**FLUIDE FRIGORIGENE INFLAMMABLE**

FLUIDE FRIGORIGENE ayant une classification d'inflammabilité de classe A2L, A2 ou A3, conformément à l'ISO 817

[SOURCE: IEC 60335-2-24:2010 et IEC 60335-2-24:2010/AMD2:2017, 3.109]

3.2.124**EPROUVETTE**

matière, substance ou produit destiné(e) à être traité(e), par exemple, dans un BAIN-MARIE, une ENCEINTE D'ESSAI ou un INCUBATEUR

3.2.125**SYSTEME D'APPLICATION**

système ou dispositif prévu pour être utilisé avec un THERMOSTAT à des fins de fonctionnement

3.5 Termes de sécurité

Addition:

Ajouter les nouveaux termes et définitions suivants:

3.5.101

PRESSIION DE VAPEUR SATUREE

<D'UN FLUIDE FRIGORIGENE> pression de vapeur à laquelle le liquide et la vapeur peuvent être équilibrés à une température donnée

3.5.102

PRESSIION MAXIMALE ADMISSIBLE

PS

pression maximale pour laquelle l'équipement est conçu, comme spécifiée par le fabricant

Note 1 à l'article: Le terme abrégé "PS" est dérivé du terme anglais développé correspondant "maximum allowable pressure".

[SOURCE: EN 378-1:2008, 3.3.2]

3.5.103

PRESSIION ASSIGNEE

PRESSIION MAXIMALE ADMISSIBLE des composants sous pression des appareils par rapport à leur capacité à résister aux pressions spécifiées par le fabricant

3.5.104

PLAGE DE REGULATION DE REFROIDISSEMENT ACTIVE

PLAGE ACC

plage de TEMPERATURES REGULEES obtenue par un SYSTEME FRIGORIFIQUE actif

Note 1 à l'article: Le terme abrégé "ACC" est dérivé du terme anglais développé correspondant "active cooling control".

3.5.105

POINT D'ECLAIR

température la plus basse du liquide à laquelle, dans des conditions normalisées, un liquide produit des vapeurs en quantité telle qu'elles peuvent former un mélange vapeur/air inflammable

Note 1 à l'article: Au POINT D'ECLAIR, la vapeur peut cesser de brûler lorsque la source d'inflammation est supprimée.

[SOURCE: IEC 60050-426:2008, 426-02-14]

3.5.106

POINT DE FEU

température la plus basse à laquelle une substance soumise à une petite flamme, présentée à sa surface dans des conditions normalisées, s'allume et continue à brûler pendant au moins 5 s

3.5.107

TEMPERATURE D'AUTO-INFLAMMATION

température la plus basse à laquelle une substance s'allume spontanément dans une atmosphère normale sans une source d'inflammation externe, telle qu'une flamme ou une étincelle

Note 1 à l'article: Une fois allumée, la substance continue à brûler jusqu'à être entièrement consumée ou jusqu'à ce que la température des restes de la substance soit égale ou inférieure à son POINT DE FEU.

3.5.108**LIMITE INFERIEURE D'EXPLOSIVITE****LEL**

concentration de gaz ou de vapeur inflammable dans l'air, au-dessous de laquelle une ATMOSPHERE EXPLOSIVE GAZEUSE ne peut pas être formée

Note 1 à l'article: Le terme abrégé "LEL" est dérivé du terme anglais développé correspondant "lower explosive limit".

[SOURCE: IEC 60050-426:2008, 426-02-09]

3.5.109**ATMOSPHERE EXPLOSIVE GAZEUSE**

mélange avec l'air, sous conditions atmosphériques, de substances inflammables sous forme de gaz ou de vapeur qui après inflammation permet une propagation autoentretenu

[SOURCE: IEC 60050-426:2008, 426-01-07]

3.5.110**CONDITION DE TEMPERATURE DE TREMPAGE**

conditions de température dans lesquelles la température ambiante de l'appareil en essai (EUT) est égale à la température maximale ambiante, définie au 1.4.1, à $\pm 2,0$ °C pour des conditions d'UTILISATION NORMALE, de stockage ou de transport, et la TEMPERATURE REGULEE de l'EUT est égale à la PLAGE ACC maximale à $\pm 2,0$ °C, le MOTOCOMPRESSEUR étant en fonctionnement ou, à la TEMPERATURE REGULEE ASSIGNEE maximale avec le MOTOCOMPRESSEUR hors tension

Note 1 à l'article: Le terme abrégé "EUT" est dérivé du terme anglais développé correspondant "equipment under test".

3.5.111**MOUVEMENT MECANIQUE**

mouvement des matières traitées, par exemple, dans un AGITATEUR ou une ENCEINTE D'ESSAI COMBINEE

3.5.112**FREQUENCE DE MOUVEMENT**

nombre de cycles complets de MOUVEMENT MECANIQUE

3.5.113**AMPLITUDE DE MOUVEMENT**

rayon, distance ou angle maximal(e) du MOUVEMENT MECANIQUE

3.5.114**TEMPERATURE REGULEE**

température de localisation de l'EVAPORATEUR et à laquelle le COTE BASSE PRESSION est exposé, à l'issue du transfert de chaleur par chauffage actif ou par le système d'application ou l'EPROUVETTE

Note 1 à l'article: Pour les systèmes à pompe à chaleur, lorsqu'une vanne 4 voies est utilisée pour passer de la chaleur au refroidissement, les fonctions du CONDENSEUR et de l'EVAPORATEUR sont échangées.

4 Essais

Cet article de la Partie 1 est applicable à l'exception de ce qui suit:

4.3 Conditions de référence pour les essais

4.3.1 Conditions d'environnement

Addition:

Ajouter le texte suivant après le point d):

Étant donné que les températures, les pressions et les appels de courant pour un SYSTÈME FRIGORIFIQUE sont influencés de manière significative par les températures ambiantes de manière non linéaire, une extrapolation linéaire des données d'essai n'est pas possible. Par conséquent, les essais visant à établir les températures, les pressions et les appels de courant pour un SYSTÈME FRIGORIFIQUE doivent être menés dans les conditions d'environnement suivantes:

- 1) une température ambiante de 40 °C, ou la température ambiante ASSIGNEE maximale si elle est plus élevée;
- 2) la température d'alimentation en eau est la température maximale telle que spécifiée par le fabricant (voir 5.4.3);
- 3) une humidité relative ne dépassant pas les limites définies en 1.4.1 d), ou l'humidité relative de fonctionnement ASSIGNEE maximale à la température ASSIGNEE maximale, si elle est plus élevée.

Si, tel que le permet la Note 2 du 1.4.1, un SYSTÈME FRIGORIFIQUE a une température ambiante ASSIGNEE inférieure à 40 °C, les essais en CONDITIONS NORMALES doivent être réalisés dans un environnement adapté à la température ambiante ASSIGNEE maximale, puis répétés à une température ambiante de 40 °C. Voir 4.3.2.114.

4.3.2 État de l'appareil

4.3.2.1 Généralités

Remplacement:

Remplacer le premier alinéa et la note par ce qui suit:

Sauf spécification contraire, chaque essai doit être effectué sur l'appareil assemblé pour une UTILISATION NORMALE, et suivant la combinaison la plus défavorable des conditions données de 4.3.2.2 à 4.3.2.13 et de 4.3.2.101 à 4.3.2.114 le cas échéant.

Lors du mesurage des températures, des pressions et des appels de courant des appareils comportant un SYSTÈME FRIGORIFIQUE, les essais doivent commencer dans des CONDITIONS DE TEMPERATURE DE TREMPAGE lorsque toutes les pressions sont totalement équivalentes. Les essais effectués à des valeurs de tension d'entrée extrêmes ($\pm 10\%$) doivent commencer dans ces conditions de tension et atteindre un état stable, mais il n'est pas nécessaire qu'ils commencent dans des CONDITIONS DE TEMPERATURE DE TREMPAGE.

En cas de doute, il peut s'avérer nécessaire de réaliser un essai avec deux combinaisons de conditions ou plus, par exemple, lorsque l'appareil fonctionne à ses TEMPERATURES REGULEES maximale et minimale, ou est soumis à des cycles de fonctionnement à des valeurs comprises entre ses mêmes températures, ou fonctionne en combinaison avec une humidité excessive, une basse pression atmosphérique, un rayonnement ou des conditions de précipitation.

Addition:

Ajouter les nouveaux paragraphes suivants:

4.3.2.101 Charge calorifique

Lorsque l'appareil ou les matières traitées exigent un apport de chaleur ou son évacuation, l'appareil en essai (EUT) doit être chargé avec une source de chaleur/un dissipateur thermique dans les conditions d'utilisation spécifiées par le fabricant (y compris une charge ASSIGNEE maximale et l'absence de charge).

NOTE La DIN 12876 (toutes les parties) prévoit des procédures de détermination de la capacité de refroidissement et de la puissance calorifique efficace de l'appareil.

4.3.2.102 Humidité et vapeur

Lorsque l'appareil génère de l'humidité ou est destiné à être raccordé à une source d'alimentation en vapeur, il doit être réglé pour générer de l'humidité ou être alimenté en vapeur dans les conditions d'utilisation spécifiées par le fabricant (y compris une charge ASSIGNEE maximale et l'absence de charge).

4.3.2.103 Lampes et appareils utilisant des lampes

L'éclairage qui assure une partie de la fonction principale (qu'elle soit intégrée ou constitue un accessoire) doit être installé et utilisé dans les conditions d'utilisation spécifiées par le fabricant (y compris les conditions maximales, hors tension et par cycles).

NOTE Un exemple d'éclairage est une lampe à arc au xénon utilisée dans une ENCEINTE D'ESSAI résistante aux intempéries.

4.3.2.104 MOUVEMENT MECANIQUE

Les appareils comportant une fonction de MOUVEMENT MECANIQUE (pour les matières ou le MOYEN DE TRANSFERT DE CHALEUR) doivent être réglés pour être exposés et exposer toutes matières traitées aux conditions les plus défavorables (y compris les conditions maximales, hors tension et par cycles).

4.3.2.105 Systèmes de pulvérisation

Les systèmes de pulvérisation des appareils doivent être utilisés dans les conditions d'utilisation spécifiées par le fabricant (y compris les conditions maximales, hors tension et par cycles).

4.3.2.106 VENTILATEURS

Les VENTILATEURS doivent être utilisés dans les conditions d'utilisation spécifiées par le fabricant (y compris les conditions maximales, hors tension et par cycles).

4.3.2.107 Pressions autres que celles du FLUIDE FRIGORIGENE

Lorsque l'appareil génère ou utilise des pressions autres que la pression atmosphérique locale, il doit être réglé pour générer ou être alimenté en pression(s) dans les conditions d'utilisation spécifiées par le fabricant (y compris la PRESSION ASSIGNEE maximale et l'absence de pression).

4.3.2.108 Pression du FLUIDE FRIGORIGENE

Lorsqu'un système de chauffage (ou MOYEN DE TRANSFERT DE CHALEUR) peut appliquer au SYSTEME FRIGORIFIQUE une TEMPERATURE REGULEE en dehors de sa PLAGE ACC, l'appareil doit être réglé pour appliquer la TEMPERATURE REGULEE maximale admise par les commandes ou les systèmes de verrouillage avec le MOTOCOMPRESSEUR hors tension ou la PLAGE ACC maximale avec le MOTOCOMPRESSEUR sous tension, selon la condition la plus défavorable.

Lorsqu'un système de chauffage (ou MOYEN DE TRANSFERT DE CHALEUR) peut appliquer au SYSTÈME FRIGORIFIQUE une TEMPÉRATURE RÉGULÉE qui peut affecter la pression du système, la condition la plus défavorable pour la pression doit être établie y compris:

- le fonctionnement continu du MOTOCOMPRESSEUR;
- le démarrage en cours d'essai du MOTOCOMPRESSEUR;
- en dehors de sa PLAGE ACC, avec le MOTOCOMPRESSEUR hors tension, et l'appareil réglé pour appliquer la TEMPÉRATURE RÉGULÉE maximale admise par les commandes ou les systèmes de verrouillage.

4.3.2.109 Refoulement et condensat

Les conditions les plus défavorables qui entraînent la production de refoulement, de vapeurs et/ou de condensats doivent être créées (y compris les conditions maximales et par cycles).

NOTE Les BORNES d'un ÉLÉMENT DE CHAUFFAGE PAR RESISTANCE exposées à la condition ambiante sont facilement sujettes à condensation après le refroidissement du MOYEN DE TRANSFERT DE CHALEUR pendant un moment jusqu'à une température inférieure à la température ambiante.

4.3.2.110 Systèmes de remplissage et de vidange

Ils doivent être utilisés dans les conditions d'utilisation spécifiées par le fabricant (y compris les conditions maximales, minimales et intermédiaires).

4.3.2.111 Système de circulation

La ou les POMPES DE CIRCULATION, le ou les AGITATEURS ou le ou les VENTILATEURS DE CIRCULATION doivent être utilisés dans les conditions d'utilisation spécifiées par le fabricant (y compris les conditions maximales et hors tension).

4.3.2.112 MOYEN DE TRANSFERT DE CHALEUR à l'état gazeux

L'appareil doit être utilisé avec le MOYEN DE TRANSFERT DE CHALEUR à l'état gazeux, qu'il s'agisse de l'air ou d'autres gaz désignés, au pourcentage de teneur et de pression dans les conditions d'utilisation spécifiées par le fabricant (y compris les conditions maximales, minimales et l'absence de conditions).

4.3.2.113 Propriétés du MOYEN DE TRANSFERT DE CHALEUR à l'état liquide

Pour les appareils avec une large plage de TEMPÉRATURES RÉGULÉES, il convient de prendre en considération l'influence de la contraction, de la dilatation, de l'évaporation, de la condensation, de l'oxydation, de l'ébullition et du gel du liquide, ainsi que de sa plage de TEMPÉRATURES RÉGULÉES admissible. Les MOYENS DE TRANSFERT DE CHALEUR qui modifient les états en UTILISATION NORMALE doivent être simulés afin de générer le passage de l'état solide à l'état liquide et inversement.

4.3.2.114 Essai de fonctionnement anormal destiné à simuler la défaillance de l'environnement contrôlé

Pour les SYSTÈMES FRIGORIFIQUES destinés à fonctionner dans un environnement ambiant plus limité que ce qui est spécifié en 1.4.1, cet essai de fonctionnement anormal supplémentaire doit être appliqué pour simuler la défaillance de l'environnement contrôlé dans lequel l'appareil se situe.

Dès lors que sont déterminées les conditions les plus défavorables pour les essais de température et de pression définis en 10.4.1, l'appareil est utilisé dans ces conditions jusqu'à stabilisation. L'environnement d'essai est alors porté aux niveaux de 1.4.1 (40 °C, HR de 50 %) et l'utilisateur laisse l'appareil se stabiliser avant d'enregistrer les températures et pressions maximales. Les dispositifs de protection ne doivent pas être dérivés ou désactivés. Si l'appareil n'atteint pas la stabilisation en raison du fonctionnement des dispositifs de protection, les valeurs maximales enregistrées pour cet essai doivent alors être:

- a) les températures et les pressions maximales au point de fonctionnement de dispositifs non réarmables ou à réarmement manuel, qu'il n'est pas nécessaire de réarmer pendant cet essai; ou
- b) les températures et les pressions maximales obtenues après des cycles continus des dispositifs de protection à réarmement automatique dont le fonctionnement par cycles doit se poursuivre jusqu'à ce qu'il apparaisse clairement que des cycles successifs ne développent pas de valeurs maximales plus élevées.

4.4.2 Application des conditions de défaut

4.4.2.10 Refroidissement

Addition:

Ajouter les points et notes suivants après le point d):

- aa) pour un GROUPE DE CONDENSATION refroidi par air, chaque ventilateur de CONDENSEUR doit être arrêté l'un après l'autre à moins qu'un premier défaut puisse désactiver simultanément tous les ventilateurs de CONDENSEURS, ou en limitant le débit d'air du CONDENSEUR selon le cas le plus défavorable, jusqu'à l'obtention d'une pression stabilisée maximale ou de températures maximales représentatives sous une charge cyclique. Les températures et les pressions doivent être contrôlées selon des intervalles de courte durée tout au long de l'essai afin de garantir la saisie de valeurs de crête. Cet essai est mené à une température ambiante de $25\text{ °C} \pm 3\text{ °C}$.
- bb) pour un GROUPE DE CONDENSATION refroidi par eau, le SYSTEME FRIGORIFIQUE doit être utilisé en coupant l'alimentation en eau de condensation ou en limitant l'eau de condensation selon le cas le plus défavorable jusqu'à l'obtention d'une pression stabilisée maximale ou de températures maximales représentatives sous une charge cyclique. Les températures et les pressions doivent être contrôlées selon des intervalles de courte durée tout au long de l'essai afin de garantir la saisie de valeurs de crête. Cet essai est mené à une température ambiante et à une température de l'eau de $25\text{ °C} \pm 3\text{ °C}$.

Si un LIMITEUR DE PRESSION à réarmement manuel est utilisé pour limiter la pression maximale et/ou minimale COTE HAUTE PRESSION ou COTE BASSE PRESSION, ce dispositif doit alors être réarmé manuellement dans un délai de fonctionnement de 6 s pendant 10 cycles.

NOTE 101 L'état de fonctionnement du MOTOCOMPRESSEUR n'est pas adapté après le fonctionnement du LIMITEUR DE haute PRESSION manuel.

Si un LIMITEUR DE PRESSION à réarmement automatique est utilisé pour limiter la pression maximale et/ou minimale COTE HAUTE PRESSION ou COTE BASSE PRESSION, ce dispositif doit alors pouvoir fonctionner selon des cycles automatiques jusqu'à ce qu'il puisse être démontré que des températures et pressions de crête ont été réalisées.

NOTE 102 Il est possible que la surchauffe d'un MOTOCOMPRESSEUR conçu pour être refroidi par fonctionnement cyclique du FLUIDE FRIGORIGENE soit telle qu'elle engendre des DANGERS, en cas de fuite de ce FLUIDE et de déclenchements répétés du LIMITEUR DE PRESSION COTE BASSE PRESSION.

NOTE 103 La spécification correcte ou le réglage approprié du différentiel de pression (hystérésis) d'un LIMITEUR DE PRESSION à réarmement automatique est important pour certains MOTOCOMPRESSEURS qui exigent une plus longue période d'ARRET (cycle hors tension).

Lorsqu'il peut être démontré qu'un LIMITEUR DE PRESSION fonctionne pendant les essais à la PRESSION MAXIMALE ADMISSIBLE (PS), le fabricant peut choisir de renoncer à l'essai, mais doit régler cette pression pour le COTE HAUTE PRESSION du MOTOCOMPRESSEUR sur la PRESSION ASSIGNEE du LIMITEUR DE PRESSION.

Pour les appareils comportant des CONDENSEURS refroidis par air et par eau, les défauts sont appliqués à chaque CONDENSEUR l'un après l'autre à moins que les appareils ne soient conçus de sorte que l'OPERATEUR puisse choisir d'utiliser soit le CONDENSEUR refroidi par air, soit le

CONDENSEUR refroidi par eau (par exemple, certains appareils sont équipés d'un condenseur refroidi par eau comme auxiliaire au condenseur refroidi par air).

Pour un SYSTEME EN CASCADE, dans lequel un EVAPORATEUR du SYSTEME FRIGORIFIQUE du premier étage agit en tant que CONDENSEUR du SYSTEME FRIGORIFIQUE du second étage, le fabricant peut choisir d'utiliser chaque GROUPE DE CONDENSATION individuellement dans le cadre des essais 4.4.2.10. Dans ce cas, la désactivation du premier SYSTEME FRIGORIFIQUE est définie comme simulant le GROUPE DE CONDENSATION du second étage qui fonctionne dans les conditions de aa) et bb) ci-dessus.

4.4.2.11 Dispositifs de chauffage

Addition:

Ajouter l'alinéa suivant après le point b):

Si un DANGER peut être provoqué par un excès ou un manque de remplissage avec un MOYEN DE TRANSFERT DE CHALEUR à l'état liquide, l'appareil doit être soumis à l'essai à vide, partiellement rempli ou trop rempli, selon le cas le plus défavorable. En cas de doute, l'essai doit être réalisé dans différentes conditions. Le MOYEN DE TRANSFERT DE CHALEUR utilisé pour l'essai doit être d'un type spécifié pour une UTILISATION NORMALE.

Addition:

Ajouter les nouveaux paragraphes suivants:

4.4.2.101 MOTOCOMPRESSEUR

Les températures de l'enveloppe et des enroulements des MOTOCOMPRESSEURS non conformes à l'IEC 60335-2-34 (y compris IEC 60335-2-34:2012, IEC 60335-2-34:2012/AMD1:2015 et IEC 60335-2-34:2012/AMD2:2016, Annexe AA) doivent être mesurées dans les conditions de 19.101, 19.102 et 19.103 de l'IEC 60335-2-34:2012.

Les températures de l'enveloppe et des enroulements des MOTOCOMPRESSEURS conformes à l'IEC 60335-2-34 (y compris IEC 60335-2-34:2012, IEC 60335-2-34:2012/AMD1:2015 et IEC 60335-2-34:2012/AMD2:2016, Annexe AA) ne sont pas mesurées.

4.4.2.102 Fuite de fluide dans l'appareil

Des fuites internes de fluides doivent être simulées.

4.4.2.103 Vanne électromagnétique et vanne motorisée

Les appareils avec lesquels la défaillance d'une vanne électromagnétique ou motorisée peut engendrer un DANGER doivent être soumis à l'essai en maintenant la vanne dans l'état le plus vraisemblablement défectueux (y compris avec ouverture ou fermeture complète, tout état intermédiaire et tout état variable au moment inopportun).

4.4.2.104 Défaillance de la régulation de température

La CUVE POUR BAIN-MARIE ou tout autre récipient pour liquide de l'appareil doit être rempli(e) avec le MOYEN DE TRANSFERT DE CHALEUR jusqu'à son niveau maximal pour une UTILISATION NORMALE telle que spécifiée par le fabricant. Les défauts suivants doivent ensuite être appliqués, le défaut a) est appliqué seul mais si les conditions pour c) sont vraies, alors c) est appliqué immédiatement après b).

- a) Échauffement non régulé – Pour les appareils comportant une ouverture au-dessus de la CUVE POUR BAIN-MARIE et dans lesquels l'ébullition du MOYEN DE TRANSFERT DE CHALEUR peut engendrer un DANGER, les régulateurs de température doivent être neutralisés de

sorte que l'ébullition soit maintenue jusqu'au déclenchement d'un DISPOSITIF DE LIMITATION DE LA TEMPERATURE pour la protection contre la surchauffe, ou qu'elle soit interrompue par la perte du liquide.

- b) Refroidissement non régulé – Les régulateurs de température doivent être neutralisés pour produire un refroidissement non régulé jusqu'à la coagulation, la solidification ou le gel du MOYEN DE TRANSFERT DE CHALEUR, ou jusqu'à l'absence de preuve d'augmentation supplémentaire de la viscosité cinématique dudit moyen, ou jusqu'à l'interruption automatique du fonctionnement du MOTOCOMPRESSEUR par un dispositif de protection.
- c) Retour à la régulation – Cet essai doit être réalisé sur des appareils comportant un EVAPORATEUR de SYSTEME FRIGORIFIQUE immergé ou de circulation directe et/ou une POMPE DE CIRCULATION, et dont le MOYEN DE TRANSFERT DE CHALEUR a gelé, s'est solidifié ou a coagulé, et dont le MOTOCOMPRESSEUR est toujours en fonctionnement ou peut se mettre à fonctionner en réarmant son dispositif de protection sans utiliser d'OUTIL. Dans ces conditions, le dispositif de protection du MOTOCOMPRESSEUR doit être réarmé (si cela est exigé) et la régulation de TEMPERATURE REGULEE doit être réactivée, la température étant réglée sur une valeur pour laquelle le MOYEN DE TRANSFERT DE CHALEUR est un liquide à la viscosité normale. L'essai prend fin lorsque tout le MOYEN DE TRANSFERT DE CHALEUR est à la TEMPERATURE REGULEE spécifiée et présente une viscosité normale.

4.4.2.105 Humidificateur

Les HUMIDIFICATEURS non ASSIGNES pour fonctionner de manière continue doivent être contraints à un tel fonctionnement.

Le récipient d'un HUMIDIFICATEUR à électrodes doit être rempli d'une solution saturée de chlorure de sodium dans l'eau, à une température de $20^{\circ}\text{C} \pm 5^{\circ}\text{C}$. L'HUMIDIFICATEUR doit être alimenté à sa tension ASSIGNEE.

NOTE La solution est saturée lorsqu'une quantité supplémentaire de sel ne peut être dissoute dans l'eau à une température spécifique.

Lorsqu'un tube souple ou un flexible est utilisé pour la sortie d'évacuation de la vapeur ou du brouillard, l'essai doit être effectué avec le tube ou le flexible dégagé, partiellement bloqué et entièrement bloqué.

Si l'appareil dépend d'une pression différentielle entre l'entrée et la sortie de l'HUMIDIFICATEUR afin de diriger la vapeur ou le brouillard dans sa direction, l'HUMIDIFICATEUR doit être utilisé avec l'appareil fonctionnant normalement ou par cycles à une température comprise entre ses TEMPERATURES REGULEES maximale et minimale, selon la température la plus défavorable.

En cas de doute, les essais doivent être réalisés avec plusieurs combinaisons de conditions.

4.4.2.106 Régulateur de vitesse

Lorsqu'un DANGER peut survenir en cas de premier défaut d'un régulateur de vitesse, de tels défauts doivent alors être appliqués l'un après l'autre.

NOTE À titre d'exemple, les régulateurs de vitesse sont parfois utilisés pour réguler la FREQUENCE DE MOUVEMENT dans un AGITATEUR ou UNE ENCEINTE D'ESSAI COMBINEE, et pour réguler la pression et le débit d'une POMPE DE CIRCULATION. Dans le cas d'une CONDITION DE PREMIER DEFOUT du régulateur de vitesse, un DANGER peut survenir si la pression développée par la pompe dépasse la PRESSION MAXIMALE ADMISSIBLE d'un SYSTEME D'APPLICATION, ou si une FREQUENCE DE MOUVEMENT excessive d'un AGITATEUR ou d'une ENCEINTE D'ESSAI combinée entraîne le desserrage, la culbute, l'éjection ou la destruction de l'EPROUVETTE.

4.4.3 Durée des essais

4.4.3.1 Généralités

Remplacement:

Remplacer le texte par le suivant:

Les appareils doivent fonctionner jusqu'à ce qu'il soit improbable qu'une modification ultérieure ne se produise par suite du défaut appliqué. La durée de chaque essai est normalement limitée à 1 h car tout défaut secondaire occasionné par une CONDITION DE PREMIER DEFECT se manifeste habituellement dans ce délai. S'il apparaît qu'un DANGER de choc électrique, de propagation du feu ou de blessures de personnes peut finalement se produire, l'essai doit être poursuivi jusqu'à ce qu'il soit évident que des conditions stables ont été maintenues pendant au moins 1 h, à moins que l'un de ces DANGERS ne survienne avant.

4.4.4 Conformité après l'application des conditions de défaut

4.4.4.1 Généralités

Addition:

Ajouter le texte suivant sous le point c):

La conformité aux exigences concernant la protection thermique des MOTOCOMPRESSEURS est vérifiée comme cela est spécifié au 4.4.2.101.

5 Marquage et documentation

Cet article de la Partie 1 est applicable à l'exception de ce qui suit:

5.1.3 Alimentation RESEAU

Addition:

Ajouter les nouveaux symboles suivants au Tableau 1:

IECNORM.COM : Click to view the full PDF of IEC 61010-2-012:2019 RLV

Tableau 1 – Symboles

Numéro	Symbole	Référence	Description
101		ISO 7010-W010 (2011-05)	Avertissement; conditions de basse température/gel, DANGER de gelure
102		ISO 7010-W021 (2011-05)	Avertissement; matière/LIQUIDE INFLAMMABLE
103		ISO 7010-W009 (2011-05)	Avertissement; DANGER biologique
104		ISO 7010-W027 (2011-05)	Avertissement; rayonnement optique
105		ISO 7010-W011 (2011-05)	Avertissement; surface glissante
106		ISO 7010-W024 (2011-05)	Avertissement; écrasement des mains

5.1.5 BORNES, connexions et dispositifs de fonctionnement

Addition:

Ajouter les nouveaux paragraphes suivants:

5.1.5.101 CONNEXIONS DE LIQUIDES pour le MOYEN DE TRANSFERT DE CHALEUR

Elles doivent comporter un marquage constitué de symboles graphiques ou d'un texte permettant d'identifier la sortie et l'entrée du MOYEN DE TRANSFERT DE CHALEUR.

NOTE Pour les THERMOSTATS de réfrigération, les symboles 107 à 109 peuvent être utilisés et, pour les THERMOSTATS de réfrigération et de chauffage, les symboles 110 à 112 peuvent être utilisés (voir Tableau AA.1).

De plus, il peut être envisagé d'apposer les marquages suivants:

- si la pression de sortie du liquide est supérieure à 0,03 MPa ou 0,02 MPa avec un débit maximal de plus de 10 l/min, la pression maximale en Pa associée au symbole 108 ou 111;
- pour un THERMOSTAT avec une pression d'aspiration de liquide supérieure à 0,02 MPa, la pression maximale en Pa précédée par un signe moins, associée au symbole 109 ou 112;
- pour un THERMOSTAT sous enveloppe et destiné à être raccordé à un SYSTEME D'APPLICATION étanche, et s'il s'avère nécessaire que les CONNEXIONS DE LIQUIDES résistent à une pression supérieure à 0,03 MPa, la pression maximale pour chaque CONNEXION DE LIQUIDE, associée aux symboles 108 et 109, ou 111 et 112.

Les symboles 107 à 112 peuvent être consultés dans le Tableau AA.1.

Lorsque l'espace proche des CONNEXIONS DE LIQUIDES est insuffisant, le symbole 14 du Tableau 1 peut être utilisé et des explications doivent être données dans les instructions qui accompagnent les appareils.

La conformité est vérifiée par examen.

5.1.5.102 CONNEXION DE LIQUIDE pour le remplissage des CUVES POUR BAINS-MARIE avec THERMOSTATS sous enveloppe

Si une erreur de réglage des commandes ou des vannes associées à la CONNEXION DE LIQUIDE pour le remplissage d'une CUVE POUR BAIN-MARIE avec un THERMOSTAT sous enveloppe est susceptible de représenter un DANGER, le symbole 14 doit être placé près de la CONNEXION DE LIQUIDE et les instructions d'utilisation (voir 5.4.4) doivent expliquer clairement les réglages nécessaires permettant de garantir la sécurité dans les différentes conditions de fonctionnement.

La conformité est vérifiée par examen.

5.1.5.103 Autres CONNEXIONS DE LIQUIDES et ouverture de refoulement

Les CONNEXIONS DE LIQUIDES pour le remplissage, l'alimentation en eau, la vidange, le débordement et l'ouverture de refoulement doivent faire l'objet du marquage suivant:

- a) pour les appareils destinés à un remplissage de liquide manuel, si la zone d'ouverture de la CUVE POUR BAIN-MARIE ou de tout autre récipient pour liquide est inférieure à 80 cm² ou n'est pas évidente en soi, un marquage textuel ou le symbole 116 pour indiquer l'emplacement de l'ouverture de remplissage;
- b) pour les appareils destinés à être raccordés directement à l'alimentation en eau, un marquage textuel ou le symbole 113 pour chaque CONNEXION DE LIQUIDE dédiée à une source d'eau, et facultativement, selon le cas, un texte auxiliaire destiné à indiquer la PRESSION ASSIGNEE, le débit et la température maximale de l'alimentation en eau;
- c) pour les appareils comportant un GROUPE DE CONDENSATION refroidi par eau, ou pour les CONNEXIONS DE LIQUIDES dédiées à l'eau circulante, un marquage textuel ou le symbole 113 qui permet d'identifier l'entrée, et un marquage textuel ou le symbole 114 qui permet d'identifier la sortie, un de ces marquages ou symboles, voire les deux, indiquant également la direction du débit de liquide, et y compris, selon le cas, un texte auxiliaire destiné à indiquer la PRESSION ASSIGNEE, le débit et la température maximale de l'alimentation en eau;
- d) pour la CONNEXION DE LIQUIDE dédiée au condensat, un marquage textuel ou le symbole 115;
- e) pour la CONNEXION DE LIQUIDE dédiée à la vidange, un marquage textuel ou le symbole 117;
- f) pour la CONNEXION DE LIQUIDE dédiée au débordement, un marquage textuel ou le symbole 118;
- g) les marquages associés à un VENTILATEUR incluent:
 - 1) le symbole 119 pour la poignée ou l'arbre de réglage du VENTILATEUR,
 - 2) le symbole 120 pour la prise d'air frais accompagné, si nécessaire, du texte suivant ou son équivalent, "Prise d'air frais. Ne pas obstruer.";
 - 3) le symbole 121 pour l'ouverture de refoulement.

NOTE Les symboles 113 à 121 peuvent être consultés dans le Tableau AA.1.

Lorsque l'espace proche des CONNEXIONS DE LIQUIDES et/ou des ouvertures de refoulement est insuffisant, le symbole 14 du Tableau 1 peut être utilisé et des explications supplémentaires doivent être incluses dans les instructions.

La conformité est vérifiée par examen.

5.1.5.104 BORNES de liaison équipotentielle

Chaque BORNE de liaison équipotentielle doit être marquée avec le symbole de liaison équipotentielle de l'IEC 60417-5021 (2002-10). Aucun marquage ne doit être apposé sur une vis, un boulon, une rondelle amovible ou toute autre partie amovible lorsque des conducteurs ou des fils font l'objet d'un raccordement.

La conformité est vérifiée par examen.

Addition:

Ajouter les nouveaux paragraphes suivants à la fin de 5.1:

5.1.101 Marquage pour les appareils comportant un GROUPE DE CONDENSATION du FLUIDE FRIGORIGENE

Pour les appareils comportant un GROUPE DE CONDENSATION du FLUIDE FRIGORIGENE, les informations suivantes doivent faire l'objet d'un marquage:

- a) la masse totale du FLUIDE FRIGORIGENE pour chaque circuit de FLUIDE FRIGORIGENE distinct;
- b) pour un FLUIDE FRIGORIGENE ayant un seul composant, au moins un des marquages suivants:
 - 1) le nom chimique,
 - 2) la formule chimique,
 - 3) le numéro du FLUIDE FRIGORIGENE;
- c) pour un mélange de FLUIDES FRIGORIGENES, au moins un des marquages suivants:
 - 1) le nom chimique et la proportion nominale de chacun de ses composants,
 - 2) la formule chimique et la proportion nominale de chacun de ses composants,
 - 3) le numéro du fluide frigorigène et la proportion nominale de chacun de ses composants,
 - 4) le numéro du fluide frigorigène du mélange de fluides frigorigènes;

NOTE 1 Les numéros de FLUIDE FRIGORIGENE sont cités conformément à l'ISO 817 ou toute autre norme de classification de FLUIDE FRIGORIGENE, par exemple l'ANSI/ASHRAE 34.

- d) LA PRESSION MAXIMALE ADMISSIBLE (PS) EN CONDITION NORMALE, le COTE HAUTE PRESSION et le COTE BASSE PRESSION pour chaque étage du FLUIDE FRIGORIGENE.

NOTE 2 L'ensemble des résultats d'essai qui définit la PS est détaillé en 11.7.1.

La conformité est vérifiée par examen.

5.1.102 Marquage pour les appareils comportant un MOUVEMENT MECANIQUE

Pour les AGITATEURS et les ENCEINTES D'ESSAI COMBINEES comportant une fonction de MOUVEMENT MECANIQUE, la charge de sécurité maximale du porte-EPROUVETTES doit faire l'objet d'un marquage.

La conformité est vérifiée par examen.

5.2 Marquage des avertissements

Addition:

Ajouter le texte suivant après le point b):

Les marquages d'avertissement pour les DANGERS particuliers qui existent uniquement lors des opérations de maintenance des appareils doivent être apposés de sorte qu'ils soient visibles uniquement lors de la réalisation d'une opération de maintenance particulière. Par exemple, le marquage du type de FLUIDE FRIGORIGÈNE INFLAMMABLE et de l'agent moussant inflammable doit être visible lors de l'ACCES aux MOTOCOMPRESSEURS, et, dans le cas d'appareils avec un GROUPE DE CONDENSATION de fluide frigorigène distant, aux raccords de tuyauteries. Le symbole 102 du Tableau 1 doit avoir une hauteur de 15 mm au moins.

5.4.1 Généralités

Remplacement:

Remplacer le point d) par ce qui suit:

- d) les informations spécifiées de 5.4.2 à 5.4.6, en 5.4.101 et en 5.4.102;

5.4.2 Caractéristiques ASSIGNEES des appareils

Remplacement:

Remplacer le premier alinéa par le texte suivant:

Le cas échéant, la documentation doit comporter les informations suivantes:

Addition:

Ajouter les points suivants après le point f):

- aa) les TEMPERATURES REGULEES maximale et minimale;
- bb) la PLAGE AAC et la capacité de refroidissement ASSIGNEE pour le SYSTEME FRIGORIFIQUE;
- cc) la PRESSION ASSIGNEE et le débit pour les CONNEXIONS DE LIQUIDES entre le THERMOSTAT et un SYSTEME D'APPLICATION;
- dd) l'humidité relative supplémentaire maximale;
- ee) la pression atmosphérique minimale;
- ff) la résistance au rayonnement maximale;
- gg) la PRESSION ASSIGNEE et le débit pour les raccordements aux sources d'alimentation en liquide et en air;
- hh) la FREQUENCE et l'AMPLITUDE DE MOUVEMENT maximales par rapport à la masse de la charge.

5.4.3 Installation des appareils

Remplacement:

Remplacer les points a) à g) par ce qui suit:

- a) les exigences relatives à l'assemblage, à la mise en place et au montage. Les exigences concernant l'espace, notamment la distance minimale par rapport à tous les orifices ou toutes les grilles d'aération, les connexions de liquides et/ou l'ouverture de refoulement. Les exigences supplémentaires concernant la rigidité et la surface non glissante du sol et/ou du banc de laboratoire. Lorsqu'un DANGER peut être engendré par la chute d'objets chauds des appareils, par exemple lors de l'ouverture d'une porte, un avertissement doit indiquer que les appareils ne doivent pas être montés sur une surface en matière inflammable. Assembler les appareils à distance des capteurs d'incendie aériens, lorsque l'ouverture de la porte ou du couvercle ou l'échappement des fumées est possible pour une UTILISATION NORMALE;

- b) pour les appareils comportant des roulettes pivotantes et/ou des stabilisateurs verrouillables, les exigences concernant le verrouillage des roulettes et l'ajustement des stabilisateurs;
- c) les exigences de ventilation: si le fonctionnement des appareils peut entraîner l'échappement d'un mélange d'air ou de gaz dangereux, les instructions d'installation doivent avertir de la nécessité d'utiliser un système d'extraction, des DISPOSITIFS DE LIMITATION DE LA TEMPERATURE supplémentaires relatifs à des températures sûres pour les matières, etc.;
- d) les exigences concernant le remplissage, la vidange ou le débordement de liquide (voir 10.1 b));
- e) le raccordement à la source d'alimentation:
 - 1) les instructions pour mise à la terre de protection;
 - 2) pour les appareils destinés à des emplacements humides (voir 1.4.2) et dont il peut être nécessaire d'accéder à des parties actives dangereuses (voir 6.1.2), un symbole d'avertissement et un énoncé précisant l'utilisation d'une prise de courant avec protection IP appropriée et indiquant si un disjoncteur différentiel résiduel externe (DDR) avec pouvoir de coupure assigné est nécessaire,
 - 3) un symbole d'avertissement et un énoncé nécessaires lorsqu'un branchement permanent à la source d'alimentation est essentiel,
 - 4) pour les APPAREILS BRANCHES EN PERMANENCE:
 - les exigences relatives au câblage d'alimentation;
 - les exigences pour tout interrupteur ou tout disjoncteur extérieur (voir 6.11.3.1) et pour tout dispositif extérieur de protection contre les surintensités (voir 9.6.2) et une recommandation pour que l'interrupteur ou le disjoncteur soit placé à côté de l'appareil;
- f) les exigences pour services externes particuliers, par exemple, air et liquide de refroidissement. Les caractéristiques nécessaires pour la sécurité doivent être spécifiées, par exemple, températures maximale et minimale, pression, ou flux d'air ou liquide de refroidissement;
- g) les exigences concernant l'installation et/ou le raccordement à une pompe à vide, un compresseur d'air et/ou une source de vapeur;
- h) les instructions relatives au niveau de pression acoustique (voir 12.5.1); le niveau maximal de puissance acoustique produit par les appareils qui émettent un son, lorsqu'un mesurage est exigé par 12.5.1;
- i) les exigences concernant le SECHAGE et/ou l'ARRET (voir 5.4.3.101);
- j) les exigences concernant le raccordement d'un GROUPE DE CONDENSATION distant à l'appareil, notamment les exigences concernant l'emplacement, l'espace, les tuyaux, les tubes et les accessoires (voir 14.101), les spécifications détaillées du FLUIDE FRIGORIGENE (voir 5.1.101), la ventilation, l'alimentation en eau et les procédures détaillées de raccordement et d'ajustement;
- k) les exigences concernant le raccordement d'un THERMOSTAT au SYSTEME D'APPLICATION, notamment les exigences concernant l'emplacement, l'espace et les tubes, les accessoires (voir 14.102), l'isolation et le MOYEN DE TRANSFERT DE CHALEUR à l'état liquide, la ventilation, l'alimentation en eau et les procédures détaillées de raccordement et d'ajustement;
- l) les exigences concernant l'installation d'une source de lumière (lampe) fonctionnelle, notamment les lampes et les accessoires recommandés, les mesures de protection contre la rupture de la lampe et son élimination, les précautions de protection contre les DANGERS de choc électrique potentiel, les surfaces chaudes, les rayonnements optiques et/ou ultraviolets excessifs, les exigences concernant la ventilation et la source d'eau, ainsi que les procédures détaillées d'installation et d'ajustement;
- m) les exigences concernant le raccordement d'un HUMIDIFICATEUR ou d'une source de vapeur à l'appareil, notamment le type et les spécifications recommandés de l'HUMIDIFICATEUR, l'évaporation équivalente de la source de vapeur, les exigences concernant les tubes et

les accessoires, l'isolation, la ventilation et l'alimentation en eau, les précautions de protection contre les DANGERS de choc électrique potentiel, les surfaces chaudes, les dommages mécaniques associés à l'installation, ainsi que les procédures détaillées d'installation et d'ajustement;

n) les exigences concernant l'installation et l'ajustement pour le MOUVEMENT MECANIQUE.

La conformité est vérifiée par examen.

Addition:

Ajouter le nouveau paragraphe suivant:

5.4.3.101 SECHAGE et ARRET

Les instructions doivent comprendre un avertissement précisant que les appareils sont susceptibles de ne pas satisfaire à toutes les exigences relatives à la sécurité du présent document pendant le SECHAGE et/ou l'ARRET.

La conformité est vérifiée par examen.

5.4.4 Fonctionnement de l'appareil

Addition:

Ajouter les points suivants après le point j):

- aa) les exigences concernant le MOYEN DE TRANSFERT DE CHALEUR à l'état liquide et un avertissement contre les DANGERS liés à une utilisation incorrecte du liquide;
 - les spécifications du liquide applicables aux appareils, notamment la plage de TEMPERATURES REGULEES, l'inflammabilité, la viscosité, le POINT D'ECLAIR, le POINT DE FEU, la TEMPERATURE D'AUTO-INFLAMMATION, la densité et la chaleur massique, ainsi que leur effet sur les applications (voir 4.3.2.113);
 - les procédures et les précautions de remplissage, de vidange et de remplacement (voir 10.1 b));
 - les DANGERS chimiques et les instructions pour l'élimination et le traitement d'urgence;
 - les exigences spéciales pour les MOYENS DE TRANSFERT DE CHALEUR qui modifient les états en UTILISATION NORMALE, notamment les MOYENS DE TRANSFERT DE CHALEUR dans un BAIN-MARIE de sel;

- bb) les instructions concernant la méthode de calcul de la capacité de refroidissement et/ou de la puissance calorifique effective pour les EPROUVETTES et le SYSTEME D'APPLICATION;

NOTE 101 La capacité de refroidissement représente le mesurage du flux thermique qu'un SYSTEME FRIGORIFIQUE retire du MOYEN DE TRANSFERT DE CHALEUR, tel que déterminé selon des procédures d'essai normalisées, par exemple, DIN 12876-2.

NOTE 102 La puissance calorifique effective représente le mesurage du flux thermique que les sources de chauffage diffusent au MOYEN DE TRANSFERT DE CHALEUR.

- cc) les exigences concernant le chargement, la répartition et la fixation des EPROUVETTES dans l'espace de travail dédié au BAIN-MARIE, à l'INCUBATEUR ou à l'ENCEINTE D'ESSAI ou au-dessus du porte-EPROUVETTES de MOUVEMENT MECANIQUE;
- dd) les procédures à suivre pour arrêter les appareils en toute sécurité et les laisser dans un état de sécurité;
- ee) un avertissement contre tout ACCES aux APPAREILS MOBILES (voir également l'Annexe BB) par du personnel inexpérimenté ou des enfants. Les exigences concernant l'ACCES aux APPAREILS MOBILES, notamment l'utilisation d'un équipement de protection individuelle, la présence d'un second OPERATEUR, le déverrouillage du mécanisme et le dégagement de

- la porte, et la présence d'un dispositif indicateur de la présence de l'OPERATEUR à l'intérieur de l'appareil;
- ff) les exigences concernant le dispositif de ventilation, l'orifice (trappe) d'accès et les CONNEXIONS DE LIQUIDES; un avertissement contre les DANGERS engendrés par des températures élevées et basses (voir 10.1), et un gaz, liquide ou solide dangereux libéré (voir 13.1);
 - gg) les exigences concernant un examen régulier et ses intervalles par rapport à la fixation des EPROUVETTES et aux DANGERS potentiels au cours du processus d'agitation;
 - hh) les instructions concernant le bon fonctionnement des lampes et des appareils utilisant des lampes, de l'HUMIDIFICATEUR ou de la source de vapeur et du MOUVEMENT MECANIQUE, ainsi qu'un avertissement contre les DANGERS engendrés par ces derniers;
 - ii) les instructions d'utilisation d'un équipement de protection individuelle, les mesures de protection ou les exigences relatives à la formation.

La conformité est vérifiée par examen.

Addition:

Ajouter le nouveau paragraphe suivant:

5.4.4.101 Nettoyage et décontamination

Les instructions doivent inclure les conditions et les intervalles relatifs au nettoyage et, si nécessaire, à la décontamination. Les noms génériques reconnus des matières recommandées pour le nettoyage et la décontamination doivent être fournis, ainsi qu'une indication des matières susceptibles d'être utilisées mais qui sont incompatibles avec certaines parties de l'appareil ou avec les matières qu'il contient.

Les instructions doivent également mentionner que l'AUTORITE RESPONSABLE doit garantir que:

- a) la décontamination appropriée est effectuée si une substance dangereuse est répandue sur ou dans l'appareil;
- b) des agents de décontamination ou de nettoyage qui peuvent causer un DANGER résultant d'une réaction avec des parties de l'appareil ou avec les matières qu'il contient ne sont pas utilisés;
- c) le fabricant ou son agent est consulté s'il existe un doute quelconque à propos de la compatibilité de la décontamination ou des agents de nettoyage avec les parties de l'appareil ou avec les matières qu'il contient.

Si un fabricant prétend qu'un article peut être décontaminé par stérilisation à la vapeur, cet article doit être capable de supporter la stérilisation à la vapeur dans au moins une des conditions de température-temps mentionnées dans le Tableau 101.

Il convient que les fabricants prennent connaissance du "Manuel de sécurité biologique pour laboratoires" reconnu internationalement, publié par l'Organisation mondiale de la Santé à Genève, qui donne des informations sur les décontaminants, leur utilisation, leurs dilutions, leurs propriétés et leurs applications potentielles. Il existe également des lignes directrices nationales couvrant ces domaines.

Le nettoyage et la décontamination peuvent s'avérer nécessaires à titre préventif lorsque les appareils destinés à une application biologique et leurs accessoires font l'objet d'opérations de maintenance, sont réparés ou transférés. Les fabricants doivent délivrer un document à l'AUTORITE RESPONSABLE pour certifier que ce traitement a été effectué.

Tableau 101 – Conditions de température-temps

Pression absolue kPa	Température de la vapeur correspondante		Temps de maintien minimal min
	Nominale °C	Plage °C	
325	136,0	134 à 138	3
250	127,5	126 à 129	10
215	122,5	121 à 124	15
175	116,5	115 à 118	30

NOTE Le "temps de maintien minimal" signifie la durée pendant laquelle le produit contaminé reste à la température de la vapeur.

La conformité est vérifiée par examen.

5.4.5 Entretien de l'appareil et service

Remplacement:

Remplacer le texte par le suivant:

Si le fonctionnement continu en toute sécurité dépend d'un examen, d'un essai de l'appareil et/ou d'un entretien planifiés et réguliers, les instructions destinées à l'AUTORITE RESPONSABLE doivent détailler l'entretien, l'examen et/ou les procédures d'essai exigés et fournir des informations permettant d'aider l'AUTORITE RESPONSABLE à élaborer un plan d'entretien adapté.

Les détails suivants doivent notamment être inclus le cas échéant:

- Les spécifications détaillées concernant le FLUIDE FRIGORIGENE (voir 5.1.101), le MOYEN DE TRANSFERT DE CHALEUR, les tubes souples, flexibles, les raccords de tuyauterie, les matériaux isolants, les lampes, les joints de portes spécifiques à l'appareil.
- Les intervalles et les procédures détaillées de vérification du fonctionnement du mécanisme relatif à la sécurité du MOUVEMENT MECANIQUE, et les parties et accessoires consommables spécifiques.
- Les intervalles et les procédures détaillées d'examen du fonctionnement du DISPOSITIF DE LIMITATION DE LA TEMPERATURE, du DISPOSITIF D'ARRET DE NIVEAU DE LIQUIDE, du LIMITEUR DE PRESSION et de dispositifs de protection analogues.
- Les intervalles et les procédures détaillées de nettoyage du transducteur piézoélectrique utilisé dans un HUMIDIFICATEUR ultrasonique, de l'ELEMENT DE CHAUFFAGE PAR RESISTANCE, de l'échangeur de chaleur à circulation d'eau, et des filtres dans le système d'échange de chaleur.
- Un énoncé stipulant que les opérations d'entretien ACCESSIBLES au moyen d'un OUTIL doivent être réalisées uniquement par du personnel qualifié agréé par le fabricant.
- Le cas échéant, les instructions doivent spécifier des procédures afin que L'AUTORITE RESPONSABLE vérifie le fonctionnement effectif des dispositifs ou systèmes en matière de protection contre la surchauffe, de protection du niveau de liquide, de protection contre une pression élevée ou basse, ainsi que du mécanisme de déverrouillage ou de verrouillage de la porte ou du couvercle pour permettre à l'OPERATEUR de s'extraire de l'APPAREIL MOBILE (voir l'Annexe BB), ces procédures étant nécessaires pour la sécurité. Les instructions doivent également indiquer la fréquence à laquelle il est nécessaire de réaliser les contrôles.

Le cas échéant, la documentation du fabricant doit déconseiller le remplacement des cordons d'alimentation RESEAU amovibles par des cordons ASSIGNES inappropriés.

Pour les appareils utilisant des piles remplaçables, le type spécifique de pile doit être indiqué.

Les instructions doivent spécifier les parties devant être examinées ou fournies uniquement par le fabricant ou par son agent, afin de garantir que la sécurité n'est pas compromise. Il suffit d'indiquer le numéro de pièce du fabricant lorsque le fabricant ne souhaite pas autoriser l'utilisation d'alternatives.

Les CARACTERISTIQUES ASSIGNEES et les caractéristiques des fusibles remplaçables doivent être indiquées.

Si des procédures spéciales sont exigées pour préparer l'appareil à des périodes d'inactivité, de stockage ou à la mise hors service, ces procédures doivent être détaillées dans les instructions.

Si l'appareil doit être maintenu au repos et/ou stocké dans des conditions ambiantes de gel, des instructions doivent être données concernant l'interruption de l'alimentation, la vidange des liquides et le SECHAGE.

Les énoncés et avertissements de précaution contre les DANGERS liés aux procédures d'entretien et d'examen doivent être indiqués.

Les instructions sur les sujets suivants doivent être fournies au personnel d'entretien, si nécessaire, afin d'assurer un entretien en toute sécurité et une sécurité en permanence de l'appareil après l'entretien, si l'appareil est adapté pour les opérations d'entretien:

- a) les RISQUES spécifiques à l'appareil qui peuvent affecter le personnel d'entretien;
- b) les mesures de protection pour ces RISQUES;
- c) la vérification de l'état de sécurité de l'appareil après réparation.

Il n'est pas nécessaire que les instructions pour le personnel d'entretien soient fournies à l'AUTORITE RESPONSABLE, mais il convient que le personnel d'entretien puisse les consulter.

La conformité est vérifiée par examen.

Addition:

Ajouter les nouveaux paragraphes suivants:

5.4.101 Instructions supplémentaires pour les appareils de réfrigération qui utilisent un FLUIDE FRIGORIGENE INFLAMMABLE

Pour les appareils de réfrigération qui utilisent un FLUIDE FRIGORIGENE INFLAMMABLE, les instructions doivent inclure des informations suffisantes pour permettre la manutention, l'entretien et l'élimination de l'appareil en toute sécurité.

Les instructions doivent inclure les avertissements suivants si nécessaire:

- AVERTISSEMENT: S'assurer que toutes les ouvertures de ventilation ne soient pas obstruées;
- AVERTISSEMENT: Ne pas utiliser de dispositifs mécaniques ou d'autres moyens pour accélérer le processus de dégivrage, autres que ceux recommandés par le fabricant;
- AVERTISSEMENT: Ne pas endommager le circuit de fluide frigorigène;
- AVERTISSEMENT: Ne pas utiliser d'appareils électriques dans l'appareil, autres que ceux recommandés par le fabricant.

NOTE Aux États-Unis, pour les appareils de réfrigération utilisant des fluides frigorigènes inflammables, il existe des marquages supplémentaires et des exigences informatives supplémentaires. Voir l'Annexe DD pour des informations détaillées.

Pour les appareils qui utilisent un gaz inflammable pour obtenir un agent moussant, les instructions doivent inclure les informations concernant l'élimination des appareils.

Les instructions concernant les appareils comportant un GROUPE DE CONDENSATION de FLUIDE FRIGORIGENE distant qui utilise un FLUIDE FRIGORIGENE INFLAMMABLE doivent inclure l'avertissement suivant:

- AVERTISSEMENT: Afin de réduire les dangers d'incendie, l'installation de cet appareil doit être effectuée uniquement par du personnel qualifié agréé par le fabricant.

Le marquage du type de FLUIDE FRIGORIGENE INFLAMMABLE et du GAZ INFLAMMABLE pour la formation d'un agent moussant, doit être visible lors de l'accès aux MOTOCOMPRESSEURS, et, dans le cas d'appareils avec un GROUPE DE CONDENSATION de fluide frigorigène distant, aux raccords de tuyauteries.

Le symbole 102 du Tableau 1 doit être placé sur la plaque signalétique de l'appareil à proximité de la déclaration du type de FLUIDE FRIGORIGENE et des informations de chargement. Il doit être clairement visible après l'installation de l'appareil.

La conformité est vérifiée par examen.

5.4.102 Instructions supplémentaires pour les appareils destinés à être utilisés avec un MOYEN DE TRANSFERT DE CHALEUR LIQUIDE INFLAMMABLE

Pour les BAINS-MARIE, les THERMOSTATS et les BAINS-MARIE à agitation destinés à être utilisés avec un MOYEN DE TRANSFERT DE CHALEUR LIQUIDE INFLAMMABLE, les instructions doivent inclure les informations suffisantes pour garantir la manutention, l'entretien et l'élimination en toute sécurité de l'appareil.

Les instructions doivent inclure les avertissements suivants si nécessaire:

- AVERTISSEMENT: S'assurer que toutes les ouvertures de ventilation ne soient pas obstruées;
- AVERTISSEMENT: Défense de fumer! Pas de flamme! Ne pas utiliser de pièces électriques qui peuvent produire des étincelles lors de manœuvres autour de l'appareil et du système d'application;
- AVERTISSEMENT: Vidanger et récupérer le liquide lorsque l'appareil est au repos, si le moyen de transfert de chaleur à l'état liquide est utilisé avec une cuve pour bain-marie ouverte et s'il est hautement volatil à la température ambiante.

Une étiquette portant le symbole 102 doit être fournie avec l'appareil pouvant être utilisé avec un MOYEN DE TRANSFERT DE CHALEUR LIQUIDE INFLAMMABLE avec les instructions destinées à l'AUTORITE RESPONSABLE pour fixer l'étiquette de façon visible sur l'appareil s'il doit être utilisé avec un MOYEN DE TRANSFERT DE CHALEUR LIQUIDE INFLAMMABLE.

Les instructions doivent comporter les informations détaillées applicables aux procédures de réduction du RISQUE par rapport à l'utilisation du MOYEN DE TRANSFERT DE CHALEUR LIQUIDE INFLAMMABLE, y compris la méthode de réglage approprié du DISPOSITIF DE LIMITATION DE LA TEMPERATURE de sorte que la température de surface en contact avec le liquide soit inférieure à la limite définie en 9.5 a).

La conformité est vérifiée par examen.

6 Protection contre les chocs électriques

Cet article de la Partie 1 est applicable à l'exception de ce qui suit:

6.1.1 Exigences

Addition:

Ajouter ce qui suit après la déclaration de conformité:

Lorsque les instructions d'installation spécifient un processus d'ARRET ou de SECHAGE (voir 5.4.3.101), ceci est effectué avant les mesurages définis en 6.3, 6.7.2.2 et 6.8. L'ARRET ou le SECHAGE est suivi d'une période de repos de 2 h, avec l'appareil hors tension, avant de réaliser les mesurages.

Les mesurages sont effectués avec l'appareil à température ambiante. S'il existe un doute que les limites admissibles puissent être dépassées dans les conditions de fonctionnement combinées les plus défavorables, les mesurages appropriés sont répétés dans ces conditions et les valeurs les plus élevées sont utilisées.

6.3.1 Niveaux en CONDITION NORMALE

Addition:

Ajouter ce qui suit au point b) 1):

Les niveaux pour les APPAREILS BRANCHES EN PERMANENCE représentent 1,5 fois ces valeurs.

6.3.2 Niveaux en CONDITION DE PREMIER DEF AUT

Addition:

Ajouter ce qui suit au point b) 1):

Les niveaux pour les APPAREILS BRANCHES EN PERMANENCE représentent 1,5 fois ces valeurs.

6.7.2.2 Isolation solide

Addition:

Ajouter le nouveau paragraphe suivant:

6.7.2.2.101 SECHAGE

Si les exigences de performance de l'appareil ne peuvent pas être satisfaites sans utiliser une isolation de chauffage hygroscopique, il est admis que l'appareil exige une période de fonctionnement pour sécher l'isolation avant de satisfaire aux exigences de 6.7.2.2, de 6.3.1 et de 6.8.2 à condition que l'OPERATEUR en soit informé (voir 5.4.3.101).

La conformité est vérifiée en effectuant le SECHAGE spécifié dans le manuel de l'OPERATEUR (voir 5.4.3.101) avant de réaliser les essais de 6.3.1 et de 6.8.2.

6.8.1 Généralités

Addition:

Ajouter l'alinéa suivant après le deuxième alinéa:

Si un SECHAGE est spécifié (voir 6.7.2.2.101), il est effectué conformément au manuel de l'OPERATEUR (voir 5.4.3.101) avant les essais de 6.8.3. Le SECHAGE est suivi d'une période de repos de 2 h, avec l'appareil hors tension. Les essais sont ensuite effectués et terminés en moins de 1 h à la fin de la période de repos.

6.8.2 Préconditionnement à l'humidité

Addition:

Ajouter ce qui suit à la fin du dernier alinéa:

Les appareils pour lesquels un SECHAGE est spécifié (voir 5.4.3.101) ne doivent pas être soumis au preconditionnement à l'humidité.

6.9.1 Généralités

Addition:

Ajouter l'alinéa suivant après la note:

Les parties ACTIVES DANGEREUSES nues et les câblages et connexions isolés doivent être acheminés et disposés de sorte que les DISTANCES D'ISOLEMENT et les LIGNES DE FUITE ne soient pas réduites en dessous de valeurs acceptables par

- 1) des liquides, des vapeurs ou autres impuretés condensés, cumulés ou qui fuient à l'intérieur des appareils;
- 2) un contact avec des parties chaudes ou froides;
- 3) une contrainte mécanique ou une abrasion par des angles vifs.

6.10.1 CORDONS d'alimentation RESEAU

Remplacement:

Remplacer les troisième et quatrième alinéas comme suit:

Si un cordon est susceptible d'entrer en contact avec des parties externes chaudes ou froides de l'appareil, il doit être constitué d'une matière suffisamment résistante à la chaleur ou, en variante, une protection supplémentaire doit être prévue afin d'éviter que le cordon n'entre en contact avec une surface chauffée ou froide.

Si le cordon est amovible, le cordon et le socle du connecteur doivent avoir des températures ASSIGNEES compatibles. Le cordon et le socle du connecteur doivent avoir des températures ASSIGNEES supérieures aux températures maximales mesurées en CONDITION NORMALE sur toute partie du socle du connecteur lui-même.

Le connecteur doit comporter un mécanisme qui empêche le cordon ayant une température ASSIGNEE inférieure d'être inséré dans le socle du connecteur dont la température ASSIGNEE est plus élevée.

NOTE Un connecteur conforme à l'IEC 60320 (toutes les parties), tel que celui de types C15 et C16, ou C21 et C22 pour des conditions chaudes ou de types C15A et C16A pour des conditions très chaudes, constitue un exemple de mécanisme exigé.

7 Protection contre les DANGERS mécaniques

Cet article de la Partie 1 est applicable à l'exception de ce qui suit:

7.3.5.1 Limitation des écartements entre les parties mobiles – Accès normalement autorisé

Addition:

Ajouter les alinéas suivants après le premier alinéa:

Si la largeur de l'écartement peut passer d'une valeur supérieure à l'écartement minimal du Tableau 13 pour cette partie du corps à une valeur inférieure à l'écartement minimal en CONDITION NORMALE et en CONDITION DE PREMIER DEFECT, par exemple, la porte et/ou le dispositif de verrouillage des ENCEINTES D'ESSAI ou des INCUBATEURS, y compris l'APPAREIL MOBILE (voir l'Annexe BB), la porte ou le dispositif de verrouillage doit comporter une poignée ou un arbre de sorte que la main, le poignet, le poing et les doigts soient maintenus éloignés de l'écartement entre les parties mobiles lors de la fermeture et/ou du verrouillage de la porte. Lorsque des doubles portes sont utilisées, elles peuvent être construites de sorte qu'il soit possible de fermer et/ou verrouiller une porte uniquement après la fermeture de l'autre porte, lorsque le DANGER d'écrasement est réduit le plus possible.

Un marquage d'avertissement supplémentaire est nécessaire à proximité de l'écartement entre les parties mobiles et à l'emplacement du dispositif de verrouillage, en utilisant le symbole 106 du Tableau 1.

Addition:

Ajouter le nouveau paragraphe suivant:

7.3.101 Marquages d'avertissement pour le MOUVEMENT MECANIQUE

La zone de MOUVEMENT MECANIQUE dans un AGITATEUR ou une ENCEINTE D'ESSAI COMBINÉE doit être marquée avec le symbole 14 du Tableau 1 ou les symboles applicables 122 à 127 du Tableau AA.1.

Le porte-EPROUVETTES du MOUVEMENT MECANIQUE doit être marqué avec le symbole 14 du Tableau 1.

La conformité est vérifiée par examen.

7.4 Stabilité

Addition:

Ajouter les nouveaux paragraphes suivants:

7.4.101 Mouvement en cours de fonctionnement

Les appareils ne doivent pas changer de position en UTILISATION NORMALE.

La conformité est vérifiée par examen et essai.

L'appareil doit être utilisé conformément aux spécifications du fabricant, pour le réglage et la condition de charge correspondant aux conditions de fonctionnement normales les plus défavorables. Le temps de fonctionnement est de 10 min, ou correspond à la durée d'un cycle de fonctionnement, selon la durée la plus courte.

Le mouvement doit être limité soit par la conception, soit par fixation à la surface de montage, ou une combinaison de ces deux moyens, de sorte qu'aucune partie de l'appareil ne se déplace hors d'un espace libre de plus de 5 mm, ou moins si le fabricant l'indique, dans toute direction depuis les parties externes de l'appareil dans sa position d'origine.

Au cours des essais, l'appareil doit rester en position. Un tube souple ou autre connexion mécanique entre l'appareil et le SYSTÈME D'APPLICATION doit résister à la contrainte susceptible d'engendrer un DANGER.

Pour les appareils destinés à un fonctionnement continu de longue durée, la course maximale et la période d'essai doivent être déterminées par l'appréciation du RISQUE de l'Article 17.

7.4.102 Porte-EPROUVETTES amovible pour le MOUVEMENT MECANIQUE

Lorsqu'un DANGER tel qu'un bruit anormal ou un dommage mécanique dû au déséquilibre ou au décrochage du porte-EPROUVETTES pour le MOUVEMENT MECANIQUE en UTILISATION NORMALE, peut survenir lors du retrait ou de la réintroduction, le porte-EPROUVETTES amovible doit être marqué avec un symbole d'avertissement approprié à proximité immédiate des poignées du porte-EPROUVETTES et la documentation doit comporter une explication.

La conformité est vérifiée par examen.

7.5 Moyens de levage et de transport

7.5.1 Généralités

Addition:

Ajouter le texte suivant après le premier alinéa:

Lorsque la construction physique est telle que les parties qui ne sont pas conçues pour être utilisées en tant que poignées, anses, moyens de levage ou de transport peuvent être prises comme telles de manière erronée, elles doivent:

- a) avoir une résistance égale ou supérieure à celle exigée pour les moyens de levage ou de transport normaux ou,
- b) comporter un marquage d'avertissement (voir 5.2) stipulant que les parties ne doivent pas être utilisées en tant que poignées, anses, moyens de levage ou de transport adjacents à la ou aux parties concernées. Le symbole 14 du Tableau 1 et les explications supplémentaires dans la documentation sont considérés comme satisfaisant aux exigences.

Remplacement:

Remplacer la déclaration de conformité comme suit:

La conformité est vérifiée par examen et comme spécifié en 7.5.2 et 7.5.3.

8 Résistance aux contraintes mécaniques

Cet article de la Partie 1 est applicable à l'exception de ce qui suit:

8.1 Généralités

Remplacement:

Remplacer le texte du point 3) par le suivant:

- 3) excepté pour les APPAREILS INSTALLES A POSTE FIXE, les appareils de masse supérieure à 100 kg ou les appareils dont la taille et le poids rendent peu probables les mouvements involontaires et qui ne sont pas déplacés en UTILISATION NORMALE.

8.2.1 Essai statique

Remplacement:

Remplacer le deuxième alinéa par le suivant:

Une ENVELOPPE non métallique ou utilisant du verre comme partie intégrante, est utilisée jusqu'à stabilisation, dans les conditions les plus défavorables parmi les conditions suivantes:

- a) à la température ambiante maximale ou minimale; ou*
- b) à la température ambiante maximale ou minimale étendue; ou*
- c) à une température supérieure à la TEMPERATURE REGULEE maximale ou minimale; ou*
- d) par cycles entre les plages de TEMPERATURES REGULEES maximales et minimales; ou*
- e) avec toutes les lampes allumées et à la puissance maximale pour un rayonnement.*

L'appareil est débranché de sa source d'alimentation avant de réaliser l'essai.

8.2.2 Essai de choc

Remplacement:

Remplacer le premier alinéa après la Note par le suivant:

Une ENVELOPPE non métallique ou utilisant du verre comme partie intégrante, est utilisée jusqu'à stabilisation, dans les conditions les plus défavorables parmi les conditions suivantes:

- a) à la température ambiante maximale ou minimale; ou*
- b) à la température ambiante maximale ou minimale étendue; ou*
- c) à une température supérieure à la TEMPERATURE REGULEE maximale ou minimale; ou*
- d) par cycles entre les plages de TEMPERATURES REGULEES maximales et minimales; ou*
- e) avec toutes les lampes allumées et à la puissance maximale pour un rayonnement.*

L'appareil est débranché de sa source d'alimentation, puis soumis à l'essai pendant 10 min.

9 Protection contre la propagation du feu

Cet article de la Partie 1 est applicable à l'exception de ce qui suit:

9.5 Exigences pour les appareils contenant des LIQUIDES INFLAMMABLES

Addition:

Ajouter le texte suivant après le premier alinéa:

Ce paragraphe 9.5 s'applique aux LIQUIDES INFLAMMABLES autres que les FLUIDES FRIGORIGENES INFLAMMABLES. Les exigences concernant les FLUIDES FRIGORIGENES INFLAMMABLES sont spécifiées en 5.4.101 et 11.7.101.

Remplacement:

Remplacer le point a) et la Note 1 par ce qui suit:

- a) L'appareil doit être construit de façon à être conforme aux points 1), 2) et 3) comme suit:
 - 1) En CONDITION NORMALE et en CONDITION DE PREMIER DEFECT, la température de surface du LIQUIDE INFLAMMABLE ne doit pas dépasser le POINT D'ECLAIR du liquide exposé à l'air.

- 2) En CONDITION NORMALE et en CONDITION DE PREMIER DEFUT, la température de surface de tout ELEMENT DE CHAUFFAGE PAR RESISTANCE à la surface du LIQUIDE INFLAMMABLE et en contact avec l'air ne doit pas dépasser $(t - 25) ^\circ\text{C}$, où t est le POINT DE FEU du liquide.
- 3) Dans le cas des appareils pour lesquels un réglage de l'OPERATEUR peut exposer un LIQUIDE INFLAMMABLE à une condition dans laquelle les températures de 1) ou 2) peuvent être dépassées dans le cas d'une CONDITION DE PREMIER DEFUT au cours d'un MAUVAIS USAGE RAISONNABLEMENT PREVISIBLE, des mesures supplémentaires doivent être prises pour protéger l'OPERATEUR contre ce DANGER.
 - Par exemple, un DISPOSITIF D'ARRET DE NIVEAU DE LIQUIDE qui désactive l'ELEMENT DE CHAUFFAGE PAR RESISTANCE avant que les températures exigées en 1) ou 2) ne soient dépassées, est considéré comme conforme à cette exigence.
 - Il convient de prêter attention à tout scénario pouvant exposer un LIQUIDE INFLAMMABLE autorisé à une température pouvant dépasser $t_a - 100 ^\circ\text{C}$, où t_a est la TEMPERATURE D'AUTO-INFLAMMATION.
 - L'utilisation dans l'appareil d'un LIQUIDE INFLAMMABLE non agréé par le fabricant n'est pas considérée comme un réglage de l'OPERATEUR et n'est donc pas couverte par l'évaluation de l'Article 16.

NOTE 101 Le 16.1 fournit des recommandations relatives à ce qui est considéré comme un MAUVAIS USAGE RAISONNABLEMENT PREVISIBLE.

Il n'est pas suffisant de limiter la température de surface du LIQUIDE INFLAMMABLE et des parties en contact avec la surface uniquement par le système de régulation de température. Une protection contre la surchauffe conforme aux exigences de 10.101, obtenue au moyen d'un DISPOSITIF DE LIMITATION DE LA TEMPERATURE indépendant et réglable, doit être utilisée.

NOTE 102 La température de surface de l'ELEMENT DE CHAUFFAGE PAR RESISTANCE utilisé pour chauffer un liquide peut être bien plus élevée que la température du liquide.

NOTE 103 Les instructions supplémentaires concernant les appareils destinés à être utilisés avec un MOYEN DE TRANSFERT DE CHALEUR LIQUIDE INFLAMMABLE sont détaillées en 5.4.102.

Addition:

Ajouter la note suivante après le point c):

NOTE 104 Lorsqu'un LIQUIDE INFLAMMABLE est présent dans l'appareil, le symbole 102 peut être utilisé comme marquage d'avertissement.

Remplacement:

Remplacer le premier alinéa de la déclaration de conformité par le suivant:

La conformité est vérifiée par examen, y compris la plaque signalétique, la documentation et le fonctionnement des appareils, et si nécessaire, par les essais et les mesurages de la température, comme spécifié en 10.4 et en 10.101.

10 Limites de température de l'appareil et résistance à la chaleur

Cet article de la Partie 1 est applicable à l'exception de ce qui suit:

10.1 Limites de température des surfaces pour la protection contre les brûlures

Remplacement:

Remplacer le titre par ce qui suit: