

INTERNATIONAL
STANDARD

IEC
61788-3

Second edition
2006-04

Superconductivity –

**Part 3:
Critical current measurement –
DC critical current of Ag- and/or Ag alloy-sheathed
Bi-2212 and Bi-2223 oxide superconductors**

IECNORM.COM : Click to view the full PDF of IEC 61788-3:2006



Reference number
IEC 61788-3:2006(E)

Publication numbering

As from 1 January 1997 all IEC publications are issued with a designation in the 60000 series. For example, IEC 34-1 is now referred to as IEC 60034-1.

Consolidated editions

The IEC is now publishing consolidated versions of its publications. For example, edition numbers 1.0, 1.1 and 1.2 refer, respectively, to the base publication, the base publication incorporating amendment 1 and the base publication incorporating amendments 1 and 2.

Further information on IEC publications

The technical content of IEC publications is kept under constant review by the IEC, thus ensuring that the content reflects current technology. Information relating to this publication, including its validity, is available in the IEC Catalogue of publications (see below) in addition to new editions, amendments and corrigenda. Information on the subjects under consideration and work in progress undertaken by the technical committee which has prepared this publication, as well as the list of publications issued, is also available from the following:

- **IEC Web Site (www.iec.ch)**
- **Catalogue of IEC publications**

The on-line catalogue on the IEC web site (www.iec.ch/searchpub) enables you to search by a variety of criteria including text searches, technical committees and date of publication. On-line information is also available on recently issued publications, withdrawn and replaced publications, as well as corrigenda.

- **IEC Just Published**

This summary of recently issued publications (www.iec.ch/online_news/_justpub) is also available by email. Please contact the Customer Service Centre (see below) for further information.

- **Customer Service Centre**

If you have any questions regarding this publication or need further assistance, please contact the Customer Service Centre:

Email: custserv@iec.ch
Tel: +41 22 919 02 11
Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

IEC
61788-3

Second edition
2006-04

Superconductivity –

**Part 3:
Critical current measurement –
DC critical current of Ag- and/or Ag alloy-sheathed
Bi-2212 and Bi-2223 oxide superconductors**

IECNORM.COM : Click to view the full PDF of IEC 61788-3:2006

© IEC 2006 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE

T

For price, see current catalogue

CONTENTS

FOREWORD	3
INTRODUCTION	5
1 Scope	6
2 Normative reference	6
3 Terms and definitions	6
4 Principle	8
5 Requirements	8
6 Apparatus	8
7 Specimen preparation	9
8 Measurement procedure	10
9 Precision and accuracy of the test method	11
10 Calculation of results	12
11 Test report	13
Annex A (informative) Additional information relating to Clauses 1 to 10	15
Annex B (informative) Magnetic hysteresis of the critical current of high-temperature oxide superconductors	21
Bibliography	23
Figure 1 – Intrinsic U - I characteristic	14
Figure 2 – U - I characteristic with a current transfer component	14
Figure A.1 – Illustration of a measurement configuration for a short specimen of a few hundred A class conductors	20
Figure A.2 – Illustration of superconductor simulator circuit	20
Table A.1 – Thermal expansion data of Bi-oxide superconductor and selected materials	19

INTERNATIONAL ELECTROTECHNICAL COMMISSION

SUPERCONDUCTIVITY –

**Part 3: Critical current measurement –
DC critical current of Ag- and/or Ag alloy-sheathed
Bi-2212 and Bi-2223 oxide superconductors**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61788-3 has been prepared by IEC technical committee 90: Superconductivity.

This second edition cancels and replaces the first edition published in 2000. Modifications made to the second version mostly involve wording and essentially include no technical changes. Examples of technical changes introduced include the voltage lead diameter being smaller than 0,21 mm and the mode of expression for magnetic field accuracy being $\pm 1\%$ and $\pm 0,02\text{ T}$ instead of 1 %. The expression for magnetic field precision has been changed in the same way.

The text of this standard is based on the following documents:

FDIS	Report on voting
90/184/FDIS	90/190/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

IEC 61788 consists of the following parts, under the general title *Superconductivity*:

- Part 1: Critical current measurement – DC critical current of Cu/Nb-Ti composite superconductors
- Part 2: Critical current measurement – DC critical current of Nb₃Sn composite superconductors
- Part 3: Critical current measurement – DC critical current of Ag- and/or Ag alloy-sheathed Bi-2212 and Bi-2223 oxide superconductors
- Part 4: Residual resistance ratio measurement – Residual resistance ratio of Nb-Ti composite superconductors
- Part 5: Matrix to superconductor volume ratio measurement – Copper to superconductor volume ratio of Cu/Nb-Ti composite superconductors
- Part 6: Mechanical properties measurement – Room temperature tensile test of Cu/Nb-Ti composite superconductors
- Part 7: Electronic characteristic measurements – Surface resistance of superconductors at microwave frequencies
- Part 8: AC loss measurements – Total AC loss measurement of Cu/Nb-Ti composite superconducting wires exposed to a transverse alternating magnetic field by a pickup coil method
- Part 9: Measurements for bulk high temperature superconductors – Trapped flux density of large grain oxide superconductors
- Part 10: Critical temperature measurement – Critical temperature of Nb-Ti, Nb₃Sn, and Bi-system oxide composite superconductors by a resistance method
- Part 11: Residual resistance ratio measurement – Residual resistance ratio of Nb₃Sn composite superconductors
- Part 12: Matrix to superconductor volume ratio measurement – Copper to non-copper volume ratio of Nb₃Sn composite superconducting wires
- Part 13: AC loss measurements – Magnetometer methods for hysteresis loss in Cu/Nb-Ti multifilamentary composites

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

INTRODUCTION

In 1986 J.G. Bednorz and K.A. Mueller discovered that some Perovskite type Cu-containing oxides show superconductivity at temperatures far above those which metallic superconductors have shown. Since then, extensive R & D work on high-temperature oxide superconductors has been and is being made worldwide, and its application to high-field magnet machines, low-loss power transmission, electronics and many other technologies is in progress [1].¹⁾

Fabrication technology is essential to the application of high-temperature oxide superconductors. Among high-temperature oxide superconductors developed so far, BiSrCaCu oxide (Bi-2212 and Bi-2223) superconductors have been the most successful at being fabricated into wires and tapes of practical length and superconducting properties. These conductors can be wound into a magnet to generate a magnetic field of several tesla [2]. It has also been shown that Bi-2212 and Bi-2223 conductors can substantially raise the limit of magnetic field generation by a superconducting magnet [3].

In summer 1993, VAMAS-TWA16 started working on the test methods of critical currents in Bi-oxide superconductors. In September 1997, the TWA16 worked out a guideline (VAMAS guideline) on the critical current measurement method for Ag-sheathed Bi-2212 and Bi-2223 oxide superconductors. This pre-standardization work of VAMAS was taken as the base for the IEC standard, described in the present document, on the dc critical current test method of Ag-sheathed Bi-2212 and Bi-2223 oxide superconductors.

The test method covered in this International Standard is intended to give an appropriate and agreeable technical base to those engineers working in the field of superconductivity technology.

The critical current of composite superconductors like Ag-sheathed Bi-oxide superconductors depends on many variables. These variables need to be considered in both the testing and the application of these materials. Test conditions such as magnetic field, temperature and relative orientation of the specimen and magnetic field are determined by the particular application. The test configuration may be determined by the particular conductor through certain tolerances. The specific critical current criterion may be determined by the particular application. It may be appropriate to measure a number of test specimens if there are irregularities in testing.

¹⁾ The numbers in brackets refer to the bibliography.

SUPERCONDUCTIVITY –

Part 3: Critical current measurement – DC critical current of Ag- and/or Ag alloy-sheathed Bi-2212 and Bi-2223 oxide superconductors

1 Scope

This part of IEC 61788 covers a test method for the determination of the dc critical current of short and straight Ag- and/or Ag alloy-sheathed Bi-2212 and Bi-2223 oxide superconductors that have a monolithic structure and a shape of round wire or flat or square tape containing mono- or multicores of oxides.

This method is intended for use with superconductors that have critical currents less than 500 A and n -values larger than 5. The test is carried out with and without an applying external magnetic field. For all tests in a magnetic field, the magnetic field is perpendicular to the length of the specimen. In the test of a tape specimen in a magnetic field, the magnetic field is parallel or perpendicular to the wider tape surface (or one surface if square). The test specimen is immersed either in a liquid helium bath or a liquid nitrogen bath during testing. Deviations from this test method that are allowed for routine tests and other specific restrictions are given in this standard.

2 Normative reference

The following referenced document is indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-815:2000, *International Electrotechnical Vocabulary (IEV) – Part 815: Superconductivity*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60050-815, several of which have been repeated here for convenience, and the following apply.

3.1 critical current

I_c
maximum direct current that can be regarded as flowing without resistance

NOTE I_c is a function of magnetic field strength and temperature.

[IEV 815-03-01]

3.2 critical current criterion

I_c criterion
criterion to determine the critical current, I_c , based on the electric field strength, E or the resistivity, ρ

NOTE 1 $E = 10 \mu\text{V/m}$ or $E = 100 \mu\text{V/m}$ is often used as the electric field strength criterion, and $\rho = 10^{-13} \Omega \cdot \text{m}$ or $\rho = 10^{-14} \Omega \cdot \text{m}$ is often used as the resistivity criterion.

NOTE 2 For short high temperature oxide superconductor specimens, less sensitive criteria than those shown in Note 1 are sometimes used.

[IEV 815-03-02, modified]

3.3

n-value (of a superconductor)

exponent obtained in a specific range of electric field strength or resistivity when the voltage/current U - I curve is approximated by the equation $U \propto I^n$

NOTE In the case for high temperature oxide superconductors, the equation $U \propto I^n$ does not hold in a wide range of U .

[IEV 815-03-10, modified]

3.4

quench

uncontrollable and irreversible transition of a superconductor or a superconducting device from the superconducting state to the normal conducting state

NOTE A term usually applied to superconducting magnets.

[IEV 815-03-11]

3.5

Lorentz force (on fluxons)

force applied to fluxons by a current

NOTE 1 The force per unit volume is given by $\mathbf{J} \times \mathbf{B}$, where \mathbf{J} is a current density, and \mathbf{B} is a magnetic flux density.

NOTE 2 "Lorentz force" is defined in IEV 121-11-20.

[IEV 815-03-16]

3.6

current transfer (of composite superconductor)

phenomenon that a dc current transfers spatially from filament to filament in a composite superconductor, resulting in a voltage generation along the conductor

NOTE In the I_c measurement, this phenomenon appears typically near the current contacts where the injected current flows along the conductor from periphery to inside until uniform distribution among filaments is accomplished.

3.7

constant sweep rate method

a U - I data acquisition method where a current is swept at a constant rate from zero to a current above I_c while continuously or frequently and periodically acquiring U - I data

3.8

ramp-and-hold method

a U - I data acquisition method where a current is ramped to a number of appropriately distributed points along the U - I curve and held constant at each one of these points while acquiring a number of voltages and current readings

3.9

Bi-2212 and Bi-2223 oxide superconductors

oxide superconductors with layered structure containing CuO_2 sheets and chemical formulae, $\text{Bi}_2\text{Sr}_2\text{CaCu}_2\text{O}_x$ ($x = \sim 8$) and $(\text{Bi},\text{Pb})_2\text{Sr}_2\text{Ca}_2\text{Cu}_3\text{O}_x$ ($x = \sim 10$), respectively

4 Principle

The critical current of a composite superconductor is determined from a voltage (U) - current (I) characteristic measured at a certain value of a static applied magnetic field strength (magnetic field) and at a specified temperature in a liquid cryogen bath at a constant pressure. To get a U - I characteristic, a direct current is applied to the superconductor specimen and the voltage generated along a section of the specimen is measured. The current is increased from zero and the U - I characteristic generated is recorded. The critical current is determined as the current at which a specific electric field strength criterion (electric field criterion) (E_c) or resistivity criterion (ρ_c) is reached. For either E_c or ρ_c , there is a corresponding voltage criterion (U_c) for a specified voltage tap separation.

5 Requirements

The target precision of this method is a coefficient of variation (standard deviation divided by the average of the critical current determinations) that is less than 5 % for the measurement at 0 T and near 4,2 K or 77 K.

The use of a common current transfer correction is excluded from this test method. Furthermore, if a current transfer signature is pronounced in the measurement, then the measurement shall be considered invalid.

It is the responsibility of the user of this standard to consult and establish appropriate safety and health practices and to determine the applicability of regulatory limitations prior to use. Specific precautionary statements are given below.

Hazards exist in this type of measurement. Very large direct currents with very low voltages do not necessarily provide a direct personal hazard, but accidental shorting of the leads with another conductor, such as tools or transfer lines, can release significant amounts of energy and cause arcs or burns. It is imperative to isolate and protect current leads from shorting. Also the energy stored in the superconducting magnets commonly used for the background magnetic field can cause similar large current and/or voltage pulses or deposit large amounts of thermal energy in the cryogenic systems, causing rapid boil-off or even explosive conditions. Under rapid boil-off conditions, cryogens can create oxygen-deficient conditions in the immediate area and additional ventilation may be necessary. The use of cryogenic liquids is essential to cool the superconductors to allow the transition into the superconducting state. Direct contact of skin with cold liquid transfer lines, storage Dewars or apparatus components can cause immediate freezing, as can direct contact with a spilled cryogen. If improperly used, liquid helium storage Dewars can freeze air or water in pressure vent lines and cause the Dewar to over-pressurize and fail despite the common safety devices. It is imperative that safety precautions for handling cryogenic liquids be observed.

6 Apparatus

6.1 Measurement holder material

The measurement holder shall be made from an insulating material or from a conductive non-ferromagnetic material that is either covered or not covered with an insulating layer.

The critical current may inevitably depend on the measurement holder material due to the strain induced by the differential thermal contraction between the specimen and the measurement holder.

The total strain induced in the specimen at the measuring temperature shall be minimized to be within $\pm 0,1\%$. If there is an excess strain due to the differential thermal contraction of the specimen and the holder, the critical current shall be noted to be determined under an excess strain state by identification of the holder material.

Suitable measurement holder materials are recommended in A.3.1. Any one of these may be used.

When a conductive material is used without an insulating layer, the leakage current through the holder shall be less than 1 % of the total current when the specimen current is at I_c (see 9.5).

6.2 Measurement holder construction

The holder shall have a flat surface on which a straight specimen can be placed.

The current contact shall be rigidly fastened to the measurement holder to avoid stress concentration in the region of transition between the holder and the current contact. It is important to have no difference in level between the mounting surfaces of the current contacts and the specimen holder.

6.3 Measurement set up

The apparatus to measure the U - I characteristic of the superconductor specimen consists of a specimen probe, a test cryostat, a magnet system and a U - I measurement system.

The specimen probe, which consists of a specimen, a measurement holder and a specimen support structure, is inserted in the test cryostat filled with liquid cryogen. In some cases the cryostat contains a superconducting solenoid magnet and its support structure to apply a magnetic field to the specimen. The U - I measurement system consists of a dc current source, a recorder and necessary preamplifiers, filters or voltmeters, or a combination thereof. A computer assisted data acquisition system is also allowed.

7 Specimen preparation

7.1 Reaction heat treatment

Reaction heat treatment shall be carried out according to the manufacturer's specification which includes reaction temperature, period and atmosphere, oxygen partial pressure, specimen warming and cooling rates, specimen protection method against mechanical strain, examination of deformation and surface condition of specimen and error limits which shall not be exceeded. Temperature variations within the furnace shall be controlled such as not to exceed those limits.

Reaction heat treatment can be skipped when it has already been carried out by the manufacturer.

7.2 Specimen mounting for measurement

After the reaction heat treatment, the ends of the specimen shall be trimmed to suit the measurement holder.

When using resistivity criteria for the critical current determination, the total cross-sectional area S of the specimen shall be determined to an accuracy of 5 %.

The specimen shall be mounted to the flat surface of the holder and both ends shall be soldered to the current contact blocks (see Clause A.5 for solder material).

For the test in magnetic fields, a low-temperature adhesive (such as epoxy) shall be used to bond the specimen to the measurement holder to reduce specimen motion against the Lorentz force.

For a tape specimen, the bond shall be strong enough to keep the specimen in place against the Lorentz force, in the case where the applied magnetic field is perpendicular to the specimen surface.

The length of a specimen to be measured shall be defined as follows:

$$L_1 = 2 \times L_2 + L + 2 \times L_3 \geq 5 \times W \quad (1)$$

$$L_2, L, L_3 \geq W \quad (2)$$

where

L is the distance between the voltage taps;

L_1 is the length of a specimen to be measured;

L_2 is the length of the soldered part of the current contact;

L_3 is the shortest distance from a current contact to a voltage tap;

W is the width or diameter of a specimen to be measured.

For a specimen with a large current-carrying capacity, narrow tape, or round wire, L_2 shall be larger. L shall be larger for a measurement that needs high sensitivity and L_3 shall be larger when current transfer voltage cannot be neglected.

In the case of a specimen that has a stainless steel or other high-resistivity material backing or jacket, L_2 shall be longer than 3 W .

In the case of the wire specimen the angle between the specimen axis and the magnetic field shall be $(90 \pm 9)^\circ$. This angle shall be determined with an accuracy of $\pm 2^\circ$.

In the case of tape specimens, there are two options in addition to the requirement that the angle between the longitudinal specimen axis and the magnetic field shall be $(90 \pm 9)^\circ$. In one option, the magnetic field shall be perpendicular to the specimen surface, the angle deviation being within $\pm 7^\circ$. In the second option, the magnetic field shall be parallel to the specimen surface, the angle deviation being within $\pm 3^\circ$.

The voltage taps shall be placed in the central part along both the specimen length and the specimen width.

All soldering shall be conducted as quickly as possible so as not to cause thermal damage to the specimen. Voltage leads with a diameter less than 0,21 mm shall be used and twisted together before soldering.

The distance between the voltage taps, L , shall be measured to an accuracy of 5 %.

8 Measurement procedure

The specimen shall be immersed in cryogen for the data acquisition phase. The specimen may be cooled slowly in cryogen vapour and then inserted into the cryogen bath, or inserted slowly into the cryogen bath, or, in the case of cooling to the 4,2 K range, first slowly immersed in liquid nitrogen and then liquid helium. The specimen shall be cooled from room temperature to liquid helium (or liquid nitrogen) temperature over a time period of at least 5 min.

When measuring at more than one temperature or magnetic field angle, between each measuring temperature and/or each magnetic-field angle, the specimen shall be cooled in zero field, from a temperature above the critical temperature down to the measuring temperature, and then the field angle with respect to the conductor cross-section shall be fixed while the field is still zero. This procedural step can only be omitted if one of the following two conditions is met:

only zero applied field measurements will be made with monotonically increasing temperatures or the specimen has a demonstrated magnetic hysteresis of less than 2 % at the magnetic fields where I_c is to be reported (see Annex B).

The temperature of the cryogen bath shall be measured during each determination of I_c .

Unless a quench protection circuit or resistive shunt is used to protect the specimen from damage, the specimen current shall be kept low enough so that the specimen does not enter the normal state.

When using the constant sweep rate method, the time for the ramp from zero current to I_c shall be more than 30 s.

When using the ramp-and-hold method, the current sweep rate between current set points shall be lower than the equivalent of ramping from zero current to I_c in 3 s. Data acquisition at each set point shall be started as soon as the flow/creep voltage generated by the current ramp can be disregarded. The current drift during each current set point shall be less than 1 % of I_c .

The relation between the magnetic field and the magnet current shall be measured beforehand. The magnet current shall be measured before each determination of I_c .

If the magnetic field is parallel to the surface of the measurement holder, the relative direction of the current to the applied magnetic field shall result in the Lorentz force which pushes the specimen against the surface of the measurement holder. In the case of the applied magnetic field perpendicular to the measurement holder surface, either direction of the current relative to the field is possible, with the condition that the specimen is rigidly mounted to the measurement holder with appropriate adhesive.

Record the U - I characteristic with increasing current and at monotonically increasing magnetic fields (see Annex B).

The baseline voltage of the U - I characteristic shall be taken as the recorded voltage at zero current for the ramp-and-hold method or the average voltage at approximately 0,1 I_c for the constant sweep rate method.

9 Precision and accuracy of the test method

9.1 Critical current

The current source shall provide a dc current having a maximum periodic and random deviation of less than ± 2 % at I_c , within the bandwidth 10 Hz to 10 MHz.

A four-terminal standard resistor, with an accuracy of at least 0,5 %, shall be used to determine the specimen current.

A recorder and the necessary preamplifiers, filters or voltmeters, or a combination thereof, shall be used to record the U - I characteristic. The record of the U - I characteristic shall allow the determination of U_c to a precision of 10 % and the corresponding current to an accuracy of 1 % and with a precision of 1 %.

9.2 Temperature

A cryostat shall provide the necessary environment for measuring I_c and the specimen shall be measured while immersed in liquid helium or liquid nitrogen. The liquid temperature shall be reported to an accuracy of $\pm 0,1$ K, measured by means of a pressure sensor or an appropriate temperature sensor.

The difference between the specimen temperature and the bath temperature shall be minimized.

To convert the pressure observed in the cryostat into a temperature value, the phase diagram of helium or nitrogen shall be used. The pressure measurement shall be accurate enough to obtain the required accuracy of the temperature measurement.

9.3 Magnetic field

A magnet system shall provide the magnetic field to an accuracy better than the larger of $\pm 1\%$ and $\pm 0,02\text{ T}$ and a precision better than the larger of $\pm 0,5\%$ and $\pm 0,02\text{ T}$.

When testing without a magnet, the background magnetic field shall be measured to an accuracy of $\pm 0,0002\text{ T}$ and a precision of $\pm 0,0001\text{ T}$.

The magnetic field shall have a uniformity better than the larger of $0,5\%$ and $0,02\text{ T}$ over the length of the specimen between the voltage contacts.

The maximum periodic and random deviation of the magnetic field shall be less than the larger of $\pm 1\%$ and $\pm 0,02\text{ T}$.

For critical current measurements at zero or very low magnetic field, the residual magnetic field in a superconducting magnet shall be minimized.

9.4 Specimen and holder support structure

The support structure shall provide adequate support for the specimen and the orientation of the specimen with respect to the magnetic field. The specimen support is adequate if it allows additional determinations of critical current with a precision of 2% .

9.5 Specimen protection

If a resistive shunt or a quench protection circuit is used in parallel with the specimen, then the current through the shunt or the circuit shall be less than 1% of the total current at I_c .

10 Calculation of results

10.1 Critical current criteria

The critical current I_c shall be determined by using an electric field criterion E_c or a resistivity criterion ρ_c where the total cross-sectional area S of the composite superconductor is preferred for the estimation of the resistivity (see Figures 1 and 2).

In the case of the electric field criterion, two values of I_c shall be determined at criteria of $100\text{ }\mu\text{V/m}$ and $500\text{ }\mu\text{V/m}$. In the other case, two values of I_c shall be determined at the resistivity criteria of $2 \times 10^{-13}\text{ }\Omega\text{m}$ and $10^{-12}\text{ }\Omega\text{m}$.

When it is difficult to measure the I_c properly at a criterion of $500\text{ }\mu\text{V/m}$, an E_c criterion of less than $500\text{ }\mu\text{V/m}$ shall be substituted. Otherwise, measurements using the resistivity criterion are recommended.

The I_c shall be determined as the current corresponding to the point on the U - I curve where the voltage is U_c measured relative to the baseline voltage (see Figures 1 and 2):

$$U_c = L E_c \quad (3)$$

where

U_c is the voltage criterion in microvolts (μV);
 L is the voltage tap separation in meters (m);
 E_c is the electric field criterion in microvolts/meter ($\mu\text{V/m}$);
or, when using a resistivity criterion:

$$U_c = I_c \rho_c L/S \quad (4)$$

where U_c , I_c and ρ_c are the corresponding voltage, current and resistivity to the intersecting point of a straight line with the U - I curve as shown in Figure 1, and S is the total cross-sectional area in square meters.

A straight line shall be drawn from the baseline voltage to the average voltage near $0,5 I_c$ (see Figures 1 and 2). A finite slope of this line may be due to current transfer and/or local sample damage. A valid determination of I_c requires that the slope of the line be less than $0,3 U_c/I_c$, where U_c and I_c are determined at a criterion of $100 \mu\text{V/m}$ or $2 \times 10^{-13} \Omega\text{m}$.

10.2 n -value (optional)

The n -value shall be calculated as the slope of the plot of $\log U$ versus $\log I$ in the region where the I_c is determined.

The range of the criteria used to determine n shall be reported.

11 Test report

11.1 Identification of test specimen

The test specimen shall be identified, if possible, by the following:

- name of the manufacturer of the specimen;
- classification and/or symbol;
- lot number;
- raw materials and their chemical composition;
- shape and area of the cross-section of the wire, number of cores, diameter of cores, volume fractions of cores to Ag and/or Ag alloy sheath, and other components in the wire;
- manufacturing process technique.

11.2 Report of I_c values


The I_c values, along with their corresponding criteria, and n -values (optional) shall be reported.

11.3 Report of test conditions


The following test conditions shall be reported:

- test magnetic field strength, and orientation, uniformity and accuracy of field;
- test temperature and accuracy of temperature;
- length between voltage taps and total specimen length;
- the shortest distance from a current contact to a voltage tap;
- soldered length of the current contacts;
- the specimen bonding method, including identification of the bonding material;

- g) Lorentz force direction;
- h) sample history with magnetic field sweep;
- i) sample history with temperature variation;
- j) sample history with current sweep and hold.




(a)




(b)

NOTE The application of the (a) electric field and (b) resistivity criteria to determine the critical current is shown above.

Figure 1 – Intrinsic U-I characteristic

(a)



(b)

NOTE The application of the (a) electric field and (b) resistivity criteria to determine the critical current on a U-I characteristic with a current transfer component exhibited as a linear region at low current is shown above.

Figure 2 – U-I characteristic with a current transfer component

Annex A (informative)

Additional information relating to Clauses 1 to 10

A.1 Scope

There are a large number of variables that have a significant effect on the measured value of critical current in Ag- and/or Ag alloy-sheathed Bi-2212 and Bi-2223 oxide superconductor wires and tapes. However, significant portions of the test method covered in this standard are common or similar to those for Nb_3Sn composite superconductors (IEC 61788-2). Thus, only part of these variables will be addressed in this informative annex. For those variables that are not mentioned here, refer to IEC 61788-2.

Special features found for oxide superconductors may be classified into two groups. The first group is specific to oxide composite superconductors, including mechanical fragility, electromagnetic weak links, cryogen gas bubble formation, aging degradation, magnetic flux flow and creep, large anisotropy, hysteresis in critical current with magnetic field sweep, etc. The second group is due to the short length of the specimen used in the standard. A critical current measurement on such a specimen may easily pick up different voltage signals due to thermal electromotive force, inductive voltage, thermal noise, current redistribution, specimen motion relative to the holder, etc. Current transfer voltages may be present due to the short distance from a current contact to a voltage tap. Short specimen length may reduce mechanical tolerance against the Lorentz force, for example, by promoting the formation of cryogen gas bubbles within the composite.

Superconductors with critical currents above 500 A could be measured with the present standard with an anticipated reduction both in accuracy and precision and a more significant self-field effect.

The reason for the restrictions in this test method is to obtain the necessary precision in the final definitive phase of long conductor qualification.

This standard assumes that measurements are made either in liquid helium or liquid nitrogen. However, it is generally accepted that, if these measurements can be made in liquid helium, then they can be made in other cryogens, such as liquid neon and liquid hydrogen, because the heat of vaporization of liquid helium is low compared to other cryogens. Thus, this standard should extend to measurements conducted in other cryogens.

Cryogens (including nitrogen, helium, neon, and hydrogen) are used at temperatures near boiling point for the normal atmospheric pressure of the test site. The use of cryogens at temperatures other than near boiling point, or measurements in a gas or a vacuum are not covered by the scope of this standard.

A.2 Requirements

The minimum total length of the tape specimen is five times the tape width (W), which represents the sum of the following:

- the soldered length of current contacts (2 W);
- the shortest distance between current and voltage contacts (2 W);
- the minimum voltage tap separation (1 W).

The target precision of the method described in this standard is defined by the results of an interlaboratory comparison. Results from the previous VAMAS interlaboratory comparisons (the regional and the general intercomparisons) were used in this test method to formulate the tolerances of the many variables that affect the precision of critical current measurements. The target precision, for an interlaboratory comparison, is a coefficient of variation (standard deviation divided by the average of critical current determination) that is less than 5 % for the measurement at 0 T and near 4,2 K or 77 K.

It is expected that the specimen mounting and the specimen cooling procedures in this test method may be one of the most significant contributors to the overall uncertainty of the critical current measurement.

In the case of routine tests where it is impractical to adhere to these specific restrictions, this standard can be used as a set of general guidelines with an anticipated reduction in precision.

The test method for determining the I_c values of Ag- and/or Ag alloy-sheathed Bi-oxide superconducting wires and tapes excluded from the present test method may be addressed in future documents.

In the case of measurements made in liquid hydrogen, additional safety precautions may be required since hydrogen leakage into air can result in accidental gas explosion.

A.3 Apparatus

A.3.1 Measurement holder material

In this method, the specimen strain is controlled to a minimum (less than 0,1 %). A 0,1 % thermal contraction may result in no appreciable I_c deviation at 0 T and near 4,2 K or 77 K. One significant source of strain is the mismatch in thermal contraction rates between the measurement holder and the specimen when cooled to liquid helium or nitrogen temperature.

Based on the typical thermal contractions shown in table A.1, the following materials are suggested for the measurement holder material. For alternate holder materials, a carefully prepared qualification study should precede the routine tests.

Recommended holder material:

- fibreglass epoxy composite, with the specimen lying in the plane of the fabric wrap;
- ceramic dispersed epoxy;
- Ag/Ag alloy.

The leakage current through a conductive holder without an insulating layer can be estimated by making measurements under test conditions with and without a specimen on the holder. The measurement of the voltage drop from current contact to current contact without a specimen and under test conditions can be used to estimate the resistance of the leakage path including contact resistance. Then, measurement of the voltage drop from current contact to current contact with a specimen and under test conditions can be used to estimate leakage current.

A.3.2 Measurement holder construction

An example of a measurement holder is shown in Figure A.1. Typically, the current contacts are made from copper blocks, and the thickness of the contact should be determined so that there will be no difference in level between the holder surface and the contact surfaces; the contact blocks need to be rigidly affixed to the holder.

A.4 Specimen preparation

Extreme care must be taken in trimming and mounting the specimen after the reaction so as not to damage the specimen.

Specimen motion can damage the specimen and result in a premature quench (irreversible thermal runaway), voltage noise and ultimately a reduction in the repeatability of critical current.

It is recommended that a low-temperature adhesive, such as epoxy, be used to secure the specimen to the holder.

A rough and clean surface on the measurement holder and a clean surface on the specimen are needed for strong specimen bonding.

The low-temperature adhesive should withstand the heat from soldering.

The low-temperature adhesive should be a thin layer between the specimen and the holder surface.

After the low-temperature adhesive is applied, the specimen should be pressed to the holder with a pressure that does not damage the specimen.

The distance between the voltage taps is defined as the smallest distance between the soldered leads, irrespective of the sizes of the solder spots.

A.5 Measurement procedure

The specimen support structure is needed to hold the specimen in the centre of the background magnet in a liquid helium or nitrogen cryostat and to support current and voltage leads between room and measurement temperatures.

To reduce thermoelectric voltages on the specimen voltage leads, copper voltage leads are used which are continuous from the cryogen bath to room temperature where an isothermal environment for all room temperature joints or connections is provided. It should be noted that the joints or connections immersed in cryogen are isothermal.

As soldering material, Indium, Indium alloys or Bismuth alloys with a low melting temperature are preferable, although usual Pb-60 % Sn and Pb-70 % Sn are also applicable.

The specimen cooling rate may affect the measured critical current. The strength of the bond between the specimen and its holder changes during the cooling process when differential thermal contraction between the specimen and the holder is also occurring. This may result in disabling the low-temperature adhesive.

Oxygen impurities can cause boiling temperature variation of liquid nitrogen in the test cryostat if it is not tightly sealed. Liquid nitrogen stored in a non-pressurized Dewar for several weeks will condense enough oxygen impurities to shift the boiling point.

If the system noise is significant compared to the prescribed value of voltage, i.e. U_c , it is desirable to increase the time for the ramp from zero current to I_c to more than 150 s. In this case, care should be taken to increase the heat capacity and/or cooling surface of the current contacts enough to suppress the influence of heat generation due to the longer time required for the measurement. It should be noted that the ramp-and-hold method allows for averaging data which can be appropriately distributed along the U - I characteristic.

Ramping the specimen current can induce a positive or negative voltage on the voltage taps with time. This source of interfering voltage during the ramp can be identified by its proportional dependence on ramp rate. If this voltage is significant compared to U_c , then decrease the ramp rate, decrease the area of the loop formed by the voltage taps and the specimen between them, or else use the ramp-and-hold method.

Faster current ramp rates can be used for the ramp-and-hold method if the measurement system proves to yield consistent results with the specified ramp rate equivalent to ramping from zero to I_c in 3 s. It is possible to obtain consistent results with ramp rates as high as 500 A/s on a conductor with critical current from 10 A to 200 A.

Specimen motion can induce noise spikes. The specimen holder should be tightly mounted to the support structure, while the support structure should be held rigid against the magnetic force.

The baseline voltage may include thermoelectric, off-set, ground-loop and common-mode voltages. It is assumed that these voltages remain relatively constant for the time it takes to record each U - I characteristic. Small changes in thermoelectric and off-set voltages can be approximately removed by measuring the baseline voltage before and after the U - I curve measurement and assuming a linear change with time. If the change in the baseline voltage is significant compared to U_c , then corrective action to the experimental configuration should be taken.

For critical current measurements at zero or very low magnetic fields, the residual magnetic field in a superconducting magnet shall be completely minimized or the use of a superconducting magnet shall be avoided. This is especially important for the measurements near liquid nitrogen temperature.

A.6 Precision and accuracy of the test method

An optional method for partially assessing the overall precision of a laboratory's critical current measurement system is to obtain and measure a superconductor simulator (Figure A.2) originally developed at the National Institute of Standards and Technology, Boulder, Colorado, USA [4].

A.7 Calculation of results

A.7.1 Critical current criteria

For some applications, the non-Ag (or non-Ag alloy) cross-sectional area is used in the resistivity criterion. It can be determined by using a graphical analysing method.

A larger separation between current and voltage connections may be necessary if a significant current transfer component exists relative to the criteria.

A.7.2 n -value

The superconductor's U - I characteristic curve near the I_c can usually be approximated by the empirical power-law equation:

$$U = U_0(I/I_0)^n \quad (\text{A.1})$$

where

U is the specimen voltage in microvolts (μV);

U_0 is a reference voltage in microvolts (μV);

I is the specimen current in amperes (A);

I_0 is a reference current in amperes (A).