

NFPA

220

TYPES OF

BUILDING CONSTRUCTION 1979



NATIONAL FIRE PROTECTION ASSN.
LIBRARY
470 ATLANTIC AVENUE
BOSTON, MASS. 02210

Copyright © 1979

All Rights Reserved

NATIONAL FIRE PROTECTION ASSOCIATION, INC.

470 Atlantic Avenue, Boston, MA 02210

4M-7-79-FP

Printed in U.S.A.

NOTICE

All questions or other communications relating to this document should be sent only to NFPA Headquarters, addressed to the attention of the Committee responsible for the document.

For information on obtaining Formal Interpretations of the document, proposing Tentative Interim Amendments, proposing amendments for Committee consideration, and appeals on matters relating to the content of the document, write to the Assistant Vice President—Standards, National Fire Protection Association, 470 Atlantic Avenue, Boston, MA 02210.

Licensing Provision — This document is copyrighted by the National Fire Protection Association (NFPA).

1. Adoption by Reference — Public authorities and others are urged to reference this document in laws, ordinances, regulations, administrative orders or similar instruments. Any deletions, additions and changes desired by the adopting authority must be noted separately. Those using this method are requested to notify the NFPA (Attention: Assistant Vice President — Standards) in writing of such use. The term "adoption by reference" means the citing of title and publishing information only.

2. Adoption by Transcription — **A.** Public authorities with law-making or rule-making powers only, upon written notice to the NFPA (Attention: Assistant Vice President — Standards), will be granted a royalty-free license to print and republish this document in whole or in part, with changes and additions, if any, noted separately, in laws, ordinances, regulations, administrative orders or similar instruments having the force of law, provided that: (1) due notice of NFPA's copyright is contained in each law and in each copy thereof; and, (2) that such printing and republication is limited to numbers sufficient to satisfy the jurisdiction's law-making or rule-making process. **B.** Public authorities with advisory functions and all others desiring permission to reproduce this document or its contents in whole or in part in any form shall consult the NFPA.

All other rights, including the right to vend, are retained by NFPA.

(For further explanation, see the Policy Concerning the Adoption, Printing and Publication of NFPA Documents which is available upon request from the NFPA.)

Statement on NFPA Procedures

This material has been developed under the published procedures of the National Fire Protection Association, which are designed to assure the appointment of technically competent Committees having balanced representation. While these procedures assure the highest degree of care, neither the National Fire Protection Association, its members, nor those participating in its activities accepts any liability resulting from compliance or noncompliance with the provisions given herein, for any restrictions imposed on materials or processes, or for the completeness of the text.

NFPA has no power or authority to police or enforce compliance with the contents of this document and any certification of products stating compliance with requirements of this document is made at the peril of the certifier.

See Official NFPA Definitions at the back of this pamphlet.

© 1979 NFPA, All Rights Reserved

Standard on Types of Building Construction

NFPA 220 — 1979

1979 Edition of NFPA 220

The following text on Standard on Types of Building Construction has been prepared by the NFPA Committee on Building Construction and was adopted by the National Fire Protection Association, Inc., on May 16, 1979 at its Annual Meeting in St. Louis, MO. It was released for publication by the Standards Council on June 11, 1979. The descriptions included are intended to identify only those factors necessary to define building types. This particular edition represents a limited revision but includes a substantial change with reference to the classification of types of construction as contained in Chapter 3.

Origin and Development of NFPA 220

In 1952, the Committee on Building Construction secured tentative adoption of Standard Types of Building Construction at the NFPA Annual Meeting. At the 1954 NFPA Annual Meeting, revisions of the 1952 tentative text were adopted by the Association, and in 1955 minor revisions were also acted upon favorably. A new definition of "noncombustibility" and editorial changes in the description of the fire resistance rating of structural members (under the definition of fire-resistive construction) were adopted at the 1956 NFPA Annual Meeting on recommendation of the Committee on Building Construction.

In 1958, with the use of plastics in building construction, recommendations on the types of standard fire tests to be used in evaluating the fire safety of these materials were adopted and inserted in the Appendix.

In 1961, an Appendix was adopted to furnish a guide to NFPA Committees, regulatory officials, and others relative to the classification of air supported structures.

In 1975, a more fundamental definition for noncombustible was added including the introduction of "limited combustible" based on potential heat value limitations and more generalized definitions for types of building construction.

Correlating Committee on Building Construction

Donald W. Belles, *Chairman*
Madison, TN

John R. Anderson†, *Secretary*
National Fire Protection Association, Inc.

John L. Bryant†, University of Maryland,
Dept. of Fire Protection Engineering

John G. Degenkolb, Glendale, CA

George W. Flach†, (Rep. NFPA National
Electrical Code Comm.)

Harold E. Nelson, Center for Fire Research,
U.S. National Bureau of Standards

Chester W. Schirmer, Schirmer Engineering
Corp.

William A. Schmidt, Office of Construction
(O8H), U.S. Veterans Administration

Richard H. Solomon, Naperville, IL

†Nonvoting

Technical Committee on Building Construction

Harold E. Nelson, *Chairman*
Center for Fire Research, U.S. National Bureau of Standards

Louis E. Almgren, The FPE Group

C. R. Beauchamp, New England Telephone
Co. (Rep. NFPA Industrial Fire Protection
Section)

Roland Bellman, Rolf Jensen & Associates,
Inc.

Michael F. Burke, Factory Mutual Research
Corp.

Thomas E. Burke, A. Kahn Associates, Archi-
tects & Engineers, Inc.

Herbert B. Carlsen, Gypsum Association

John P. Chleapas, Framingham Center, MA

William M. Connell, Port Authority of New
York (Rep. ANSI Comm. on Safety Stan-
dards for Const. and Demolition)

William A. De Grow, Argonaut Realty Divi-
sion, General Motors Corp.

William J. Downing, U.S. General Services
Administration

Cornelius Duffy, Jr., Deputy Fire Marshal,
Westport Fire Dept. (Rep. Fire Marshals As-
sociation of North America)

Dr. D. S. Ellifritt, Metal Building Manu-
facturers Association

Richard G. Gewain, American Iron & Steel
Institute

Christian Hansen, Insurance Services Office

Paul K. Heilstedt, Portland Cement Associ-
ation

K. W. Howell, Underwriters Laboratories
Inc.

Edwin B. Lancaster, Lancaster & Lancaster

Gerald E. Lingenfelter, American Insurance
Association

Donald T. Lyon, American Telephone &
Telegraph Co.

E. E. Miller, Industrial Risk Insurers

G. L. Nelson, Plastics Division, General
Electric Co. (Rep. National Electrical Manu-
facturers Association)

Alvin O. Peterson, Rogers Lovelock & Fritz

John Ed Ryan, National Forest Products
Association

Robert S. Strength, Monsanto Fire Safety
Center

Elmer W. Wetmore, Kemper Insurance Cos.
(Rep. Alliance of American Insurers)

Alternates

- | | |
|--|--|
| James P. Barris , Portland Cement Association
(Alternate to P. K. Heilstedt) | Wendell H. Couch , Kemper Insurance Cos.
(Alternate to E. M. Wetmore) |
| J. S. Barritt , Industrial Risk Insurers (Alternate to E. E. Miller) | Sanford Davis , U.S. National Bureau of Standards, Center for Fire Research (Alternate to H. E. Nelson) |
| William I. Blazek , U.S. General Services Administration (Alternate to William Downing) | John L. Jablonsky , American Insurance Association (Alternate to G. E. Lingenfelter) |
| Delbert F. Boring, Jr. , American Iron & Steel Institute (Alternate to R. G. Gewain) | Herman Spaeth , Insurance Services Office (Alternate to C. Hansen) |
| David Brackett , Gypsum Association (Alternate to H. B. Carlsen) | Lyndon Welch , American Institute of Architects (Alternate to Edwin Lancaster) |
| R. B. Buchan , National Forest Products Association (Alternate to J. E. Ryan) | |

This list represents the membership at the time the Committee was balloted on the text of this edition. Since that time, changes in the membership may have occurred.

Contents

Chapter 1	General	220- 5
1-1	Purpose	220- 5
1-2	Scope	220- 5
1-3	Guide to Classification of Types of Construction	220- 5
Chapter 2	Definitions	220- 6
Chapter 3	Types of Construction	220- 8
3-1	Type I (443-332)	220- 8
3-2	Type II (222-111-000)	220- 8
3-3	Type III (211-200)	220- 8
3-4	Type IV (2HH)	220- 8
3-5	Type V (111-000)	220-11
Appendix A		220-12
Appendix B		220-13
Appendix C		220-14
Appendix D		220-15

Standard on Types of Building Construction

NFPA 220 — 1979

Chapter 1 General

1-1 Purpose. This Standard outlines basic definitions for standard types of building construction for reference by committees operating under the procedures of the National Fire Protection Association.

1-2 Scope. This Standard considers only those factors necessary to define building types. The requirements for partitions, fire separation partitions, shaft enclosures and fire walls, other than bearing walls and partitions, are not related to the construction types and need to be specified in other standards and codes, where appropriate. It is also necessary for the user to consider the influence of location, occupancy, exterior exposure, possibility of mechanical damage to fire protection material, and other features which may impose additional requirements for safeguarding life and property, as commonly covered in building codes.

1-3 Guide to Classification of Types of Construction. The types of construction include five basic types designated by Roman numerals as Type I, Type II, Type III, Type IV, and Type V. This system of designating types of construction also includes a specific breakdown of construction type through the use of Arabic numbers. These numbers follow the Roman numeral notation when naming a type of construction, e.g., Type I-443, Type II-111, Type III-200, etc.

The Arabic numbers following each basic type (Type I, Type II, etc.) designate the fire resistance rating requirements for certain structural elements as follows:

First Arabic Number — Exterior bearing walls.

Second Arabic Number — Structural frame or columns and girders, supporting loads for more than one floor.

Third Arabic Number — Floor construction.

Chapter 2 Definitions¹

2-1 Fire resistance rating is the time, in minutes or hours, that materials or assemblies have withstood a fire exposure as established in accordance with the test procedures of *Standard Methods of Fire Tests of Building Construction and Materials* (NFPA 251).²

2-2 Flame spread rating refers to numbers or classifications obtained according to the *Method of Test of Surface Burning Characteristics of Building Materials* (NFPA 255).

2-3 Limited-combustible as applied to a building construction material, means a material, *not complying with the definition of non-combustible material*, which, in the form in which it is used, has a potential heat value not exceeding 3500 Btu per pound (8141 Kj/Kg),³ and complies with one of the following paragraphs (a) or (b). Materials subject to increase in combustibility or flame spread rating beyond the limits herein established through the effects of age, moisture, or other atmospheric condition shall be considered combustible.

(a) Materials having a structural base of noncombustible material, with a surfacing not exceeding a thickness of $\frac{1}{8}$ of an inch (3.2 mm) which has a flame spread rating not greater than 50.

(b) Materials, in the form and thickness used, other than as described in (a), having neither a flame spread rating greater than 25 nor evidence of continued progressive combustion and of such composition that surfaces that would be exposed by cutting through the material on any plane would have neither a flame spread rating greater than 25 nor evidence of continued progressive combustion.

¹These definitions apply to the materials used in the construction of buildings, but do not apply to furnishings or the contents of buildings, or to the fire hazard evaluation of materials.

²The fire resistance of building construction varies with the susceptibility to damage by fire of the building materials used and the degree of fire protection, if any, provided for the structural members.

³See *Standard Test Method for Potential Heat of Building Materials*, NFPA 259.

2-4 Minimum hourly fire resistance rating is that degree of fire resistance deemed necessary by the authority having jurisdiction.

2-5 Potential heat value means the average value, in Btu per pound, obtained by testing a building material in accordance with the *Tentative Method of Test for Potential Heat of Materials in Building Fires* (ASTM Special Technical Publication 464, 1970, pp. 147-152).

2-6 Noncombustible material means a material which, in the form in which it is used and under the conditions anticipated, will not ignite, burn, support combustion, or release flammable vapors, when subjected to fire or heat. Materials reported as noncombustible, when tested in accordance with the *Standard Method of Test for Noncombustibility of Elementary Materials*, ASTM E-136, shall be considered noncombustible materials.

Chapter 3 Types of Construction

3-1 Type I (443-332).

3-1.1 Type I Construction is that type in which the structural members, including walls, columns, beams, floors, and roofs, are of approved noncombustible or limited-combustible materials and have fire resistance ratings not less than those set forth in Table 3.

3-2 Type II (222-111-000).

3-2.1 Type II Construction is that type not qualifying as Type I Construction in which the structural members including walls, columns, beams, floors, and roofs are of approved noncombustible or limited-combustible materials and have fire resistance ratings not less than those set forth in Table 3.

3-3 Type III (211-200).

3-3.1 Type III Construction is that type in which exterior walls and structural members which are portions of exterior walls are of approved noncombustible or limited-combustible materials, and interior structural members, including walls, columns, beams, floors, and roofs, are wholly or partly of wood of smaller dimensions than required for Type IV Construction or of approved noncombustible, limited-combustible, or other approved combustible materials. In addition, structural members have fire resistance ratings not less than those set forth in Table 3.

3-4 Type IV¹ (2HH).

3-4.1 Type IV Construction is that type in which exterior and interior walls and structural members which are portions of such walls are of approved noncombustible or limited-combustible materials. Other interior structural members including columns, beams, arches, floors and roofs are of solid or laminated wood without concealed spaces and comply with the provisions of 3-4.2 through 3-4.6. In addition, structural members have fire resistance ratings not less than those set forth in Table 3.

Exception No. 1: Interior columns, arches, beams, girders, and trusses of approved materials other than wood are permitted provided they are protected to provide a fire resistance rating of not less than 1 hour.

Exception No. 2: Certain concealed spaces are permitted by the Exception to 3-4.4.

¹ The dimensions used for sawn and glued laminated lumber in this Section 3-4 are nominal dimensions.

Table 3 Fire Resistance Requirements for Type I through Type V Construction

	Type I		Type II			Type III		Type IV	Type V	
	443	332	222	111	000	211	200	2HH	111	000
EXTERIOR BEARING WALLS —										
Supporting more than one floor, columns or other bearing walls	4	3	2	1	0 ¹	2	2	2	1	0 ¹
Supporting one floor only	4	3	2	1	0 ¹	2	2	2	1	0 ¹
Supporting a roof only	4	3	1	1	0 ¹	2	2	2	1	0 ¹
INTERIOR BEARING WALLS —										
Supporting more than one floor, columns or other bearing walls	4	3	2	1	0	1	0	2	1	0
Supporting one floor only	3	2	2	1	0	1	0	1	1	0
Supporting a roof only	3	2	1	1	0	1	0	1	1	0
COLUMNS —										
Supporting more than one floor, bearing walls or other columns	4	3	2	1	0	1	0	H ²	1	0
Supporting one floor only	3	2	2	1	0	1	0	H ²	1	0
Supporting a roof only	3	2	1	1	0	1	0	H ²	1	0
BEAMS, GIRDERS, TRUSSES & ARCHES —										
Supporting more than one floor, bearing walls or columns	4	3	2	1	0	1	0	H ²	1	0
Supporting one floor only	3	2	2	1	0	1	0	H ²	1	0
Supporting a roof only	3	2	1	1	0	1	0	H ²	1	0
FLOOR CONSTRUCTION	3	2	2	1	0	1	0	H ²	1	0
ROOF CONSTRUCTION	2	1½	1	1	0	1	0	H ²	1	0
EXTERIOR NONBEARING WALLS	0 ¹	0 ¹	0 ¹	0 ¹	0 ¹	0 ¹	0 ¹	0 ¹	0 ¹	0 ¹



Those members listed that are permitted to be of approved combustible material.

¹ Requirements for fire resistance of exterior walls, the provision of spandrel wall sections, and the limitation or protection of wall openings are not related to construction type. They need to be specified in other standards and codes, where appropriate, and may be required in addition to the requirements of this Standard for the construction type.

² "H" indicates heavy timber members; see text for requirements.

3-4.2 Wood columns supporting floor loads shall be not less than 8 inches (203 mm) in any dimension; wood columns supporting roof loads only shall be not less than 6 inches (152 mm) in least dimension and not less than 8 inches (203 mm) in depth.

3-4.3 Wood beams and girders supporting floor loads shall be not less than 6 inches (152 mm) in width and not less than 10 inches (254 mm) in depth; wood beams and girders and other roof framing, supporting roof loads only, shall be not less than 4 inches (102 mm) in width and not less than 6 inches (152 mm) in depth.

3-4.4 Framed or glued laminated arches which spring from grade or the floor line and timber trusses which support floor loads shall be not less than 8 inches (203 mm) in width or depth. Framed or glued laminated arches for roof construction which spring from grade or the floor line and do not support floor loads shall have members not less than 6 inches (152 mm) in width and not less than 8 inches (203 mm) in depth for the lower half of the height and not less than 6 inches (152 mm) in depth for the upper half. Framed or glued laminated arches for roof construction which spring from the top of walls or wall abutments and timber trusses which do not support floor loads shall have members not less than 4 inches (102 mm) in width and not less than 6 inches (152 mm) in depth.

Exception: Spaced members may be composed of two or more pieces not less than 3 inches (76 mm) in thickness when blocked solidly throughout their intervening spaces or when such spaces are tightly closed by a continuous wood cover plate not less than two inches (51 mm) in thickness, secured to the underside of the members.

Splice plates shall be not less than 3 inches (76 mm) in thickness.

3-4.5 Floors shall be constructed of splined or tongued and grooved plank not less than 3 inches (76 mm) in thickness covered with 1 inch (25 mm) tongue and groove flooring, laid crosswise or diagonally to the plank, or with $\frac{1}{2}$ inch (12.7 mm) plywood, or of laminated planks not less than 4 inches (102 mm) in width, set on edge close together, spiked at intervals of 18 inches (457 mm) and covered with 1 inch (25 mm) tongue and groove flooring laid crosswise or diagonally to the plank or with $\frac{1}{2}$ inch (12.7 mm) plywood.

3-4.6 Roof decks shall be of splined or tongued and grooved plank not less than 2 inches (51 mm) in thickness; or of laminated planks not less than 3 inches (76 mm) in width, set on edge close together, and laid as required for floors; or of $1\frac{1}{8}$ -inch (28.6-mm) thick interior plywood (exterior glue); or of approved noncombustible or limited-combustible materials of equal fire durability.

3-5 Type V (111-000).

3-5.1 Type V Construction is that type in which exterior walls, bearing walls, and floors and roofs and their supports are wholly or partly of wood or other approved combustible material smaller than required for Type IV Construction. In addition, structural members have fire resistance ratings not less than those set forth in Table 3.

Appendix A

This Appendix is not a part of this NFPA Standard, but is included for information purposes only.

A-1 Reference Publications.

A-1.1 NFPA Standards. This Publication makes reference to the following NFPA Standards and the year dates shown indicate the latest editions available:

(a) NFPA 102-1978, *Standard for Assembly Seating, Tents, and Air-Supported Structures.*

(b) NFPA 251-1979, *Standard Methods of Fire Tests of Building Construction and Materials.*

(c) NFPA 255-1979, *Method of Test of Surface Burning Characteristics of Building Materials.*

(d) NFPA 259-1976, *Standard Test Method for Potential Heat of Building Materials.*

A-1.2 Other Publications. This Standard makes reference to the following publications and the year date shown indicates the latest edition available:

(a) ASTM E-136-1973, *Standard Method of Test for Noncombustibility of Elementary Materials*, American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103.

Appendix B. Recommendations on Plastics in Building Codes and Standards

This Appendix is not a part of this NFPA Standard, but is included for information purposes only.

This Appendix is prepared to furnish guidance to NFPA committees and for the drafting of provisions, applying to plastics, which may be used in building codes.

Small-scale fire tests may provide misleading results in evaluating plastics for building materials. It is not proper to exempt plastics from recommendations as to fire hazard characteristics which building codes and standards specify for other building materials.

The use of standard fire tests for all building materials, including plastics, is recommended, particularly those for fire resistance of structural assemblies (NFPA 251, *Standard Methods for Fire Tests of Building Construction and Materials*) and for surface flame spread and other features (NFPA 255, *Method of Test of Surface Burning Characteristics of Building Materials*).

Appendix C. Classification of Air Supported Structures¹

This Appendix is not a part of this NFPA Standard, but is included for informational purposes only.

This Appendix is prepared to furnish guidance to NFPA committees, regulatory officials and others interested in the classification of air supported structures.

Air supported structures are enclosures which depend primarily on air pressure for their support. They are generally made of plastics and in most cases are directly supported by air pressure and in other cases the supports are air inflated columns, pillars or pilasters. A third type has a limited amount of structural steel supports.

The use of air for structural support raises the question of the proper classification of such structures for application of codes and standards.

These structures should *not* be classified as buildings for a number of reasons, some of which follow. Present codes and standards contemplate that the supporting members of buildings are of material such as steel, concrete and wood, which are considered to provide more dependable structural support than air pressure. Further, there is no means for supporting sprinklers, where such might be needed to protect the structure or the occupancy, nor can fire resistance ratings be readily obtained for portions of the structure which should have such ratings under certain conditions if they were classified as buildings. These factors clearly indicate that such structures cannot be made to comply with provisions normally applicable to buildings.

It is recommended that these structures be classed as tents, as they more closely resemble tents from a fire-protection standpoint and by classifying them as such, they can be made to comply with provisions applicable to tents, whether such provisions be in a building code, fire prevention code, or separate standards.

¹See also, NFPA 102, *Standard for Assembly Seating, Tents, and Air-Supported Structures*.

Appendix D. Potential Heat of Selected Building Materials¹

	Material	Thickness in.	Density lb./ft. ³	Potential Heat, Weight basis, BTU/lb.
1. WOODS				
a.	Douglas fir, untreated	¾	38.0	8,400
b.	Douglas fir (retardant treatment "A")	¾	37.2	8,290
c.	Douglas fir (retardant treatment "B")	¾	47.2	7,850
d.	Douglas fir (retardant treatment "C")	¾	38.8	7,050
e.	Maple soft, untreated	1	39.5	7,940
f.	Hardboard, untreated	¼	59.8	8,530
2. PLASTICS				
a.	Polystyrene, wall tile	0.075	65.4	17,420
b.	Rigid, polyvinyl chloride, retardant treated147	86.0	9,290
c.	Phenolic laminate063	76.4	7,740
d.	Polycarbonate resin	¼	78.7	13,330
3. INSULATION				
a.	Glass fiber, semirigid, no vapor barrier	1	3.0	3,040
b.	Rock wool batting, paper enclosure	3	2.4	1,050
c.	Roof insulation board	1	10.4	3,380
d.	Cork (reconstituted cork sheet) . .	¼	14.8	11,110
e.	Cellulose mineral board	2	47.8	2,250
4. CONCRETE				
a.	Cinder aggregate		93.0	3,080
b.	Slag aggregate		110.1	80
c.	Shale aggregate		80.5	10
d.	Calcareous gravel aggregate . . .		133.1	— 250
e.	Siliceous gravel aggregate		166.8	— 40
5. CEMENT BOARD				
a.	Asbestos cement board	¾ ₁₆	117.0	80
b.	Asbestos cement board + 20 mil paint	¾ ₁₆	159.2	390

¹*Proceedings of ASTM*, Vol. 61, 1961, pp. 1336-1348.